

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: 08-500 21755

Applicant:

Date Evaluated:

Address:

Property Size:

Proposed Facility: SFD

Design Flow (.1949): 360

Property Recorded:

Location of Site: 1125

Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
S J 7		0-38	GR SL	VFR SE					.L
		0-24	GR SL	VFR S-					
		24-30	SHK SCL	FR SE					
		30-38	SHK SL	PE S-	CR 2 C 36				.04
		0-38	GR SL	VFR S-					.L
		0-38	GR SL	VFR S-					.L
		0-8	GR SL	VFR S-					
		8-30	SHK SCL	FR S-	Dark				.04
		30-38	SHK SCL	FR S-	CR 2 C 34				.04
		0-12	GR SL	VFR S-					
		12-24	SHK SCL	FR S-					
		24-38	SHK SL	FR S-	CR 2 C 36				.35
		0-12	GR SL	VFR S-					
		12-24	SHK SCL	FR S-					
		24-38	SHK SL	FR S-	CR 2 C 36				.35

Description	Initial System	Repair System
Available Space (.1945)	/	/
System Type(s)	25%	Day
Site LTAR	.35	.35

Other Factors (.1946): _____
 Site Classification (.1948): P1
 Evaluated By: AW
 Others Present: no