

Property ID:
 Lot #:
 File #:
 Code:

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: 08-500-2398

Applicant:

Address:

Date Evaluated:

Proposed Facility: ~~SEW~~ SFD

Design Flow (.1949): 360

Property Size:

Location of Site: 1125

Property Recorded:

Water Supply: Public Individual Well

Spring Other

Evaluation Method: Auger Boring Pit

Cut

Type of Wastewater: Sewage Industrial Process

Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horz	
S 3%		0-18	Gr SL	UFR 5					.4 .5 .5 .6 .6
		18-38	SK JCL	Fu 5					
		18-48	SK SC	FF 5	ca 2 + 38				
		0-24	Gr SL	UFR 12					
		24-38	SK JCL	Fu 12					
		0-24	Gr SL	UFR 5					
		24-38	SK JCL	Fu 5					
		0-24	Gr SL	UFR 12					
		0-30	Gr SL	UFR 12					

Description	Initial System	Repair System
Available Space (.1945)		
System Type(s)	257	207
Site LTAR	.4	.4

Other Factors (.1946): _____
 Site Classification (.1948): B1
 Evaluated By: [Signature]
 Others Present: