

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: 08-800-21399

Applicant:

Address:

Date Evaluated:

Proposed Facility: SFA

Design Flow (.1949): 260

Property Size:

Location of Site: 1f25

Property Recorded:

Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

| P R O F I L E # | .1940 Landscape Position/ Slope% | Horizon Depth (IN.) | SOIL MORPHOLOGY .1941 | | OTHER PROFILE FACTORS | | | | Profile Class & LTAR |
|--------------------------------------|-------------------------------------------|---------------------------|--------------------------------|------------------------------------|------------------------------------|------------------------------|-------------------------|-------------------------|----------------------------|
| | | | .1941 Structure/ Texture | .1941 Consistence Mineralogy | .1942 Soil Wetness/ Color | .1943 Soil Depth (IN.) | .1956 Sapro Class | .1944 Restr Horiz | |
| 5 3% | | 032 | GR SL | VFA J | | | | | 2 |
| | | 032 | GR SL | VFA J | | | | | 2 |
| | | 032 | GR SL | VFA J | | | | | 2 |
| | | 024 | GR SL | VFA J | | | | | 5 |
| | | 243 | GR SL | FA I | | | | | 5 |
| | | 024 | GR SL | VFA J | | | | | 5 |
| | | 243 | GR SL | FA I | | | | | 5 |
| | | | | | | | | | |

| Description | Initial System | Repair System |
|-------------------------|----------------|---------------|
| Available Space (.1945) | / | / |
| System Type(s) | 25% | 25% |
| Site LTAR | .5 | .5 |

Other Factors (.1946): _____
 Site Classification (.1948): B1
 Evaluated By: [Signature]
 Others Present: