Department of Environment, Health, and Natural Resources
Division of Environmental Health
On-site Wastewater Section

Property ID:
Lot #:
File #:
Code:

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Owner: 09.520-21475 Applicant:

Address: Date Evaluated:

Proposed Facility: SFM Design Flow (.1949): 360 Property Size:

Location of Site: 1139 Property Recorded:

Water Supply: [X] Public [ ] Individual [ ] Well [ ] Spring [ ] Other

Evaluation Method: [X] Auger Boring [ ] Pit [ ] Cut

Type of Wastewater: [X] Sewage [ ] Industrial Process [ ] Mixed

PROFILE #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
	5	0-3	Gr SL	VFR					.6
	7Y								
		0-7	Gr SL	VFR					.6
		0-7	GRSL	VFR					.6
		0-8	Gr SL	VFR					.5
		30-3	SDHCL	VFR					

Description	Initial System	Repair System
Available Space (.1945)	—	—
System Type(s)	25%	25%
Site LTAR	.5	.5

Other Factors (.1946):

Site Classification (.1948): C1

Evaluated By: [illegible]

Others Present: