

Property ID:
 Lot #:
 File #:
 Code:

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner:

Applicant:

Address:

Date Evaluated:

Proposed Facility: 3 Bedroom

Design Flow (.1949): 360 gpd

Property Size:

Location of Site:

Property Recorded:

Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			1941 Structure/ Texture	1941 Consistence Mineralogy	1942 Soil Wetness/ Color	1943 Soil Depth (IN.)	1958 Sapro Class	1944 Restr. Hortz	
1	LS 2-5%	0-18"	G S	VFL NS/NP					PS .5
		18-28"	SBK SCL	FL SS/NP					
		28"-	SCL/PM	FL SS/NP	10-127/2 @ 34"				
2		0-36"	G S	VFL NS/NP					PS .6
		36-48"	G LS	VFL NS/NP					
3		0-48"	G S	VFL NS/NP					S.R
4		0-48"	G S	VFL NS/NP					S.R
5		0-98"	G S	VFL NS/NP					S.R
6		0-16"	G S	VFL NS/NP					US
		16-22"	SBK SCL	FL SS/NP					
		22"-	M SCL						

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	CON	CON
Site LTAR	.8	.6

3 x 50" @ 24-30"

Other Factors (.1946): _____

Site Classification (.1948): PS

Evaluated By: OT

Others Present: