

**SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM**

Owner:

Applicant:

Address:

Date Evaluated: 3/9/09

Proposed Facility: 3 BEDROOM HOME Design Flow (.1949): 360 gpd

Property Size:

Location of Site:

Property Recorded:

Water Supply: Public Individual Well Spring Other

Evaluation Method: Auger Boring Pit Cut

Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L5 0-2%	0-12"	G SL	VFR NS/MP					P5 .35
		12-24"	SBK SCL	FR SS/SP					
		24-38"	SBK CL	FR S/SP					
2		0-8"	G SL	VFR NS/MP					P5 .35
		8-22"	SBK SCL	FR SS/SP					
		22-46"	SBK SCL	FR S/SP					
3		0-12"	G SL	VFR NS/MP					P5 .35
		12-24"	SBK SCL	FR SS/SP					
		24-36"	SBK CL	FR S/SP					

Description	Initial System	Repair System
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
System Type(s)	25% RFD	25% RFD
Site LTAR	.35	.35

Other Factors (.1946): _____
 Site Classification (.1948): P5
 Evaluated By: OT
 Others Present:

3x90 @ 24"-18"
 STUB PLUMBING AT GROUND SURFACE OR PUMP WILL BE NEEDED