
ADDRESS : 112 TEAK WOOD CT SUBDIV: WOODSHIRE PH 5
 CONTRACTOR : CEBCO CONSTRUCTION INC PHONE : (910) 893-3331
 OWNER : KENNETH CUMMINGS LLC PHONE : (910) 984-6765
 PARCEL : 01-0536-06- -0028- -05-
 APPL NUMBER: 09-50021631 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 112 TEAK WOOD COURT, WOODSHIRE SUB DIV
 #163. HWY 27W, LEFT ON NURSERY, LEFT
 ON LEMUEL, LEFT ON WOODSHIRE, RIGHT
 SUNORA, LEFT TEAKWOOD, END OF STREET,
 112 TEAK WOOD COURT, #168.
 T/S: 02/26/2009 09:02 AM VBROWN -----

STRUCTURE: 000 000 66X56.7 4BDR 2.5BATH,GAR, DECK, CRAWL
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : CONTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/31/09	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001749291
	3/31/09	AP	
B103 01	4/02/09	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001750484
	4/02/09	AP	
B105 01	4/03/09	TI	R*OPEN FLOOR VRU #: 001750992
	<u>4/13/09</u>	<u>AP DT</u>	

----- COMMENTS AND NOTES -----

ADDRESS . . : 112 TEAK WOOD CT SUBDIV: WOODSHIRE PH 5
CONTRACTOR : CEBCO CONSTRUCTION INC PHONE : (910) 893-3331
OWNER . . . : KENNETH CUMMINGS LLC PHONE : (910) 984-6765
PARCEL . . . : 01-0536-06- -0028- -05-
APPL NUMBER: 09-50021631 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 112 TEAK WOOD COURT, WOODSHIRE SUB DIV
#163. HWY 27W, LEFT ON NURSERY, LEFT
ON LEMUEL, LEFT ON WOODSHIRE, RIGHT
SUNORA, LEFT TEAKWOOD, END OF STREET,
112 TEAK WOOD COURT, #168.
T/S: 02/26/2009 09:02 AM VBROWN ----

STRUCTURE: 000 000 66X56.7 4BDR 2.5BATH, GAR, DECK, CRAWL
FLOOD ZONE . . . : FLOOD ZONE X
BEDROOMS : 4.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : CONTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/31/09	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001749291
	3/31/09	AP	
B103 01	4/02/09	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001750484
	4/02/09	AP	
B105 01	4/03/09	DT	R*OPEN FLOOR VRU #: 001750992
	4/03/09	AP	
A814 01	4/07/09	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001750509
	4/08/09	AP	112 TEAK WOOD CT
R425 01	4/17/09	TI	FOUR TRADE ROUGH IN VRU #: 001756692
	<u>4/17/09</u>	<u>DA DT</u>	

----- COMMENTS AND NOTES -----

ADDRESS : 112 TEAK WOOD CT SUBDIV: WOODSHIRE PH 5
 CONTRACTOR : CEBCO CONSTRUCTION INC PHONE : (910) 893-3331
 OWNER : KENNETH CUMMINGS LLC PHONE : (910) 984-6765
 PARCEL : 01-0536-06- -0028- -05-
 APPL NUMBER: 09-50021631 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 112 TEAK WOOD COURT, WOODSHIRE SUB DIV
 #163. HWY 27W, LEFT ON NURSERY, LEFT
 ON LEMUEL, LEFT ON WOODSHIRE, RIGHT
 SUNORA, LEFT TEAKWOOD, END OF STREET,
 112 TEAK WOOD COURT, #168.
 T/S: 02/26/2009 09:02 AM VBROWN ----

STRUCTURE: 000 000 66X56.7 4BDR 2.5BATH,GAR, DECK, CRAWL
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : CONTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/31/09	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001749291
	3/31/09	AP	
B103 01	4/02/09	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001750484
	4/02/09	AP	
B105 01	4/03/09	DT	R*OPEN FLOOR VRU #: 001750992
	4/03/09	AP	
A814 01	4/07/09	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001750509
	4/08/09	AP	112 TEAK WOOD CT
R425 01	4/17/09	DT	FOUR TRADE ROUGH IN VRU #: 001756692
	4/17/09	DA	1. Trusses not in accordance with documents. 2. Fireplace not installed. 3. 2 plumbing vents missing boots. 4. Leak at hall bath tub trap.
R425 02	4/20/09	TI	FOUR TRADE ROUGH IN VRU #: 001757450
	4/20/09	AP DT	

COMMENTS AND NOTES

ADDRESS : 112 TEAK WOOD CT SUBDIV: WOODSHIRE PH 5
 CONTRACTOR : CEBCO CONSTRUCTION INC PHONE : (910) 893-3331
 OWNER : KENNETH CUMMINGS LLC PHONE : (910) 984-6765
 PARCEL : 01-0536-06- -0028- -05-
 APPL NUMBER: 09-50021631 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 112 TEAK WOOD COURT, WOODSHIRE SUB DIV
 #163. HWY 27W, LEFT ON NURSERY, LEFT
 ON LEMUEL, LEFT ON WOODSHIRE, RIGHT
 SUNORA, LEFT TEAKWOOD, END OF STREET,
 112 TEAK WOOD COURT, #168.
 T/S: 02/26/2009 09:02 AM VBROWN -----

STRUCTURE: 000 000 66X56.7 4BDR 2.5BATH,GAR, DECK, CRAWL
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : CONTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/31/09	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001749291
	3/31/09	AP	
B103 01	4/02/09	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001750484
	4/02/09	AP	
B105 01	4/03/09	DT	R*OPEN FLOOR VRU #: 001750992
	4/03/09	AP	
A814 01	4/07/09	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001750509
	4/08/09	AP	✓ 112 TEAK WOOD CT
R425 01	4/17/09	DT	FOUR TRADE ROUGH IN VRU #: 001756692
	4/17/09	DA	1. Trusses not in accordance with documents. 2. Fireplace not installed. 3. 2 plumbing vents missing boots. 4. Leak at hall bath tub trap.
R425 02	4/20/09	DT	FOUR TRADE ROUGH IN VRU #: 001757450
	4/20/09	AP	
I129 01	4/22/09	DT	R*INSULATION INSPECTION VRU #: 001758477
	4/22/09	AP	
H824 01	5/05/09	JW	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001765148
	5/05/09	AP	
R429 01	6/12/09	TI	FOUR TRADE FINAL VRU #: 001780889
	<u>6/12/09</u>	<u>AP DT</u>	

----- COMMENTS AND NOTES -----

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: Residential Conditional Use Permit No.: _____
Type of Construction: _____ Building Permit No.: _____
Owner of Building: Kenneth Cummings LLC Electrical Permit No.: _____
Building Address: 112 Teak Wood Ct Insulation Permit No.: _____
Zoning District: _____ Plumbing Permit No.: 09-50021631
Zoning Permit No.: _____ Mech. Permit No.: _____
Date: 6/12/09 Envir. C.O. No.: _____
D. E. Tyler
Building Official Zoning Official

ADDRESS : 112 TEAK WOOD CT SUBDIV: WOODSHIRE PH 5
 CONTRACTOR : CEBCO CONSTRUCTION INC PHONE : (910) 893-3331
 OWNER : KENNETH CUMMINGS LLC PHONE : (910) 984-6765
 PARCEL : 01-0536-06- -0028- -05-
 APPL NUMBER: 09-50021631 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 112 TEAK WOOD COURT, WOODSHIRE SUB DIV
 #163. HWY 27W, LEFT ON NURSERY, LEFT
 ON LEMUEL, LEFT ON WOODSHIRE, RIGHT
 SUNORA, LEFT TEAKWOOD, END OF STREET,
 112 TEAK WOOD COURT, #168.
 T/S: 02/26/2009 09:02 AM VBROWN ----

STRUCTURE: 000 000 66X56.7 4BDR 2.5BATH,GAR, DECK, CRAWL
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : CONTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/31/09	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001749291
	3/31/09	AP	
B103 01	4/02/09	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001750484
	4/02/09	AP	
B105 01	4/03/09	DT	R*OPEN FLOOR VRU #: 001750992
	4/03/09	AP	
A814 01	4/07/09	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001750509
	4/08/09	AP	112 TEAK WOOD CT
R425 01	4/17/09	DT	FOUR TRADE ROUGH IN VRU #: 001756692
	4/17/09	DA	1. Trusses not in accordance with documents. 2. Fireplace not installed. 3. 2 plumbing vents missing boots. 4. Leak at hall bath tub trap.
R425 02	4/20/09	DT	FOUR TRADE ROUGH IN VRU #: 001757450
	4/20/09	AP	
I129 01	4/22/09	TI	R*INSULATION INSPECTION VRU #: 001758477
	<u>4/22/09</u>	<u>AP DT</u>	

COMMENTS AND NOTES