

ADDRESS : 66 CROSS ROADS CT
CONTRACTOR : AQ CONTRACTING INC.
OWNER : B & J TINGEN PLACE LLC
PARCEL : 03-9597- - -0033- -32-
APPL NUMBER: 09-50021652 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 66 CROSS ROADS, TINGEN PLACE #37 PH2.
27W LEFT ON TINGEN RD, LEFT ON TOWER
DRIVE TO THE RIGHT ON CROSS ROADS
COURT.
T/S: 03/02/2009 08:32 AM VBROWN ----

SUBDIV: TINGEN PLACE PH 2 28LOTS
PHONE : (919) 542-9893
PHONE :

STRUCTURE: 000 000 53.5X26.5 3 BDR 2.5BATH, GAR, PATIO, CRL

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW SEPTIC

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
--------	------------------------	----------------	---------------------------------

B101 01	3/31/09 <u>3-31-09</u>	TI <u>AP-MR</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001749431 please inspect as early as possible so concrete can be poured the same day. Thank You,
---------	---------------------------	--------------------	---

COMMENTS AND NOTES

ADDRESS : 66 CROSS ROADS CT
CONTRACTOR : AQ CONTRACTING INC.
OWNER : B & J TINGEN PLACE LLC
PARCEL : 03-9597- - -0033- -32-
APPL NUMBER: 09-50021652 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 66 CROSS ROADS, TINGEN PLACE #37 PH2.
27W LEFT ON TINGEN RD, LEFT ON TOWER
DRIVE TO THE RIGHT ON CROSS ROADS
COURT.
T/S: 03/02/2009 08:32 AM VBROWN ----

SUBDIV: TINGEN PLACE PH 2 28LOTS
PHONE : (919) 542-9893
PHONE :

STRUCTURE: 000 000 53.5X26.5 3 BDR 2.5BATH, GAR, PATIO, CRL
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/31/09 3/31/09	MR AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001749431 please inspect as early as possible so concrete can be poured the same day. Thank You,
A814 01	4/03/09	TI	ADDRESS CONFIRMATION VRU #: 001750710
B103 01	4/03/09 <u>4.3.9</u>	TI <u>AP-MR</u>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001750702

----- COMMENTS AND NOTES -----



ADDRESS : 66 CROSS ROADS CT
CONTRACTOR : AQ CONTRACTING INC.
OWNER : B & J TINGEN PLACE LLC
PARCEL : 03-9597- - -0033- -32-
APPL NUMBER: 09-50021652 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 66 CROSS ROADS, TINGEN PLACE #37 PH2.
27W LEFT ON TINGEN RD, LEFT ON TOWER
DRIVE TO THE RIGHT ON CROSS ROADS
COURT.
T/S: 03/02/2009 08:32 AM VBROWN ----

SUBDIV: TINGEN PLACE PH 2 28LOTS
PHONE : (919) 542-9893
PHONE :

STRUCTURE: 000 000 53.5X26.5 3 BDR 2.5BATH, GAR, PATIO, CRL

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/31/09 3/31/09	MR AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001749431 please inspect as early as possible so concrete can be poured the same day. Thank You,
A814 01	4/03/09	TI	ADDRESS CONFIRMATION VRU #: 001750710
B103 01	4/03/09 4/03/09	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001750702
B105 01	4/06/09 <u>4.6.9</u>	TI <u>AP-MR</u>	R*OPEN FLOOR VRU #: 001751619

COMMENTS AND NOTES

ADDRESS : 66 CROSS ROADS CT
CONTRACTOR : AQ CONTRACTING INC.
OWNER : B & J TINGEN PLACE LLC
PARCEL : 03-9597- - -0033- -32-
APPL NUMBER: 09-50021652 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 66 CROSS ROADS, TINGEN PLACE #37 PH2.
27W LEFT ON TINGEN RD, LEFT ON TOWER
DRIVE TO THE RIGHT ON CROSS ROADS
COURT.
T/S: 03/02/2009 08:32 AM VBROWN ----

SUBDIV: TINGEN PLACE PH 2 28LOTS
PHONE : (919) 542-9893
PHONE :

STRUCTURE: 000 000 53.5X26.5 3 BDR 2.5BATH, GAR, PATIO, CRL
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/31/09 3/31/09	MR AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001749431 please inspect as early as possible so concrete can be poured the same day. Thank You,
B103 01	4/03/09 4/03/09	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001750702
A814 01	4/03/09 4/03/09	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001750710 66 CROSS ROADS CT
B105 01	4/06/09 4/06/09	MR AP	R*OPEN FLOOR VRU #: 001751619
R425 01	4/17/09	TI	FOUR TRADE ROUGH IN VRU #: 001756337

4-17-9 DA-MR

----- COMMENTS AND NOTES -----

HARNETT COUNTY

Building Inspections Dept.

108 E. Front St.

Lillington, NC 27546

910-893-7525

DO NOT REMOVE

DATE: 4-17-09

PERMIT# 09-50021652

ADDRESS: 66 crossroads

VIOLATIONS:

1. Firecaulk at ac line set
2. Seal floor at powder room toilet floor
3. Ok to side and insul. I will check at insul insp.
4. Toilet Joint

Harnett County Building Department

Mike Rearic cell# (910) 984- 4772

ADDRESS : 66 CROSS ROADS CT
 CONTRACTOR : AQ CONTRACTING INC.
 OWNER : B & J TINGEN PLACE LLC
 PARCEL : 03-9597- - -0033- -32-
 APPL NUMBER: 09-50021652 CP NEW RESIDENTIAL (SFD)

SUBDIV: TINGEN PLACE PH 2 28LOTS
 PHONE : (919) 542-9893
 PHONE :

DIRECTIONS : 66 CROSS ROADS, TINGEN PLACE #37 PH2.
 27W LEFT ON TINGEN RD, LEFT ON TOWER
 DRIVE TO THE RIGHT ON CROSS ROADS
 COURT.
 T/S: 03/02/2009 08:32 AM VBROWN ----

STRUCTURE: 000 000 53.5X26.5 3 BDR 2.5BATH, GAR, PATIO, CRL

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW SEPTIC

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/31/09 3/31/09	MR AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001749431 please inspect as early as possible so concrete can be poured the same day. Thank You,
B103 01	4/03/09 4/03/09	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001750702
A814 01	4/03/09 4/03/09	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001750710 66 CROSS ROADS CT
B105 01	4/06/09 4/06/09	MR AP	R*OPEN FLOOR VRU #: 001751619
R425 01	4/17/09 4/17/09	MR DA	FOUR TRADE ROUGH IN VRU #: 001756337 1 firecaulk ac line set 2 seal floor at powder room toilet 3 repair toilet joist where notched 4 ok to side and insul
I129 01	4/21/09 <u>4/21/09</u>	TI <u>AP-MR</u>	R*INSULATION INSPECTION VRU #: 001757582
R425 03	4/21/09 <u>4/21/09</u>	TI <u>AP-MR</u>	FOUR TRADE ROUGH IN VRU #: 001757574 Please inspect insulation as well Thank You!!
R425 02	4/21/09 4/20/09	TI CA	FOUR TRADE ROUGH IN VRU #: 001757566 Please inspect insulation as well Thank You!!

COMMENTS AND NOTES

ADDRESS : 66 CROSS ROADS CT
 CONTRACTOR : AQ CONTRACTING INC.
 OWNER : B & J TINGEN PLACE LLC
 PARCEL : 03-9597- - -0033- -32-
 APPL NUMBER: 09-50021652 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 66 CROSS ROADS, TINGEN PLACE #37 PH2.
 27W LEFT ON TINGEN RD, LEFT ON TOWER
 DRIVE TO THE RIGHT ON CROSS ROADS
 COURT.
 T/S: 03/02/2009 08:32 AM VBROWN ----

SUBDIV: TINGEN PLACE PH 2 28LOTS
 PHONE : (919) 542-9893
 PHONE :

STRUCTURE: 000 000 53.5X26.5 3 BDR 2.5BATH, GAR, PATIO, CRL

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW SEPTIC

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/31/09 3/31/09	MR AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001749431 please inspect as early as possible so concrete can be poured the same day. Thank You,
B103 01	4/03/09 4/03/09	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001750702
A814 01	4/03/09 4/03/09	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001750710 ✓66 CROSS ROADS CT
B105 01	4/06/09 4/06/09	MR AP	R*OPEN FLOOR VRU #: 001751619
R425 01	4/17/09 4/17/09	MR DA	FOUR TRADE ROUGH IN VRU #: 001756337 1. firecaulk ac line set 2, seal floor at powder room toilet 3. repair toilet joist where notched 4. ok to side and insul
I129 01	4/21/09 4/21/09	MR AP	R*INSULATION INSPECTION VRU #: 001757582
R425 03	4/21/09 4/21/09	MR AP	FOUR TRADE ROUGH IN VRU #: 001757574 Please inspect insulation as well Thank You!!
R425 02	4/21/09 4/20/09	TI CA	FOUR TRADE ROUGH IN VRU #: 001757566 Please inspect insulation as well Thank You!!
H824 01	5/04/09 5/04/09	JW AP	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001765163
R429 01	5/13/09	TI	FOUR TRADE FINAL VRU #: 001767383

5-13-9 DA-MR

COMMENTS AND NOTES

HARNETT COUNTY

Building Inspections Dept.

108 E. Front St.

Lillington, NC 27546

910-893-7525

DO NOT REMOVE

DATE: 05-13-09

PERMIT# 09-50021652

ADDRESS: 66 crossroads

VIOLATIONS:

1. Dining room outlets rare to be arc fault protected
2. Water heater is leaking
3. No fee

Harnett County Building Department

Mike Rearic cell# (910) 984- 4772

ADDRESS : 66 CROSS ROADS CT SUBDIV: TINGEN PLACE PH 2 28LOTS
 CONTRACTOR : AQ CONTRACTING INC. PHONE : (919) 542-9893
 OWNER : B & J TINGEN PLACE LLC PHONE :
 PARCEL : 03-9597- - -0033- -32-
 APPL NUMBER: 09-50021652 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 66 CROSS ROADS, TINGEN PLACE #37 PH2.
 27W LEFT ON TINGEN RD, LEFT ON TOWER
 DRIVE TO THE RIGHT ON CROSS ROADS
 COURT.
 T/S: 03/02/2009 08:32 AM VBROWN ----

STRUCTURE: 000 000 53.5X26.5 3 BDR 2.5BATH, GAR, PATIO, CRL
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/31/09 3/31/09	MR AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001749431 please inspect as early as possible so concrete can be poured the same day. Thank You,
B103 01	4/03/09 4/03/09	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001750702
A814 01	4/03/09 4/03/09	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001750710 ✓ 66 CROSS ROADS CT
B105 01	4/06/09 4/06/09	MR AP	R*OPEN FLOOR VRU #: 001751619
R425 01	4/17/09 4/17/09	MR DA	FOUR TRADE ROUGH IN VRU #: 001756337 1. firecaulk ac line set 2. seal floor at powder room toilet 3. repair toilet joist where notched 4. ok to side and insul
I129 01	4/21/09 4/21/09	MR AP	R*INSULATION INSPECTION VRU #: 001757582
R425 03	4/21/09 4/21/09	MR AP	FOUR TRADE ROUGH IN VRU #: 001757574 Please inspect insulation as well Thank You!!
R425 02	4/21/09 4/20/09	TI CA	FOUR TRADE ROUGH IN VRU #: 001757566 Please inspect insulation as well Thank You!!
H824 01	5/04/09 5/04/09	JW AP	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001765163
R429 01	5/13/09 5/13/09	MR DA	FOUR TRADE FINAL VRU #: 001767383 1. dining room , living room etc. outlets to be arc fault protected 2. water heater is leaking
R429 02	5/14/09	TI	FOUR TRADE FINAL VRU #: 001768019

5-14-9 AP-MR

COMMENTS AND NOTES

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: IR-3

Owner: B+J Tingen Ltd.

911 Address: _____

66 Cross Roads Ct.

State: NC Zip Code: _____

Date: 5-14-9

T. Michael Rear

Building Official

PERMIT NUMBERS

Building Permit No.: 09-50021652

Electrical Permit No.: 1

Insulation Permit No.: 4

Plumbing Permit No.: 1

Mech. Permit No.: 1

MFG. Home: _____