
ADDRESS . . : 130 MICRO CT
 CONTRACTOR : AQ CONTRACTING INC.
 OWNER . . . : B & J TINGEN PLACE LLC
 PARCEL . . . : 03-9597- - -0033- -44-
 APPL NUMBER: 09-50021653 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 130 MICRO COURT, TINGEN PLACE #49.
 27W, LEFT ON TINGEN RD, LEFT ON TOWER
 DRIVE, RIGHT ON MICRO COURT.
 T/S: 03/02/2009 08:41 AM VBROWN -----

STRUCTURE: 000 000 35X44.3 3BDR 2.5BATH SFD, GAR, PATIO, CRL
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00
 SEPTIC - EXISTING? : NEW SEPTIC

PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/31/09 <u>3.31.9</u>	TI <u>AP-MR</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001749449 Please inspect as early as possible so concrete can be poured the same day. Thank You,

----- COMMENTS AND NOTES -----

ADDRESS : 130 MICRO CT
CONTRACTOR : AQ CONTRACTING INC.
OWNER : B & J TINGEN PLACE LLC
PARCEL : 03-9597- - -0033- -44-
APPL NUMBER: 09-50021653 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 130 MICRO COURT, TINGEN PLACE #49.
27W, LEFT ON TINGEN RD, LEFT ON TOWER
DRIVE, RIGHT ON MICRO COURT.
T/S: 03/02/2009 08:41 AM VBROWN ----

SUBDIV: TINGEN PLACE PH 2 28LOTS
PHONE : (919) 542-9893
PHONE :

STRUCTURE: 000 000 35X44.3 3BDR 2.5BATH SFD, GAR, PATIO,CRL
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00
SEPTIC - EXISTING? : NEW SEPTIC

PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/31/09 3/31/09	MR AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001749449 Please inspect as early as possible so concrete can be poured the same day. Thank You,
A814 01	4/03/09	TI	ADDRESS CONFIRMATION VRU #: 001750694
B103 01	4/03/09 <u>4-3-9</u>	TI <u>AP-MR</u>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001750660
B103 02	4/03/09 <u>4-3-9</u>	TI <u>AP-MR</u>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001750686

----- COMMENTS AND NOTES -----

ADDRESS : 130 MICRO CT
CONTRACTOR : AQ CONTRACTING INC.
OWNER : B & J TINGEN PLACE LLC
PARCEL : 03-9597- - -0033- -44-
APPL NUMBER: 09-50021653 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 130 MICRO COURT, TINGEN PLACE #49.
27W, LEFT ON TINGEN RD, LEFT ON TOWER
DRIVE, RIGHT ON MICRO COURT.
T/S: 03/02/2009 08:41 AM VBROWN ----

SUBDIV: TINGEN PLACE PH 2 28LOTS
PHONE : (919) 542-9893
PHONE :

STRUCTURE: 000 000 35X44.3 3BDR 2.5BATH SFD, GAR, PATIO,CRL

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW SEPTIC

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/31/09 3/31/09	MR AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001749449 Please inspect as early as possible so concrete can be poured the same day. Thank You,
B103 02	4/03/09 4/03/09	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001750686
B103 01	4/03/09 4/03/09	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001750660
A814 01	4/03/09 4/03/09	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001750694 130 MICRO CT
B105 01	4/14/09 <u>4-14-9</u>	TI <u>AP-MR</u>	R*OPEN FLOOR VRU #: 001754670

COMMENTS AND NOTES

ADDRESS : 130 MICRO CT
CONTRACTOR : AQ CONTRACTING INC.
OWNER : B & J TINGEN PLACE LLC
PARCEL : 03-9597- - -0033- -44-
APPL NUMBER: 09-50021653 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 130 MICRO COURT, TINGEN PLACE #49.
27W, LEFT ON TINGEN RD, LEFT ON TOWER
DRIVE, RIGHT ON MICRO COURT.
T/S: 03/02/2009 08:41 AM VBROWN ----

SUBDIV: TINGEN PLACE PH 2 28LOTS
PHONE : (919) 542-9893
PHONE :

STRUCTURE: 000 000 35X44.3 3BDR 2.5BATH SFD, GAR, PATIO,CRL

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW SEPTIC

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/31/09 3/31/09	MR AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001749449 Please inspect as early as possible so concrete can be poured the same day. Thank You,
B103 02	4/03/09 4/03/09	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001750686
B103 01	4/03/09 4/03/09	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001750660
A814 01	4/03/09 4/03/09	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001750694 130 MICRO CT
B105 01	4/14/09 4/14/09	MR AP	R*OPEN FLOOR VRU #: 001754670
R425 01	4/27/09	TI	FOUR TRADE ROUGH IN VRU #: 001759984

4.27.9 DA-MR

COMMENTS AND NOTES

HARNETT COUNTY

Building Inspections Dept.

108 E. Front St.

Lillington, NC 27546

910-893-7525

DO NOT REMOVE

DATE: 4-27-09

PERMIT# 09-50021653

ADDRESS: 130 micro

VIOLATIONS:

1. Ok to insul.
2. Fireblocking between floors cannot be mineral insul. It must be solid and held in place
3. Outlets required in kitchen in walls more than 24"
4. NEC 334 requires derating for wires when more than three through a hole. Check all holes for ampacity
5. Tyvek missing on outside wall and it doesn't lap in places
6. Install gas line and test for insp.
7. Do not side

Harnett County Building Department

Mike Rearic cell# (910) 984- 4772

ADDRESS : 130 MICRO CT
CONTRACTOR : AQ CONTRACTING INC.
OWNER : B & J TINGEN PLACE LLC
PARCEL : 03-9597- - -0033- -44-
APPL NUMBER: 09-50021653 CP NEW RESIDENTIAL (SFD)

SUBDIV: TINGEN PLACE PH 2 28LOTS
PHONE : (919) 542-9893
PHONE :

DIRECTIONS : 130 MICRO COURT, TINGEN PLACE #49.
27W, LEFT ON TINGEN RD, LEFT ON TOWER
DRIVE, RIGHT ON MICRO COURT.
T/S: 03/02/2009 08:41 AM VBROWN ----

STRUCTURE: 000 000 35X44.3 3BDR 2.5BATH SFD, GAR, PATIO,CRL

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/31/09 3/31/09	MR AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001749449 Please inspect as early as possible so concrete can be poured the same day. Thank You,
B103 02	4/03/09 4/03/09	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001750686
B103 01	4/03/09 4/03/09	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001750660
A814 01	4/03/09 4/03/09	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001750694 130 MICRO CT
B105 01	4/14/09 4/14/09	MR AP	R*OPEN FLOOR VRU #: 001754670
R425 01	4/27/09 4/27/09	MR DA	FOUR TRADE ROUGH IN VRU #: 001759984 1. fireblocking cannot be mineral insul. 2. outlets missing in kitchen 3. tyvek missing on outside in spots 4. install gas line and test 5. do not side, ok to insul.
I129 01	4/28/09 <u>4-28-9</u>	TI AP-MR	R*INSULATION INSPECTION VRU #: 001760917
R425 02	4/28/09 <u>4-28-9</u>	TI AP-MR	FOUR TRADE ROUGH IN VRU #: 001760909

COMMENTS AND NOTES

ADDRESS : 130 MICRO CT
CONTRACTOR : AQ CONTRACTING INC.
OWNER : B & J TINGEN PLACE LLC
PARCEL : 03-9597- - -0033- -44-
APPL NUMBER: 09-50021653 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 130 MICRO COURT, TINGEN PLACE #49.
27W, LEFT ON TINGEN RD, LEFT ON TOWER
DRIVE, RIGHT ON MICRO COURT.
T/S: 03/02/2009 08:41 AM VBROWN ----

SUBDIV: TINGEN PLACE PH 2 28LOTS
PHONE : (919) 542-9893
PHONE :

STRUCTURE: 000 000 35X44.3 3BDR 2.5BATH SFD, GAR, PATIO,CRL

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/31/09 3/31/09	MR AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001749449 Please inspect as early as possible so concrete can be poured the same day. Thank You,
B103 02	4/03/09 4/03/09	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001750686
B103 01	4/03/09 4/03/09	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001750660
A814 01	4/03/09 4/03/09	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001750694 ✓130 MICRO CT
B105 01	4/14/09 4/14/09	MR AP	R*OPEN FLOOR VRU #: 001754670
R425 01	4/27/09 4/27/09	MR DA	FOUR TRADE ROUGH IN VRU #: 001759984 1. fireblocking cannot be mineral insul. 2. outlets missing in kitchen 3. tyvek missing on outside in spots 4.install gas line and test 6, do not side, ok to insul.
I129 01	4/28/09 4/28/09	MR AP	R*INSULATION INSPECTION VRU #: 001760917
R425 02	4/28/09 4/28/09	MR AP	FOUR TRADE ROUGH IN VRU #: 001760909
H824 01	5/04/09 5/04/09	JW AP	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001765155
R429 01	5/18/09	TI	FOUR TRADE FINAL VRU #: 001769322

5-189 AP-MR

COMMENTS AND NOTES

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: R-3

PERMIT NUMBERS

Owner: AQ Contracting Inc

Building Permit No.: 09-50021653

911 Address: _____

Electrical Permit No.: _____

130 Misco Ct

Insulation Permit No.: _____

Plumbing Permit No.: _____

State: NC Zip Code: _____

Mech. Permit No.: _____

Date: 5-18-9

MFG. Home: _____

F. Michael Ream

Building Official