

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner:
 Address:
 Proposed Facility: Design Flow (.1949):
 Location of Site:
 Water Supply: Public Individual Well
 Evaluation Method: Auger Boring Pit
 Type of Wastewater: Sewage Industrial Process

Applicant:
 Date Evaluated: 3/12/09
 Property Size:
 Property Recorded: Spring Other
 Cut
 Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro: Class	.1944 Restr: Horiz	
LS 3-7%		0-12	G/SL	VH-NSNP					PS.3
		12-30	SBK/SC1	F. SS SP					
		30-76	SBK/C	F. S SP	10 yr 7/1	76"			
		0-24	G/SL	VH-NSNP					PS.4
		24-43	SBK/SC1	F. SS SP					
		0-12	G/SL	VH-NSNP					PS.3
	12-76	SBK/SC	F. SS SP						

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	25%	
Site LTAR	.3	.3

Other Factors (.1946): _____
 Site Classification (.1948): PS
 Evaluated By: *Bm*
 Others Present: