

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner:

Applicant:

Address:

Date Evaluated: 3/14/89

Proposed Facility: 4 BEDROOM HOME Design Flow (.1949): 480 gpd

Property Size:

Location of Site:

Property Recorded:

Water Supply:  Public  Individual  Well  Spring  Other  
 Evaluation Method:  Auger Boring  Pit  Cut  
 Type of Wastewater:  Sewage  Industrial Process  Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 5-10%	0-30	G S	VFL NS/NP					PS .6
		30-48	SBX SL	VFL SS/NP					
2		0-36	G S	VFL NS/NP					PS .6
		36-48	SBX SL	VFL NS/NP					
3		0-37	G S	VFL NS/NP					PS .7
		37-48	G SL	VFL NS/NP					
4		0-48	G S	VFL NS/NP					S .8
5		0-48	G S	VFL NS/NP					S .8

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	con	25% RED
Site LTAR	.2	.6

Other Factors (.1946): \_\_\_\_\_  
 Site Classification (.1948): PS  
 Evaluated By: GT  
 Others Present: