
ADDRESS . . : 207 STRIKE EAGLE DR SUBDIV: PATTONS POINT
 CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805
 OWNER . . : BILL CLARK HOMES LLC PHONE : (910) 426-2898
 PARCEL . . : 03-9597- - -0039- -10-
 APPL NUMBER: 09-50021736 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 207 STRIKE EAGLE DRIVE, PATTONS POINT
 #11. 27W, LEFT ON TINGEN RD, LEFT INTO
 SUB DIV, ON STRIKE EAGLE DRIVE.
 T/S: 03/16/2009 03:19 PM VBROWN -----

STRUCTURE: 000 000 65X34 3BDR 2BATH SFD, GAR, NO DCK, SLAB
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|------------------------|----------------|---|
| B101 01 | 4/07/09 | MR | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001751940 |
| | 4/07/09 | AP | |
| A814 01 | 4/13/09 | TI | ADDRESS CONFIRMATION VRU #: 001753995 |
| B103 01 | 4/13/09 | MR | R*BLDG FOUND & TEMP SVC POLE VRU #: 001754001 |
| | 4/13/09 | AP | |
| P309 01 | 4/17/09 | TI | R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 001756543 |
| | <u>4-17-9</u> | <u>AP-MR</u> | |

----- COMMENTS AND NOTES -----

ADDRESS : 207 STRIKE EAGLE DR SUBDIV: PATTONS POINT
CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805
OWNER : BILL CLARK HOMES LLC PHONE : (910) 426-2898
PARCEL : 03-9597- - -0039- -10-
APPL NUMBER: 09-50021736 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 207 STRIKE EAGLE DRIVE, PATTONS POINT
#11. 27W, LEFT ON TINGEN RD, LEFT INTO
SUB DIV, ON STRIKE EAGLE DRIVE.
T/S: 03/16/2009 03:19 PM VBROWN -----

STRUCTURE: 000 000 65X34 3BDR 2BATH SFD, GAR, NO DCK, SLAB
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|------------------------|----------------|---|
| B101 01 | 4/07/09 | MR | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001751940 |
| | 4/07/09 | AP | |
| B103 01 | 4/13/09 | MR | R*BLDG FOUND & TEMP SVC POLE VRU #: 001754001 |
| | 4/13/09 | AP | |
| A814 01 | 4/13/09 | TI | ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001753995 |
| | 4/21/09 | AP | 207 STRIKE EAGLE DR LOT 11 |
| P309 01 | 4/17/09 | MR | R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 001756543 |
| | 4/17/09 | AP | |
| B111 01 | 4/22/09 | TI | R*BLDG SLAB INSP TIME: 17:00 VRU #: 001758523 |
| | <u>4-22-9</u> | <u>AP-MR</u> | WOULD LIKE THIS AT OR AFTER LUNCH. |

----- COMMENTS AND NOTES -----

ADDRESS : 207 STRIKE EAGLE DR SUBDIV: PATTONS POINT
CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805
OWNER : BILL CLARK HOMES LLC PHONE : (910) 426-2898
PARCEL : 03-9597- - -0039- -10-
APPL NUMBER: 09-50021736 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : 207 STRIKE EAGLE DRIVE, PATTONS POINT
#11. 27W, LEFT ON TINGEN RD, LEFT INTO
SUB DIV, ON STRIKE EAGLE DRIVE.
T/S: 03/16/2009 03:19 PM VBROWN -----

STRUCTURE: 000 000 65X34 3BDR 2BATH SFD, GAR, NO DCK, SLAB
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|------------------------|----------------|---|
| B101 01 | 4/07/09 | MR | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001751940 |
| | 4/07/09 | AP | |
| B103 01 | 4/13/09 | MR | R*BLDG FOUND & TEMP SVC POLE VRU #: 001754001 |
| | 4/13/09 | AP | |
| A814 01 | 4/13/09 | TI | ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001753995 |
| | 4/21/09 | AP | 207 STRIKE EAGLE DR LOT 11 |
| P309 01 | 4/17/09 | MR | R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 001756543 |
| | 4/17/09 | AP | |
| B111 01 | 4/22/09 | MR | R*BLDG SLAB INSP TIME: 17:00 VRU #: 001758523 |
| | 4/22/09 | AP | WOULD LIKE THIS AT OR AFTER LUNCH. |
| R425 02 | 5/15/09 | TI | FOUR TRADE ROUGH IN VRU #: 001768472 |
| | <u>5-15-9</u> | <u>AP-MR</u> | |
| R425 01 | 5/15/09 | TI | FOUR TRADE ROUGH IN VRU #: 001768464 |
| | 5/14/09 | CA | |

----- COMMENTS AND NOTES -----

ADDRESS . . : 207 STRIKE EAGLE DR SUBDIV: PATTONS POINT
CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805
OWNER . . : BILL CLARK HOMES LLC PHONE : (910) 426-2898
PARCEL . . : 03-9597- - -0039- -10-
APPL NUMBER: 09-50021736 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 207 STRIKE EAGLE DRIVE, PATTONS POINT
#11. 27W, LEFT ON TINGEN RD, LEFT INTO
SUB DIV, ON STRIKE EAGLE DRIVE.
T/S: 03/16/2009 03:19 PM VBROWN -----

STRUCTURE: 000 000 65X34 3BDR 2BATH SFD, GAR, NO DCK, SLAB
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|------------------------|----------------|--|
| B101 01 | 4/07/09 | MR | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001751940 |
| | 4/07/09 | AP | |
| B103 01 | 4/13/09 | MR | R*BLDG FOUND & TEMP SVC POLE VRU #: 001754001 |
| | 4/13/09 | AP | |
| A814 01 | 4/13/09 | TI | ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001753995 |
| | 4/21/09 | AP | 207 STRIKE EAGLE DR LOT 11 |
| P309 01 | 4/17/09 | MR | R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 001756543 |
| | 4/17/09 | AP | |
| B111 01 | 4/22/09 | MR | R*BLDG SLAB INSP TIME: 17:00 VRU #: 001758523 |
| | 4/22/09 | AP | WOULD LIKE THIS AT OR AFTER LUNCH. |
| R425 02 | 5/15/09 | MR | FOUR TRADE ROUGH IN VRU #: 001768472 |
| | 5/15/09 | AP | |
| R425 01 | 5/15/09 | TI | FOUR TRADE ROUGH IN VRU #: 001768464 |
| | 5/14/09 | CA | |
| I129 01 | 5/19/09 | TI | R*INSULATION INSPECTION TIME: 17:00 VRU #: 001769629 |

5-19-9 AP-MR

----- COMMENTS AND NOTES -----

ADDRESS : 207 STRIKE EAGLE DR SUBDIV: PATTONS POINT
CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805
OWNER : BILL CLARK HOMES LLC PHONE : (910) 426-2898
PARCEL : 03-9597- - -0039- -10-
APPL NUMBER: 09-50021736 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 207 STRIKE EAGLE DRIVE, PATTONS POINT
#11. 27W, LEFT ON TINGEN RD, LEFT INTO
SUB DIV, ON STRIKE EAGLE DRIVE.
T/S: 03/16/2009 03:19 PM VBROWN -----

STRUCTURE: 000 000 65X34 3BDR 2BATH SFD, GAR, NO DCK, SLAB
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|---------------------|--------------|---|
| B101 01 | 4/07/09 | MR | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001751940 |
| | 4/07/09 | AP | |
| B103 01 | 4/13/09 | MR | R*BLDG FOUND & TEMP SVC POLE VRU #: 001754001 |
| | 4/13/09 | AP | |
| A814 01 | 4/13/09 | TI | ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001753995 |
| | 4/21/09 | AP | ✓ 207 STRIKE EAGLE DR LOT 11 |
| P309 01 | 4/17/09 | MR | R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 001756543 |
| | 4/17/09 | AP | |
| B111 01 | 4/22/09 | MR | R*BLDG SLAB INSP TIME: 17:00 VRU #: 001758523 |
| | 4/22/09 | AP | WOULD LIKE THIS AT OR AFTER LUNCH. |
| R425 02 | 5/15/09 | MR | FOUR TRADE ROUGH IN VRU #: 001768472 |
| | 5/15/09 | AP | |
| R425 01 | 5/15/09 | TI | FOUR TRADE ROUGH IN VRU #: 001768464 |
| | 5/14/09 | CA | |
| I129 01 | 5/19/09 | MR | R*INSULATION INSPECTION TIME: 17:00 VRU #: 001769629 |
| | 5/19/09 | AP | |
| H824 01 | 6/01/09 | OT | ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001776210 |
| | 6/01/09 | AP | |
| R429 01 | 6/26/09 | TI | ✓ FOUR TRADE FINAL TIME: 17:00 VRU #: 001786623 |
| | <u>6-26-09</u> | <u>DP-MR</u> | T/S: 06/25/2009 09:25 AM NTART ----- |

COMMENTS AND NOTES

HARNETT COUNTY

Building Inspections Dept.

108 E. Front St.

Lillington, NC 27546

910-893-7525

DO NOT REMOVE

DATE: 06-26-09

PERMIT # 09-50021736

ADDRESS: 207 strike.eagle

VIOLATIONS:

1. Water heater is not wired
2. Water heater needs a bollard to protect it from cars
3. Main bond missing from panel
4. No ladder on site for attic inspection

Harnett County Building Department

Mike Rearic cell# (910) 984- 4772

ADDRESS : 207 STRIKE EAGLE DR SUBDIV: PATTONS POINT
 CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805
 OWNER : BILL CLARK HOMES LLC PHONE : (910) 426-2898
 PARCEL : 03-9597- - -0039- -10-
 APPL NUMBER: 09-50021736 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 207 STRIKE EAGLE DRIVE, PATTONS POINT
 #11. 27W, LEFT ON TINGEN RD, LEFT INTO
 SUB DIV, ON STRIKE EAGLE DRIVE.
 T/S: 03/16/2009 03:19 PM VBROWN ----

STRUCTURE: 000 000 65X34 3BDR 2BATH SFD, GAR, NO DCK, SLAB
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|---------------------|--------------|--|
| B101 01 | 4/07/09 | MR | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001751940 |
| | 4/07/09 | AP | |
| B103 01 | 4/13/09 | MR | R*BLDG FOUND & TEMP SVC POLE VRU #: 001754001 |
| | 4/13/09 | AP | |
| A814 01 | 4/13/09 | TI | ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001753995 |
| | 4/21/09 | AP | ✓207 STRIKE EAGLE DR LOT 11 |
| P309 01 | 4/17/09 | MR | R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 001756543 |
| | 4/17/09 | AP | |
| B111 01 | 4/22/09 | MR | R*BLDG SLAB INSP TIME: 17:00 VRU #: 001758523 |
| | 4/22/09 | AP | WOULD LIKE THIS AT OR AFTER LUNCH. |
| R425 02 | 5/15/09 | MR | FOUR TRADE ROUGH IN VRU #: 001768472 |
| | 5/15/09 | AP | |
| R425 01 | 5/15/09 | TI | FOUR TRADE ROUGH IN VRU #: 001768464 |
| | 5/14/09 | CA | |
| I129 01 | 5/19/09 | MR | R*INSULATION INSPECTION TIME: 17:00 VRU #: 001769629 |
| | 5/19/09 | AP | |
| H824 01 | 6/01/09 | OT | ✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001776210 |
| | 6/01/09 | AP | |
| R429 01 | 6/26/09 | MR | FOUR TRADE FINAL TIME: 17:00 VRU #: 001786623 |
| | 6/26/09 | DP | T/S: 06/25/2009 09:25 AM NTART ----- T/S: 06/26/2009 12:46 PM MREARIC ----- water heater not wired water heater not protected main bond missing from panel no ladder on site for attic inspection T/S: 06/29/2009 09:02 AM NTART ----- |
| R429 02 | 6/30/09 | TI | FOUR TRADE FINAL TIME: 17:00 VRU #: 001788132 |
| | <u>6-30-9</u> | <u>DP-MR</u> | T/S: 06/29/2009 09:05 AM JBROCK ----- |

COMMENTS AND NOTES

DO NOT REMOVE!

Harnett County Inspection Department

102 East Front Street • P.O. Box 65

Lillington, NC 27546

Phone: (910) 893-7527 • Fax: (910) 893-2793

Job Name: Bill Clark Homes Date: 6-30-9

Address: 207 Strike East

Lot No.: _____ Permit No.: 21736

(Check Box for Violation)

- | | | | | | | | |
|-------------------------------------|-------------------------------------|----------------------------------|--|-------------------------------------|---------------------------------------|---------------------------------|--------------------------------------|
| <input type="checkbox"/> Footing | <input type="checkbox"/> Foundation | <input type="checkbox"/> Bldg. | <input type="checkbox"/> Elec. | <input type="checkbox"/> Plumb. | <input type="checkbox"/> Mech. | <input type="checkbox"/> Insul. | <input type="checkbox"/> Floor Fram. |
| <input type="checkbox"/> Floor Slab | <input type="checkbox"/> MFG. Home | <input type="checkbox"/> Modular | <input type="checkbox"/> Damp/Water Proof. | <input type="checkbox"/> Structural | <input type="checkbox"/> Wall Sheath. | <input type="checkbox"/> Other | |

Violations Found: _____

1) Tire stop must be 3' before water heater

2) NO electric Repairs made from last list

Fee 50⁰⁰

Code Enforcement Official

Date: _____

Signature: Mike Rean

It is unlawful for any sub contractor, general contractor, or owner to cover or cause to be covered any part of the work with flooring, sheetrock, earth or other material until the proper inspector had ample time to approve the installation.

ADDRESS : 207 STRIKE EAGLE DR SUBDIV: PATTONS POINT
 CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805
 OWNER : BILL CLARK HOMES LLC PHONE : (910) 426-2898
 PARCEL : 03-9597- - -0039- -10-
 APPL NUMBER: 09-50021736 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 207 STRIKE EAGLE DRIVE, PATTONS POINT
 #11. 27W, LEFT ON TINGEN RD, LEFT INTO
 SUB DIV, ON STRIKE EAGLE DRIVE.
 T/S: 03/16/2009 03:19 PM VBROWN ----

STRUCTURE: 000 000 65X34 3BDR 2BATH SFD, GAR, NO DCK, SLAB
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|---------------------|-------------|--|
| B101 01 | 4/07/09 | MR | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001751940 |
| | 4/07/09 | AP | |
| B103 01 | 4/13/09 | MR | R*BLDG FOUND & TEMP SVC POLE VRU #: 001754001 |
| | 4/13/09 | AP | |
| A814 01 | 4/13/09 | TI | ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001753995 |
| | 4/21/09 | AP | 207 STRIKE EAGLE DR LOT 11 |
| P309 01 | 4/17/09 | MR | R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 001756543 |
| | 4/17/09 | AP | |
| B111 01 | 4/22/09 | MR | R*BLDG SLAB INSP TIME: 17:00 VRU #: 001758523 |
| | 4/22/09 | AP | WOULD LIKE THIS AT OR AFTER LUNCH. |
| R425 02 | 5/15/09 | MR | FOUR TRADE ROUGH IN VRU #: 001768472 |
| | 5/15/09 | AP | |
| R425 01 | 5/15/09 | TI | FOUR TRADE ROUGH IN VRU #: 001768464 |
| | 5/14/09 | CA | |
| I129 01 | 5/19/09 | MR | R*INSULATION INSPECTION TIME: 17:00 VRU #: 001769629 |
| | 5/19/09 | AP | |
| H824 01 | 6/01/09 | OT | ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001776210 |
| | 6/01/09 | AP | |
| R429 01 | 6/26/09 | MR | FOUR TRADE FINAL TIME: 17:00 VRU #: 001786623 |
| | 6/26/09 | DP | T/S: 06/25/2009 09:25 AM NTART ----- T/S: 06/26/2009 12:46 PM MREARIC ----- water heater not wired water heater not protected main bond missing from panel no ladder on site for attic inspection |
| | | | T/S: 06/29/2009 09:02 AM NTART ----- |
| R429 02 | 6/30/09 | MR | FOUR TRADE FINAL TIME: 17:00 VRU #: 001788132 |
| | 6/30/09 | DP | T/S: 06/29/2009 09:05 AM JBROCK ----- T/S: 06/30/2009 09:20 AM MREARIC ----- 1. water heater protection must be 3' before the heater and bolted down 2. electric corrections not made |
| R429 03 | 7/08/09 | TI | FOUR TRADE FINAL TIME: 17:00 VRU #: 001791235 |
| | | | T/S: 07/07/2009 12:26 PM VBROWN ----- |

----- COMMENTS AND NOTES -----

COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: R-3

Type of Construction: IV

Owner of Building: Bill Clark Homes

Building Address: 207 Strike Eagle

Zoning District: _____

Zoning Permit No.: _____

Conditional Use Permit No.: _____

Building Permit No.: 09-50021736

Electrical Permit No.: 1

Insulation Permit No.: 1

Plumbing Permit No.: 1

Mech. Permit No.: 1

Envir. C.O. No.: _____

Date: 7-8-9

T. Michael Rearn

Building Official

Zoning Official