HTE#09-5-21754

Harnett County Department of Public Health 25259

Improvement Permit

PROPERTY LOCATION: 5R 1/4/ M, cro Tower Rd.
LOI IT III
NEW LLZ REPAIR
Proposed Wastewater System Type: 25 To Reduction System
Projected Daily Flow:
Pump Required: Yes No May be required based on final location and elevations of facilities
Type of Water Supply: Community Public Well Distance from well feet Permit valid for: Five years
Permit conditions: No expiration
2
Authorized State Agent: Sura M. Sura C.S. Date: 4/9/2009 SEE ATTACHED SITE SKETCH
The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of
the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.
Construction Authorization
(Required for Building Permit)
The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958. and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.
ISSUED TO: 5 tanil Builder Inc. PROPERTY LOCATION: 521141 SUBDIVISION Pattons Point TI LOT # 191
SUBDIVISION Pattons Point 1/ LOT # 181
Facility Type: SFD Mew Expansion Repair
Basement? Yes No Basement Fixtures? Yes No
(See note below, if applicable)
Installation Requirements/Conditions Number of trenches
Septic Tank Size <u>/000</u> gallons Exact length of each trench <u>/50</u> feet Trench Spacing:9 Feet on Center
Pump Tank Size gallons Trenches shall be installed on contour at a Soil Cover: G inches
Maximum Trench Depth of:
(Trench bottoms shall be level to $\pm \frac{1}{4}$ 36" above the trench bottom)
\cdot
in all directions) Pump Requirements:ft. TDH vs GPM inches below pipe
motes set of pipe
Aggregate Depth:inches above pipe
Conditions: Run drainline on contour inches total
** If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.
The specifications of this permit.
Owner/Legal Representative Signature:
his Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This
onstruction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH
$\mathcal{M} \subseteq \mathcal{M} \subseteq $
Authorized State Agent: Date: 4/9/2099
Construction Authorization Expiration Date: 4/9/20/9

111LT - 1 0 -0.70 1	HTE#	09-5-21754	
---------------------	------	------------	--

Permit # 25259

Harnett County Department of Public Health Site Sketch

Authorized State Agent: Super Main R.S.

PROPERTY LOCATON: SX 1/4/ Micro Tower Rd.

SUBDIVISION Pattern Point II LOT # 191

Date: 4/9/2009

