

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner:

Applicant:

Address:

Date Evaluated: 3/27/09

Proposed Facility: 3 Bedroom Home Design Flow (.1949): 360 gpd

Property Size:

Location of Site:

Property Recorded:

Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Saprot Class	.1944 Restr. Horiz	
1	L 7-10	0-22	GS	VFL NS/HP					PS .35
		22-35	SBK SCL	FL SS/SP					
		35"	PM						
2		0-14	GS	VFL NS/HP					PS .35
		14-27	SBK SCL	FL SS/SP					
		27"	ML						
3		0-17"	GS	VFL NS/HP					PS .4
		17-32"	SBK SCL	FL SS/SP					
		32"	PM						

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	25% RFD	25% RFD
Site LTAR	.35	.35

Other Factors (.1946): _____
 Site Classification (.1948): PS
 Evaluated By: OT
 Others Present: ✓
 ULTRASHALLOW REPAIR

4 x 70' @ 18"