

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner:

Applicant:

Address:

Date Evaluated: 3/27/07

Proposed Facility: 3 Bedroom Design Flow (.1949): 360 gpd

Property Size:

Location of Site: 17026

Property Recorded:

Water Supply: Public [] Individual [] Well [] Spring [] Other
 Evaluation Method: Auger Boring [] Pit [] Cut
 Type of Wastewater: Sewage [] Industrial Process [] Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr. Horiz	
1	L 5-7%	0-13	G SL	VFR NS/NP					PS .45
		13-46	SBK SCL	FR SS/SP	2.57 7/2 @ 42"				
2		0-12	G SL	VFR NS/NP					PS .45
		12-36	SBK SCL	FR SS/SP	2.57 7/2 @ 32"				
3		0-11"	G SL	VFR NS/NP					PS .35
		11-34"	SBK CL	FR S/P	2.57 7/2 @ 32"				

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	CON	CON
Site LTAR	45	35

Other Factors (.1946):

Site Classification (.1948): PS

Evaluated By: OT

Others Present:

4x70 @ 18" 26" PUMP REPAIR IN REAR - PUMP MAY BE OMITTED W/ PROPER
 FULL TIME DETERMINED TIME OF