

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner:
 Address:
 Proposed Facility: 3 BEDROOM HOME Design Flow (.1949): 320 gpd
 Location of Site:
 Water Supply: Public Individual Well
 Evaluation Method: Auger Boring Pit
 Type of Wastewater: Sewage Industrial Process

Applicant:
 Date Evaluated: 3/31/09
 Property Size: 5/8/09
 Property Recorded:
 Spring Other
 Pit
 Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr. Horiz	
1		0-4"	G SL	VFD NS/NP					
		4-12"	SL	SOIL SATURATED @ 12" TOO WET TO PROPERLY EVALUATE					
2		0-6"	SL		BLACK @ 0"				US
					NO COLOR CHANGE				
3		0-4"	G SL	VFD NS/NP					US/PS FILL
		4-17"	G SL	VFD NS/NP					
		17-26"	SBK SL	FR S/B	2.57 7/2 @ 22"				
4		0-6"	G SL	VFD NS/NP					PS .4
		6-18"	G SL	VFD NS/NP					
		18-29"	SBK SL	FR SS/SC	2.57 7/2 @ 28"				
5		0-4"	G SL	VFD NS/NP					PS .4
		4-10"	G SL	VFD NS/NP					
		10-29"	SBK SL	FR SS/SC	2.57 7/2 @ 29"				
6		0-8"	G SL	VFD NS/NP					PS .4
		8-28"	SBK SL	FR S/P	2.57 7/2 @ 9"				

Description	Initial System	Repair System
Available Space (.1945)		
System Type(s)		
Site LTAR		

Other Factors (.1946):
 Site Classification (.1948): PS
 Evaluated By: OT
 Others Present:

7 0-16" G SL VFD NS/NP
 16-30" SBK SL FR SS/SC CR 2 @ 28" PS .4

COMMENTS: _____

LANDSCAPE POSITIONS	GROUP	TEXTURES	.1955 LTAR	CONSISTENCE MOIST	WET
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE	NS-NON-STICKY SS-SLIGHTLY STICKY
S-SHOULDER SLOPE		LS-LOAMY SAND			
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6	FI-FIRM VFI-VERY FIRM	S-STICKY VS-VERY STICKY
FS-FOOT SLOPE		L-LOAM			
N-NOSE SLOPE	III	SI-SILT-	0.6 - 0.3	EFI-EXTREMELY FIRM	NP-NON-PLASTIC SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC
H-HEAD SLOPE		SIL-SILT LOAM			
CC-CONCLAVE SLOPE		CL-CLAY LOAM			
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM			
T-TERRACE		SICL-SILTY CLAY LOAM			
FP-FLOOD PLAN	IV	SIC-SILTY CLAY	0.4 - 0.1		
		C-CLAY			
		SC-SANDY CLAY			


STRUCTURE


- SG-SINGLE GRAIN
- M-MASSIVE
- CR-CRUMB
- GR-GRANULAR
- SBK-SUBANGULAR BLOCKY
- ABK-ANGULAR BLOCKY
- PL-PLATY
- PR-PRISMATIC

MINERALOGY

- SLIGHTLY EXPANSIVE
- EXPANSIVE

Show profile locations and other site features (dimensions, reference or benchmark, and North).





SITE PLAN APPROVAL
 DISTRICT RADOB USE SFD
 #BEDROOMS 3
3/23/09 Date

 Zoning Administrator

THIS MAP WAS PREPARED FROM RECORDED DATA AS NOTED AND FROM OTHER SOURCES PROVIDED BY THE OWNER. THIS IS A PRELIMINARY SITE PLAN, INTENDED FOR PLANNING USE ONLY AND DOES NOT REPRESENT A SURVEY MADE BY THIS COMPANY. THIS MAP IS NOT INTENDED FOR RECONSTRUCTION, CONVEYANCE, OR SALES.


Charlie T. Carpenter, P.L.S.
 Professional Land Surveyor
 1940 Juniper Church Road
 Four Oaks, NC 27524
 (919) 963-2909
 (919) 320-5281



PRELIMINARY SITE PLAN FOR:
WYNN CONSTRUCTION

PIN 9997-35-7322.000
 PARCEL ID 039576 0088 37
 LOT 37 TINGEN POINTE S/D
 PB2007 PG711-718
 3/11/09
 1"=40'

105 JUNO DRIVE
 BROADWAY, NC 27609



THIS MAP WAS PREPARED FROM RECORDED DATA, AS NOTED, AND FROM OTHER SOURCES PROVIDED BY THE OWNER. THIS IS A PRELIMINARY SITE PLAN, INTENDED FOR PLANNING USE ONLY AND IN NO WAY REPRESENTS A SURVEY MADE BY THIS COMPANY. THIS MAP IS NOT INTENDED FOR RECORDATION, CONVEYANCE, OR SALES.

Charlie T. Carpenter, P.L.S.
Professional Land Surveyor



1940 Juniper Church Road
Four Oaks, NC 27524
(919) 963-2909
(919) 320-5281

PRELIMINARY SITE PLAN FOR:
WYNN CONSTRUCTION

PIN 9597-35-7322.000
PARCEL ID 039576 0088 37
LOT 37 TINGEN POINTE S/D
PB2007 PG711-718
3/11/09
1"=40'

105 JUND DRIVE
BROADWAY, NC 27505

SITE PLAN APPROVAL
DISTRICT R200B USE SFD
#BEDROOMS 3
Date 3/22/09
Zoning Administrator [Signature]

JUND DRIVE
50' PUBLIC R/W