

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: JASON PRICE CONSTRUCTION INC PROPERTY LOCATION: MARKS RD SUBDIVISION ASHEFORD LOT # 139
NEW [X] REPAIR [] EXPANSION []
Type of Structure: SFD (55'x45')
Proposed Wastewater System Type: Pump To 25% REDUCTION SYSTEM
Projected Daily Flow: 360 GPD
Number of bedrooms: 3 Number of Occupants: 6 max
Basement [] Yes [X] No
Pump Required: [X] Yes [] No [] May be required based on final location and elevations of facilities
Type of Water Supply: [] Community [X] Public [] Well Distance from well 100 feet
Permit valid for: [X] Five years [] No expiration

Authorized State Agent: [Signature] RENS Date: 3/15/10 SEE ATTACHED SITE SKETCH
The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: JASON PRICE CONSTRUCTION INC PROPERTY LOCATION: MARKS RD SUBDIVISION ASHEFORD LOT # 139
Facility Type: SFD (55'x45') [X] New [] Expansion [] Repair
Basement? [] Yes [X] No Basement Fixtures? [] Yes [X] No
Type of Wastewater System** Pump To 25% REDUCTION SYSTEM (Initial) Wastewater Flow: 360 GPD
(See note below, if applicable []) Pump To 25% REDUCTION SYSTEM (Repair)

Installation Requirements/Conditions
Septic Tank Size 1000 gallons Exact length of each trench 180 feet Trench Spacing: 9 Feet on Center
Pump Tank Size 1000 gallons Trenches shall be installed on contour at a Soil Cover: 12 inches
Maximum Trench Depth of: 24 inches (Maximum soil cover shall not exceed 36" above the trench bottom)
(Trench bottoms shall be level to +/-1/4" in all directions)

Pump Requirements: _____ ft. TDH vs. _____ GPM _____ inches below pipe
Aggregate Depth: _____ inches above pipe
Conditions: 200' OF FRENCH DRAIN REQUIRED - SEE SITE SKETCH FOR DETAILS. _____ inches total
WATER LINE MUST BE 10' FROM SEPTIC SYSTEM. THIS PERMIT BASED ON PROPOSAL FROM APPLICANTS SOIL CONSULTANT.

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.
Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature] RENS Date: 3/15/10
Construction Authorization Expiration Date: 3/15/15

HTE# 09-5-21791RR

Permit # 25927

Harnett County Department of Public Health Site Sketch

ISSUED TO: JASON PRICE CONTR. INC PROPERTY LOCATOR: MARKS RD
SUBDIVISION ASHFORD LOT # 139

Authorized State Agent: [Signature] GEN (OLIVER TOLKSDORF) Date: 3/15/10

