Department of Environment, Health, and Natural Resources
Division of Environmental Health
On-site Wastewater Section

Site
Property
Lot #:
File #:
Code:

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Owner:
Address:
Proposed Facility:
Location of Site:
Water Supply: [✓] Public [ ] Individual [ ] Well
Evaluation Method: [✓] Auger Boring [ ] Pit
Type of Wastewater: [✓] Sewage [ ] Industrial Process

Applicant:
Design Flow (.1949):
Date Evaluated: 4/13/09
Property Size:
Property Recorded:
[ ] Spring [ ] Other
[ ] Cut
[ ] Mixed

PROFILE #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941 .1941 Structure/ Texture	.1941 Consistence Mineralogy	OTHER PROFILE FACTORS .1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	Profile Class & LTAR
	LS	0-41	G/LS	VFr NSNP					
	6-7%	41-48	SBK/SCL	Fr SS SP					.6 PS
		0-31	G/LS	VFr NSNP					
		31-48	SBK/SCL	Fr SS SP					.7 PS
		0-13	G/LS	VFr NSNP					
		13-24	SBK/SCL	Fr SS P					.3 PS

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	25% Red	25% Reduct
Site LTAR	.6	.3

Other Factors (.1946):
Site Classification (.1948): PS
Evaluated By: [illegible]
Others Present: