

-----

ADDRESS : DRY CREEK RD  
 CONTRACTOR : BALDWIN ESTATES  
 OWNER : PARTIN DANIEL V & CHRISTINA G  
 PARCEL : 11-0660- - -0094- -14-  
 APPL NUMBER: 09-50021888 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : NV STEPHENSON #14  
               TAKE HWY 210 NORTH APPROX 3MILES  
               TOWARDS ANGIER. TURN RIGHT ON DRY CREEK  
               ROAD. LOT IS APPROX 1/2MI ON THE LEFT.  
               \*\*POWER CO: WAITING ON CUS\*\*  
               T/S: 04/08/2009 02:50 PM RDCONTE ---

-----

STRUCTURE: 000 000 54.8X58.8 CRAWL 3BED/2BATH W/GAR & DECK  
 FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3.00  
 SEPTIC - EXISTING? : NEW TANK

PROPOSED USE : SFD  
 WATER SUPPLY : COUNTY

-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED	INSP	DESCRIPTION
	COMPLETED	RESULT	RESULTS/COMMENTS
B101 01	7/09/09 <i>7-9-09</i>	TI <i>APBS</i>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001791771

----- COMMENTS AND NOTES -----

-----

ADDRESS . : DRY CREEK RD SUBDIV: N J STEPHENSON  
 CONTRACTOR : BALDWIN ESTATES PHONE : (919) 723-6121  
 OWNER . . : PARTIN DANIEL V & CHRISTINA G PHONE :  
 PARCEL . . : 11-0660- - -0094- -14-  
 APPL NUMBER: 09-50021888 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : NV STEPHENSON #14  
 TAKE HWY 210 NORTH APPROX 3MILES  
 TOWARDS ANGIER. TURN RIGHT ON DRY CREEK  
 ROAD. LOT IS APPROX 1/2MI ON THE LEFT.  
 \*\*POWER CO: 36077934\*\*  
 T/S: 04/08/2009 02:50 PM RDCONTE ---  
 T/S: 07/10/2009 01:30 PM JBROCK ----

-----

STRUCTURE: 000 000 54.8X58.8 CRAWL 3BED/2BATH W/GAR & DECK  
 FLOOD ZONE . . . . : FLOOD ZONE X  
 # BEDROOMS . . . . . : 3.00 PROPOSED USE . . . . . : SFD  
 SEPTIC - EXISTING? . . . . : NEW TANK WATER SUPPLY . . . . . : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/09/09	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001791771
	7/09/09	AP	T/S: July 09, 2009 09:09 AM BSUTTON -----
B103 01	7/16/09	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001794936
	<u>7-16-09</u>	<u>AEB</u>	

----- COMMENTS AND NOTES -----

ADDRESS : DRY CREEK RD SUBDIV: N J STEPHENSON  
CONTRACTOR : BALDWIN ESTATES PHONE : (919) 723-6121  
OWNER : PARTIN DANIEL V & CHRISTINA G PHONE :  
PARCEL : 11-0660- - -0094- -14-  
APPL NUMBER: 09-50021888 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : NV STEPHENSON #14  
TAKE HWY 210 NORTH APPROX 3MILES  
TOWARDS ANGIER. TURN RIGHT ON DRY CREEK  
ROAD. LOT IS APPROX 1/2MI ON THE LEFT.  
\*\*POWER CO: 36077934\*\*  
T/S: 04/08/2009 02:50 PM RDCONTE ---  
T/S: 07/10/2009 01:30 PM JBROCK ----

STRUCTURE: 000 000 54.8X58.8 CRAWL 3BED/2BATH W/GAR & DECK  
FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 3.00 PROPOSED USE : SFD  
SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/09/09 7/09/09	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001791771 T/S: July 09, 2009 09:09 AM BSUTTON ----- T/S: 07/15/2009 04:26 PM NTART ----- T/S: 07/16/2009 08:06 AM NTART ----- T/S: 07/16/2009 08:08 AM NTART ----- CALLED PROGRESS ENERGY 07/16/09 N-TART
B103 01	7/16/09 7/16/09	BS AE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001794936 apply damproofing up to final grade level, leave exterior of foundtion open. Will check at open floor inspection
B105 01	7/20/09 <u>7-20</u>	TI <u>AP</u>	R*OPEN FLOOR VRU #: 001796587

COMMENTS AND NOTES

ADDRESS : DRY CREEK RD SUBDIV: N J STEPHENSON  
 CONTRACTOR : BALDWIN ESTATES PHONE : (919) 723-6121  
 OWNER : PARTIN DANIEL V & CHRISTINA G PHONE :  
 PARCEL : 11-0660- - -0094- -14-  
 APPL NUMBER: 09-50021888 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : NV STEPHENSON #14  
 TAKE HWY 210 NORTH APPROX 3MILES  
 TOWARDS ANGIER. TURN RIGHT ON DRY CREEK  
 ROAD. LOT IS APPROX 1/2MI ON THE LEFT.  
 \*\*POWER CO: 36077934\*\*  
 T/S: 04/08/2009 02:50 PM RDCONTE ---  
 T/S: 07/10/2009 01:30 PM JBROCK ----

STRUCTURE: 000 000 54.8X58.8 CRAWL 3BED/2BATH W/GAR & DECK  
 FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/09/09 7/09/09	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001791771 T/S: July 09, 2009 09:09 AM BSUTTON ----- T/S: 07/15/2009 04:26 PM NTART ----- T/S: 07/16/2009 08:06 AM NTART ----- T/S: 07/16/2009 08:08 AM NTART ----- CALLED PROGRESS ENERGY 07/16/09 N-TART
B103 01	7/16/09 7/16/09	BS AE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001794936 apply damproofing up to final grade level, leave exterior of foundtion open. Will check at open floor inspection
B105 01	7/20/09 7/20/09	KS AP	R*OPEN FLOOR VRU #: 001796587
A814 01	8/07/09	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001805902 T/S: 08/06/2009 11:11 AM VBROWN -----
R425 01	8/10/09 <u>8-10-09</u>	TI <u>DABS</u>	FOUR TRADE ROUGH IN VRU #: 001805910

COMMENTS AND NOTES

ADDRESS : DRY CREEK RD SUBDIV: N J STEPHENSON  
 CONTRACTOR : BALDWIN ESTATES PHONE : (919) 723-6121  
 OWNER : PARTIN DANIEL V & CHRISTINA G PHONE :  
 PARCEL : 11-0660- - -0094- -14-  
 APPL NUMBER: 09-50021888 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : NV STEPHENSON #14  
 TAKE HWY 210 NORTH APPROX 3MILES  
 TOWARDS ANGIER. TURN RIGHT ON DRY CREEK  
 ROAD. LOT IS APPROX 1/2MI ON THE LEFT.  
 \*\*POWER CO: 36077934\*\*  
 T/S: 04/08/2009 02:50 PM RDCONTE ---  
 T/S: 07/10/2009 01:30 PM JBROCK ----

**STRUCTURE: 000 000 54.8X58.8 CRAWL 3BED/2BATH W/GAR & DECK**  
 FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/09/09 7/09/09	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001791771 T/S: July 09, 2009 09:09 AM BSUTTON ----- T/S: 07/15/2009 04:26 PM NTART ----- T/S: 07/16/2009 08:06 AM NTART ----- T/S: 07/16/2009 08:08 AM NTART ----- CALLED PROGRESS ENERGY 07/16/09 N-TART
B103 01	7/16/09 7/16/09	BS AE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001794936 apply damproofing up to final grade level, leave exterior of foundtion open. Will check at open floor inspection
B105 01	7/20/09 7/20/09	KS AP	R*OPEN FLOOR VRU #: 001796587
A814 01	8/07/09	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001805902 T/S: 08/06/2009 11:11 AM VBROWN -----
R425 01	8/10/09 8/10/09	BS DA	FOUR TRADE ROUGH IN VRU #: 001805910 1. Install missing window and door before insulation inspection. Do not install siding at these areas. 2. Need tempered glass at rear door both sides, top and bottom sash. (before final)3. Master shower drain to trap exceeds max allowed of 24 inches.4 need a receptacle at front porch (over 20 sq ft)
R425 02	8/13/09	TI	FOUR TRADE ROUGH IN VRU #: 001807809
I129 01	8/13/09	TI	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001807817 T/S: 08/11/2009 02:28 PM NTART -----

COMMENTS AND NOTES

ADDRESS : DRY CREEK RD SUBDIV: N J STEPHENSON  
CONTRACTOR : BALDWIN ESTATES PHONE : (919) 723-6121  
OWNER : PARTIN DANIEL V & CHRISTINA G PHONE :  
PARCEL : 11-0660- - -0094- -14-  
APPL NUMBER: 09-50021888 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : NV STEPHENSON #14  
TAKE HWY 210 NORTH APPROX 3MILES  
TOWARDS ANGIER. TURN RIGHT ON DRY CREEK  
ROAD. LOT IS APPROX 1/2MI ON THE LEFT.  
\*\*POWER CO: 36077934\*\*  
T/S: 04/08/2009 02:50 PM RDCONTE ---  
T/S: 07/10/2009 01:30 PM JBROCK ----

STRUCTURE: 000 000 54.8X58.8 CRAWL 3BED/2BATH W/GAR & DECK  
FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 3.00 PROPOSED USE : SFD  
SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/09/09	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001791771
	7/09/09	AP	T/S: July 09, 2009 09:09 AM BSUTTON ----- T/S: 07/15/2009 04:26 PM NTART ----- T/S: 07/16/2009 08:06 AM NTART ----- T/S: 07/16/2009 08:08 AM NTART ----- CALLED PROGRESS ENERGY 07/16/09 N-TART
B103 01	7/16/09	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001794936
	7/16/09	AE	apply damproofing up to final grade level, leave exterior of foundtion open. Will check at open floor inspection
B105 01	7/20/09	KS	R*OPEN FLOOR VRU #: 001796587
	7/20/09	AP	
A814 01	8/07/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001805902
	8/13/09	AP	1031 DRY CREEK RD LOT 14 ----- LILLINGTON 27546 ----- T/S: 08/13/2009 03:46 PM TWARD -----
R425 01	8/10/09	BS	FOUR TRADE ROUGH IN VRU #: 001805910
	8/10/09	DA	1. Install missing window and door before insulation inspection. Do not install siding at these areas. 2. Need tempered glass at rear door both sides, top and bottom sash. (before final)3. Master shower drain to trap exceeds max allowed of 24 inches.4 need a receptacle at front porch (over 20 sq ft)
R425 02	8/13/09	BS	FOUR TRADE ROUGH IN VRU #: 001807809
	8/13/09	AP	T/S: August 13, 2009 10:37 AM BSUTTON -----
I129 01	8/13/09	BS	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001807817
	8/13/09	AP	T/S: 08/11/2009 02:28 PM NTART ----- T/S: August 13, 2009 10:37 AM BSUTTON -----
H824 01	10/05/09	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001831494
	10/05/09	DA	PER JAMES MANHART ON HOLD FOR WATER AND POWER LINE INSPECTION. T/S: 10/05/2009 08:53 AM SSTEWARD ----- T/S: 10/05/2009 08:54 AM SSTEWARD -----
M305 01	10/08/09	TI	R*PLUMB SEWER CONNECTION TIME: 17:00 VRU #: 001832864
	10-8		T/S: 10/07/2009 11:42 AM NTART -----

-----  
ADDRESS . : DRY CREEK RD SUBDIV: N J STEPHENSON  
CONTRACTOR : BALWIN ESTATES PHONE : (919) 723-6121  
OWNER . . : PARTIN DANIEL V & CHRISTINA G PHONE :  
PARCEL . . : 11-0660- - -0094- -14-  
APPL NUMBER: 09-50021888 CP NEW RESIDENTIAL (SFD)  
-----

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P307 01	10/08/09 <u>10-8</u>	TI <u>AP</u>	R*PLUMB WATER CONNECTION TIME: 17:00 VRU #: 001832872 T/S: 10/07/2009 11:43 AM NTART -----

----- COMMENTS AND NOTES -----

ADDRESS : 55734 \*UNASSIGNED SUBDIV: N J STEPHENSON  
 CONTRACTOR : BALDWIN ESTATES PHONE : (919) 723-6121  
 OWNER : PARTIN DANIEL V & CHRISTINA G PHONE :  
 PARCEL : 11-0660- - -0094- -14-  
 APPL NUMBER: 09-50021888 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : NV STEPHENSON #14  
 TAKE HWY 210 NORTH APPROX 3MILES  
 TOWARDS ANGIER. TURN RIGHT ON DRY CREEK  
 ROAD. LOT IS APPROX 1/2MI ON THE LEFT.  
 \*\*POWER CO: 36077934\*\*  
 T/S: 04/08/2009 02:50 PM RDCONTE ---  
 T/S: 07/10/2009 01:30 PM JBROCK ----

STRUCTURE: 000 000 54.8X58.8 CRAWL 3BED/2BATH W/GAR & DECK  
 FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/09/09	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001791771
	7/09/09	AP	T/S: July 09, 2009 09:09 AM BSUTTON ----- T/S: 07/15/2009 04:26 PM NTART ----- T/S: 07/16/2009 08:06 AM NTART ----- T/S: 07/16/2009 08:08 AM NTART ----- CALLED PROGRESS ENERGY 07/16/09 N-TART
B103 01	7/16/09	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001794936
	7/16/09	AE	apply damproofing up to final grade level, leave exterior of foundtion open. Will check at open floor inspection
B105 01	7/20/09	KS	R*OPEN FLOOR VRU #: 001796587
	7/20/09	AP	
A814 01	8/07/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001805902
	8/13/09	AP	✓ 1031 DRY CREEK RD LOT 14 ----- LILLINGTON 27546 ----- T/S: 08/13/2009 03:46 PM TWARD -----
R425 01	8/10/09	BS	FOUR TRADE ROUGH IN VRU #: 001805910
	8/10/09	DA	1. Install missing window and door before insulation inspection. Do not install siding at these areas. 2. Need tempered glass at rear door both sides, top and bottom sash. (before final)3. Master shower drain to trap exceeds max allowed of 24 inches.4 need a receptacle at front porch (over 20 sq ft)
R425 02	8/13/09	BS	FOUR TRADE ROUGH IN VRU #: 001807809
	8/13/09	AP	T/S: August 13, 2009 10:37 AM BSUTTON -----
I129 01	8/13/09	BS	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001807817
	8/13/09	AP	T/S: 08/11/2009 02:28 PM NTART ----- T/S: August 13, 2009 10:37 AM BSUTTON -----
H824 01	10/05/09	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001831494
	10/05/09	DA	PER JAMES MANHART ON HOLD FOR WATER AND POWER LINE INSPECTION. T/S: 10/05/2009 08:53 AM SSTEWARD ----- ----- T/S: 10/05/2009 08:54 AM SSTEWARD -----
M305 01	10/08/09	KS	R*PLUMB SEWER CONNECTION TIME: 17:00 VRU #: 001832864
	10/08/09	AP	T/S: 10/07/2009 11:42 AM NTART -----

CONTINUED ONTO NEXT PAGE



-----  
ADDRESS . . : 55734 \*UNASSIGNED SUBDIV: N J STEPHENSON  
CONTRACTOR : BALDWIN ESTATES PHONE : (919) 723-6121  
OWNER . . . : PARTIN DANIEL V & CHRISTINA G PHONE :  
PARCEL . . . : 11-0660- - -0094- -14-  
APPL NUMBER: 09-50021888 CP NEW RESIDENTIAL (SFD)  
-----

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P307 01	10/08/09	KS	R*PLUMB WATER CONNECTION TIME: 17:00 VRU #: 001832872
	10/08/09	AP	T/S: 10/07/2009 11:43 AM NTART -----
H824 02	11/24/10	JM	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002012250
	11/24/10	AP	T/S: 11/29/2010 09:09 AM SZIMMER ----- T/S: 11/29/2010 09:09 AM SZIMMER -----
R431 02	11/30/10	VC	FOUR TRADE FINAL >2500 VRU #: 002012326
	11/29/10	CA	key code for entry 1796 T/S: 11/29/2010 09:43 AM VBROWN ----- CUSTOMER CALLED AND RESCHED FOR 12/1/10
R431 03	11/30/10 <u>11-30</u>	TT <u>DP</u>	FOUR TRADE FINAL >2500 TIME: 17:00 VRU #: 002012342 T/S: 11/29/2010 09:43 AM VBROWN ----- T/S: 11/29/2010 01:54 PM NTART ----- T/S: 11/29/2010 01:54 PM NTART ----- KEY CODE IS 1796 *****

----- COMMENTS AND NOTES -----

911 #

**Violation Notice**  
**Do Not Remove**

**Harnett County Inspection Department**  
**102 East Front St P.O. Box 65**  
**Lillington, NC 27546**  
**Phone (910) 893-7525 Fax (910) 893-2793**

09-50021888

30 Nov 10

1. No 911 numbers on house
2. Dead bolt shall be installed on front door
3. Insulation missing upstairs where return air was framed.
4. Shall have access door off bonus room
5. Tub surround shall be complete and properly sealed per plumbing code
6. Handrail shall extend full length of stairs.
7. Shall have guardrails with balusters on both sides of stairs

\$50.00 re-inspection fee

Ken Slattum  
Code Administrator  
Harnett County

ADDRESS : 1031 DRY CREEK RD
CONTRACTOR : BALDWIN ESTATES
OWNER : ROSEMAN TROY B AND ANNE L. #14
PARCEL : 11-0660- - -0094- -14-
APPL NUMBER: 09-50021888 CP NEW RESIDENTIAL (SFD)

SUBDIV: N J STEPHENSON
PHONE : (919) 723-6121
PHONE :

DIRECTIONS : NV STEPHENSON #14
TAKE HWY 210 NORTH APPROX 3MILES
TOWARDS ANGIER. TURN RIGHT ON DRY CREEK
ROAD. LOT IS APPROX 1/2MI ON THE LEFT.
\*\*POWER CO: 36077934\*\*
T/S: 04/08/2009 02:50 PM RDCONTE ---
T/S: 07/10/2009 01:30 PM JBROCK ----
T/S: 12/01/2010 11:41 AM DJOHNSON --
\*\*\*\*\*PUT CO IN TROY ROSEMANS NAME\*\*\*\*

STRUCTURE: 000 000 54.8X58.8 CRAWL 3BED/2BATH W/GAR & DECK

FLOOD ZONE : FLOOD ZONE X

# BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW TANK

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

Table with columns: TYP/SQ, REQUESTED COMPLETED, INSP RESULT, DESCRIPTION RESULTS/COMMENTS. Rows include permit details for B101, B103, B105, A814, R425, and H824.

Marquette County

INSPECTOR: IVR

DATE

12/02/10

ADDRESS . . : 1031 DRY CREEK RD  
 CONTRACTOR : BALDWIN ESTATES  
 OWNER . . . : ROSEMAN TROY B AND ANNE L. #14  
 PARCEL . . . : 11-0660- - -0094- -14-  
 APPL NUMBER: 09-50021888 CP NEW RESIDENTIAL (SFD)

SUBDIV: N J STEPHENSON  
 PHONE : (919) 723-6121  
 PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
M305 01	10/08/09	KS	T/S: 10/05/2009 08:54 AM S STEWART R*PLUMB SEWER CONNECTION TIME: 17:00 VRU #: 001832864
	10/08/09	AP	T/S: 10/07/2009 11:42 AM NTART
P307 01	10/08/09	KS	R*PLUMB WATER CONNECTION TIME: 17:00 VRU #: 001832872
	10/08/09	AP	T/S: 10/07/2009 11:43 AM NTART
H824 02	11/24/10	JM	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002012250
	11/24/10	AP	T/S: 11/29/2010 09:09 AM SZIMMER
			T/S: 11/29/2010 09:09 AM SZIMMER
R431 02	11/30/10	VC	FOUR TRADE FINAL >2500 VRU #: 002012326
	11/29/10	CA	key code for entry 1796 T/S: 11/29/2010 09:43 AM VBROWN CUSTOMER CALLED AND RESCHED FOR 12/1/10
R431 03	11/30/10	KS	FOUR TRADE FINAL >2500 TIME: 17:00 VRU #: 002012342
	11/30/10	DP	T/S: 11/29/2010 09:43 AM VBROWN T/S: 11/29/2010 01:54 PM NTART T/S: 11/29/2010 01:54 PM NTART
			✓ KEY CODE IS 1796 ***** T/S: 11/30/2010 01:48 PM KSLATTUM
			1. No 911 numbers on house 2. Dead bolt shall be installed on front door 3. Insulation missing upstairs where return air was framed. 4. Shall have access door off bonus room 5. Tub surround shall be complete and properly sealed per plumbing code 6. handrail shall extend full length of stairs. 7. Shall have guard rails with balusters on both sides of stairs at the top.
			T/S: 11/30/2010 04:13 PM NTART
			T/S: 11/30/2010 04:14 PM NTART
R431 01	12/01/10	TI	FOUR TRADE FINAL >2500 VRU #: 002010767
	11/22/10	CA	T/S: 11/22/2010 03:38 PM NTART
R431 04	12/02/10	TI	FOUR TRADE FINAL >2500 TIME: 17:00 VRU #: 002014025
	<u>12-2-10</u>	<u>ARBS</u>	T/S: 12/01/2010 04:32 PM NTART

COMMENTS AND NOTES

County of Harnett  
Building Inspections Department  
Planning Services

**Certificate of Compliance: \_\_\_\_\_ Occupancy: X**

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: SFD

**Permit Numbers**

Name: Troy & Ann Roseman

Building: 09-50021888

Address: 1031 Dry Creek Rd

Electrical: 09-50021888

Lillington NC 27546

Insulation: 09-50021888

Plumbing: 09-50021888

Mechanical: 09-50021888

MFG Home: NANANANANA

Date: 12-02-2010

Building Official: BSutton