Department of Environment, Health, and Natural Resources
Division of Environmental Health
On-site Wastewater Section

Property ID:
Lot #:
File #:
Code:

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Owner:
Address:
Applicant:
Proposed Facility: 3 Bedroom Home Design Flow (.1949): 360 gpd
Date Evaluated: 5/4/09
Location of Site:
Property Size:
Water Supply: [X] Public [ ] Individual [ ] Well
Property Recorded:
Evaluation Method: [X] Auger Boring [ ] Pit [ ] Spring [ ] Other
[ ] Cut
Type of Wastewater: [X] Sewage [ ] Industrial Process [ ] Mixed

PROFILE #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 10-15%	0-46"	G S	VFR NS/NP					S .8
2		0-46"	G S	VFR NS/NP					S .8

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	PUMP CONV	PUMP CONV
Site LTAR	.8	.8

Other Factors (.1946):
Site Classification (.1948): S
Evaluated By: ST
Others Present: —

- 2x75' @ 24"
- LOT NOT CLEARED AT TIME OF EVALUATION