





-----

ADDRESS : 32 EASTWOOD CT SUBDIV: WOODSHIRE PH 5  
 CONTRACTOR : DUSTIN BLACKWELL, INC PHONE : (919) 606-4696  
 OWNER : WOODSHIRE PARTNERS, LLC PHONE : (910) 263-6093  
 PARCEL : 01-0536-06- -0028- -40-  
 APPL NUMBER: 09-50021906 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : WOODSHIRE #200  
 TAKE HWY 27 WEST. TURN LEFT ON NURSERY  
 ROAD. TURN LEFT ON WOOD POINT. TURN  
 RIGHT ON KINBRAN. LEFT ON BLUE OAK.  
 LEFT ON EASTWOOD. LOT IS ON THE RIGHT.  
 \*\*\*POWER CO: WAITING ON CUS\*\*\*  
 T/S: 04/14/2009 08:27 AM RDCONTE ---

-----

STRUCTURE: 000 000 60X69 CRAWL 3BED/3BATH W/GAR & DECK  
 FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/05/09	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001763648
	5/05/09	AP	
B103 01	5/07/09	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001764869
	5/07/09	AP	
A814 01	5/07/09	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001764851
	5/07/09	AP	32 EASTWOOD CT LOT 200 LILLINGTON 27546
B105 01	5/08/09	TI	R*OPEN FLOOR VRU #: 001765478

*5/8/09 AP DT*

----- COMMENTS AND NOTES -----

-----

ADDRESS . . : 32 EASTWOOD CT SUBDIV: WOODSHIRE PH 5  
 CONTRACTOR : DUSTIN BLACKWELL, INC PHONE : (919) 606-4696  
 OWNER . . : WOODSHIRE PARTNERS, LLC PHONE : (910) 263-6093  
 PARCEL . . : 01-0536-06- -0028- -40-  
 APPL NUMBER: 09-50021906 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : WOODSHIRE #200  
 TAKE HWY 27 WEST. TURN LEFT ON NURSERY  
 ROAD. TURN LEFT ON WOOD POINT. TURN  
 RIGHT ON KINBRAN. LEFT ON BLUE OAK.  
 LEFT ON EASTWOOD. LOT IS ON THE RIGHT.  
 \*\*\*POWER CO: WAITING ON CUS\*\*\*  
 T/S: 04/14/2009 08:27 AM RDCONTE ---

-----

**STRUCTURE: 000 000 60X69 CRAWL 3BED/3BATH W/GAR & DECK**  
 FLOOD ZONE . . . . : FLOOD ZONE X  
 # BEDROOMS . . . . . : 3.00 PROPOSED USE . . . . . : SFD  
 SEPTIC - EXISTING? . . . . : NEW WATER SUPPLY . . . . . : COUNTY

-----

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/05/09	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001763648
	5/05/09	AP	
B103 01	5/07/09	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001764869
	5/07/09	AP	
A814 01	5/07/09	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001764851
	5/07/09	AP	32 EASTWOOD CT LOT 200 LILLINGTON 27546
B105 01	5/08/09	DT	R*OPEN FLOOR VRU #: 001765478
	5/08/09	AP	
R427 01	5/22/09	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001771435
	<u>5/22/09</u>	<u>DA DT</u>	

----- COMMENTS AND NOTES -----

-----  
ADDRESS : 32 EASTWOOD CT SUBDIV: WOODSHIRE PH 5  
CONTRACTOR : DUSTIN BLACKWELL, INC PHONE : (919) 606-4696  
OWNER : WOODSHIRE PARTNERS, LLC PHONE : (910) 263-6093  
PARCEL : 01-0536-06- -0028- -40-  
APPL NUMBER: 09-50021906 CP NEW RESIDENTIAL (SFD)  
-----

DIRECTIONS : WOODSHIRE #200  
TAKE HWY 27 WEST. TURN LEFT ON NURSERY  
ROAD. TURN LEFT ON WOOD POINT. TURN  
RIGHT ON KINBRAN. LEFT ON BLUE OAK.  
LEFT ON EASTWOOD. LOT IS ON THE RIGHT.  
\*\*\*POWER CO: WAITING ON CUS\*\*\*  
T/S: 04/14/2009 08:27 AM RDCONTE ---  
-----

STRUCTURE: 000 000 60X69 CRAWL 3BED/3BATH W/GAR & DECK  
FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 3.00 PROPOSED USE : SFD  
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/05/09	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001763648
	5/05/09	AP	
B103 01	5/07/09	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001764869
	5/07/09	AP	
A814 01	5/07/09	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001764851
	5/07/09	AP	32 EASTWOOD CT LOT 200 LILLINGTON 27546
B105 01	5/08/09	DT	R*OPEN FLOOR VRU #: 001765478
	5/08/09	AP	
R427 01	5/22/09	DT	FOUR TRADE ROUGH IN >2500 VRU #: 001771435
	5/22/09	DA	1. Need 10 psi on gas line. 2. A4 truss needs hurricane straps. okay to side and insulate.
I129 01	5/26/09	DT	R*INSULATION INSPECTION VRU #: 001772326
	5/26/09	AP	
R427 02	6/02/09	TI	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001776137
	6-29	AP-MR	

----- COMMENTS AND NOTES -----

OK to drywall

-----

ADDRESS . : 32 EASTWOOD CT SUBDIV: WOODSHIRE PH 5  
 CONTRACTOR : DUSTIN BLACKWELL, INC PHONE : (919) 606-4696  
 OWNER . . : WOODSHIRE PARTNERS, LLC PHONE : (910) 263-6093  
 PARCEL . . : 01-0536-06- -0028- -40-  
 APPL NUMBER: 09-50021906 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : WOODSHIRE #200  
 TAKE HWY 27 WEST. TURN LEFT ON NURSERY  
 ROAD. TURN LEFT ON WOOD POINT. TURN  
 RIGHT ON KINBRAN. LEFT ON BLUE OAK.  
 LEFT ON EASTWOOD. LOT IS ON THE RIGHT.  
 \*\*\*POWER CO: WAITING ON CUS\*\*\*  
 T/S: 04/14/2009 08:27 AM RDCONTE ---

-----

**STRUCTURE: 000 000 60X69 CRAWL 3BED/3BATH W/GAR & DECK**

FLOOD ZONE . . . . : FLOOD ZONE X  
 # BEDROOMS . . . . : 3.00 PROPOSED USE . . . . : SFD  
 SEPTIC - EXISTING? . . . . : NEW WATER SUPPLY . . . . : COUNTY

-----

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/05/09	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001763648
	5/05/09	AP	
B103 01	5/07/09	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001764869
	5/07/09	AP	
A814 01	5/07/09	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001764851
	5/07/09	AP	32 EASTWOOD CT LOT 200 LILLINGTON 27546
B105 01	5/08/09	DT	R*OPEN FLOOR VRU #: 001765478
	5/08/09	AP	
R427 01	5/22/09	DT	FOUR TRADE ROUGH IN >2500 VRU #: 001771435
	5/22/09	DA	1. Need 10 psi on gas line. 2. A4 truss needs hurricane straps. okay to side and insulate.
I129 01	5/26/09 <i>5/26/09</i>	TI <i>AP DT</i>	R*INSULATION INSPECTION VRU #: 001772326

----- COMMENTS AND NOTES -----

ADDRESS : 32 EASTWOOD CT SUBDIV: WOODSHIRE PH 5  
 CONTRACTOR : DUSTIN BLACKWELL, INC PHONE : (919) 606-4696  
 OWNER : WOODSHIRE PARTNERS, LLC PHONE : (910) 263-6093  
 PARCEL : 01-0536-06- -0028- -40-  
 APPL NUMBER: 09-50021906 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : WOODSHIRE #200  
 TAKE HWY 27 WEST. TURN LEFT ON NURSERY  
 ROAD. TURN LEFT ON WOOD POINT. TURN  
 RIGHT ON KINBRAN. LEFT ON BLUE OAK.  
 LEFT ON EASTWOOD. LOT IS ON THE RIGHT.  
 \*\*\*POWER CO: WAITING ON CUS\*\*\*  
 T/S: 04/14/2009 08:27 AM RDCONTE ---

**STRUCTURE: 000 000 60X69 CRAWL 3BED/3BATH W/GAR & DECK**

FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/05/09	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001763648
	5/05/09	AP	
B103 01	5/07/09	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001764869
	5/07/09	AP	
A814 01	5/07/09	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001764851
	5/07/09	AP	32 EASTWOOD CT LOT 200 LILLINGTON 27546
B105 01	5/08/09	DT	R*OPEN FLOOR VRU #: 001765478
	5/08/09	AP	
R427 01	5/22/09	DT	FOUR TRADE ROUGH IN >2500 VRU #: 001771435
	5/22/09	DA	1. Need 10 psi on gas line. 2. A4 truss needs hurricane straps. okay to side and insulate.
I129 01	5/26/09	DT	R*INSULATION INSPECTION VRU #: 001772326
	5/26/09	AP	
R427 02	6/02/09	MR	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001776137
	6/03/09	AP	
H824 01	6/04/09	BM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001778695
	6/04/09	AP	
R431 01	7/06/09	TI	FOUR TRADE FINAL >2500 VRU #: 001790112

7-6 DA

COMMENTS AND NOTES

**Violation Notice  
Do Not Remove**

**Harnett County Inspection Department  
102 East Front St P.O. Box 65  
Lillington, NC 27546  
Phone (910) 893-7525 Fax (910) 893-2793**

09-50021906

July 6, 2009

1. Need ground block at service
2. Need to cover nipple at service.
3. Need to take PRV from water heater to outside crawl space
4. Cleanout shall be brought up to grade outside of crawl space.
5. Attic not insulated.
6. Caulk toilets at floor.

Ken Slattum

*Ken Slattum*  
*7/6/09*

ADDRESS : 32 EASTWOOD CT SUBDIV: WOODSHIRE PH 5  
CONTRACTOR : DUSTIN BLACKWELL, INC PHONE : (919) 606-4696  
OWNER : WOODSHIRE PARTNERS, LLC PHONE : (910) 263-6093  
PARCEL : 01-0536-06- -0028- -40-  
APPL NUMBER: 09-50021906 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : WOODSHIRE #200  
TAKE HWY 27 WEST. TURN LEFT ON NURSERY  
ROAD. TURN LEFT ON WOOD POINT. TURN  
RIGHT ON KINBRAN. LEFT ON BLUE OAK.  
LEFT ON EASTWOOD. LOT IS ON THE RIGHT.  
\*\*\*POWER CO: WAITING ON CUS\*\*\*  
T/S: 04/14/2009 08:27 AM RDCONTE ---

STRUCTURE: 000 000 60X69 CRAWL 3BED/3BATH W/GAR & DECK

FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 3.00 PROPOSED USE : SFD  
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/05/09	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001763648
	5/05/09	AP	
B103 01	5/07/09	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001764869
	5/07/09	AP	
A814 01	5/07/09	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001764851
	5/07/09	AP	32 EASTWOOD CT LOT 200 LILLINGTON 27546
B105 01	5/08/09	DT	R*OPEN FLOOR VRU #: 001765478
	5/08/09	AP	
R427 01	5/22/09	DT	FOUR TRADE ROUGH IN >2500 VRU #: 001771435
	5/22/09	DA	1. Need 10 psi on gas line. 2. A4 truss needs hurricane straps. okay to side and insulate.
I129 01	5/26/09	DT	R*INSULATION INSPECTION VRU #: 001772326
	5/26/09	AP	
R427 02	6/02/09	MR	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001776137
	6/03/09	AP	
H824 01	6/04/09	BM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001778695
	6/04/09	AP	
R431 01	7/06/09	VC	FOUR TRADE FINAL >2500 VRU #: 001790112
	7/06/09	DA	DA PER KEN SLATTUM SO I CAN PUT IT BACK ON FOR NEXT DAY INSP. T/S: 07/06/2009 01:06 PM VBROWN -----
R431 02	7/07/09	TI	FOUR TRADE FINAL >2500 TIME: 17:00 VRU #: 001790674
	7/7/09	AP DT	T/S: 07/06/2009 01:06 PM VBROWN -----

COMMENTS AND NOTES

**COUNTY OF HARNETT  
DEPARTMENT OF BUILDING INSPECTION  
AND PLANNING/DEVELOPMENT  
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: Residential Conditional Use Permit No.: \_\_\_\_\_  
Type of Construction: \_\_\_\_\_ Building Permit No.: \_\_\_\_\_  
Owner of Building: Dustin Blackwell Inc. Electrical Permit No.: \_\_\_\_\_  
Building Address: 32 Eastwood Ct Insulation Permit No.: \_\_\_\_\_  
Zoning District: Lillington, NC 27546 Plumbing Permit No.: \_\_\_\_\_  
Zoning Permit No.: \_\_\_\_\_ Mech. Permit No.: 09-50021906  
Envir. C.O. No.: \_\_\_\_\_

Date: 7/7/09  
D. E. T. J. E.  
Building Official

Zoning Official