

ADDRESS . . : 15 CROSS ROADS CT  
CONTRACTOR : INFINITI HOMES CORP  
OWNER . . . : INFINITIT HOMES CORP  
PARCEL . . . : 03-9597- - -0033- -28-  
APPL NUMBER: 09-50021938 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : TINGEN PLACE LOT 33  
WEST ON NC 27 13 MILES GO LEFT ON TIGNE  
RD THEN LEFT INTO TINGEN PLACE S/D JB

SUBDIV: TINGEN PLACE PH 2 28LOTS  
PHONE : (919) 669-4579  
PHONE : (919) 669-4579

STRUCTURE: 000 000 68X35 3BDR CRAWL W/ GARAGE & DECK  
FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . . : 3.00  
SEPTIC - EXISTING? . . . . : NEW

PROPOSED USE . . . . . : SFD  
WATER SUPPLY . . . . . : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/19/09 <u>6.19.9</u>	TI <u>AP-MR</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001783950

COMMENTS AND NOTES

ADDRESS . . : 15 CROSS ROADS CT  
CONTRACTOR : INFINITI HOMES CORP  
OWNER . . . : INFINITIT HOMES CORP  
PARCEL . . . : 03-9597- - -0033- -28-  
APPL NUMBER: 09-50021938 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : TINGEN PLACE LOT 33  
WEST ON NC 27 13 MILES GO LEFT ON TIGNE  
RD THEN LEFT INTO TINGEN PLACE S/D JB

SUBDIV: TINGEN PLACE PH 2 28LOTS  
PHONE : (919) 669-4579  
PHONE : (919) 669-4579

STRUCTURE: 000 000 68X35 3BDR CRAWL W/ GARAGE & DECK  
FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . . : 3.00  
SEPTIC - EXISTING? . . . . : NEW

PROPOSED USE . . . . . : SFD  
WATER SUPPLY . . . . . : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/19/09	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001783950
	6/19/09	AP	
B103 01	6/25/09	TI	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001786284
	<u>6-25-09</u>	<u>AP-MR</u>	T/S: 06/24/2009 01:56 PM NTART -----

COMMENTS AND NOTES

-----

ADDRESS . : 15 CROSS ROADS CT  
 CONTRACTOR : INFINITI HOMES CORP  
 OWNER . . : INFINITIT HOMES CORP  
 PARCEL . . : 03-9597- - -0033- -28-  
 APPL NUMBER: 09-50021938 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : TINGEN PLACE LOT 33  
 WEST ON NC 27 13 MILES GO LEFT ON TIGNE  
 RD THEN LEFT INTO TINGEN PLACE S/D JB

-----

**STRUCTURE: 000 000 68X35 3BDR CRAWL W/ GARAGE & DECK**  
 FLOOD ZONE . . . . : FLOOD ZONE X  
 # BEDROOMS . . . . . : 3.00  
 SEPTIC - EXISTING? . . . . : NEW

-----

PROPOSED USE . . . . . : SFD  
 WATER SUPPLY . . . . . : COUNTY

-----

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/19/09 6/19/09	MR AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001783950
B103 01	6/25/09 6/25/09	MR AP	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001786284 T/S: 06/24/2009 01:56 PM NTART ----- T/S: 06/25/2009 02:22 PM MREARIC -----
B105 01	7/14/09 <u>7/14/09</u>	TI <u>APBS</u>	R*OPEN FLOOR VRU #: 001793686 Please inspect after 2:00 pm. If you cannot, schedule for following day (Wed). If you have any questions, please call me at 919-669-4579. Thanks John Fronk

----- COMMENTS AND NOTES -----

ADDRESS : 15 CROSS ROADS CT  
 CONTRACTOR : INFINITI HOMES CORP  
 OWNER : INFINITIT HOMES CORP  
 PARCEL : 03-9597- - -0033- -28-  
 APPL NUMBER: 09-50021938 CP NEW RESIDENTIAL (SFD)

SUBDIV: TINGEN PLACE PH 2 28LOTS  
 PHONE : (919) 669-4579  
 PHONE : (919) 669-4579

DIRECTIONS : TINGEN PLACE LOT 33  
 WEST ON NC 27 13 MILES GO LEFT ON TIGNE  
 RD THEN LEFT INTO TINGEN PLACE S/D JB

**STRUCTURE: 000 000 68X35 3BDR CRAWL W/ GARAGE & DECK**

FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/19/09	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001783950
	6/19/09	AP	
B103 01	6/25/09	MR	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001736284
	6/25/09	AP	T/S: 06/24/2009 01:56 PM NTART ----- T/S: 06/25/2009 02:22 PM MREARIC -----
B105 01	7/14/09	BS	R*OPEN FLOOR VRU #: 001793686
	7/14/09	AP	Please inspect after 2:00 pm. If you cannot, schedule for following day (Wed). If you have any questions, please call me at 919-669-4579. Thanks John Fronk T/S: July 14, 2009 02:08 PM BSUTTON -----
A814 01	7/15/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001793793
	7/14/09	AP	15 CROSS ROADS CT LOT 33 ----- BROADWAY 27505 ----- T/S: 07/14/2009 11:59 AM TWARD -----
R327 01	8/21/09	TI	THREE TRADE ROUGH IN >2500 VRU #: 001811926
	8/20/09	CA	T/S: 08/20/2009 02:48 PM NTART -----
R427 01	8/21/09	TI	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001812007
	<u>8/21/09</u>	<u>DA-MR</u>	T/S: 08/20/2009 02:49 PM NTART -----

COMMENTS AND NOTES

# HARNETT COUNTY

Building Inspections Dept.

108 E. Front St.

Lillington, NC 27546

910-893-7525

**DO NOT REMOVE**

DATE: 08-21-09

PERMIT # 09-50021938

ADDRESS: 15 crossroads

## VIOLATIONS:

1. Flashing needed on front porch
2. Fireblock garage
3. Check all trusses and strap them for uplift at correct points  
Ok to insulate and side

4. Range wire

Harnett County Building Department

Mike Rearic cell# (910) 984- 4772

ADDRESS . . : 15 CROSS ROADS CT SUBDIV: TINGEN PLACE PH 2 28LOTS  
 CONTRACTOR : INFINITI HOMES CORP PHONE : (919) 669-4579  
 OWNER . . : INFINITIT HOMES CORP PHONE : (919) 669-4579  
 PARCEL . . : 03-9597- - -0033- -28-  
 APPL NUMBER: 09-50021938 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : TINGEN PLACE LOT 33  
 WEST ON NC 27 13 MILES GO LEFT ON TIGNE  
 RD THEN LEFT INTO TINGEN PLACE S/D JB

**STRUCTURE: 000 000 68X35 3BDR CRAWL W/ GARAGE & DECK**

FLOOD ZONE . . . . : FLOOD ZONE X  
 # BEDROOMS . . . . : 3.00 PROPOSED USE . . . . : SFD  
 SEPTIC - EXISTING? . . . . : NEW WATER SUPPLY . . . . : COUNTY

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/19/09	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001783950
	6/19/09	AP	
B103 01	6/25/09	MR	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001786284
	6/25/09	AP	T/S: 06/24/2009 01:56 PM NTART ----- T/S: 06/25/2009 02:22 PM MREARIC -----
B105 01	7/14/09	BS	R*OPEN FLOOR VRU #: 001793686
	7/14/09	AP	Please inspect after 2:00 pm. If you cannot, schedule for following day (Wed). If you have any questions, please call me at 919-669-4579. Thanks John Fronk T/S: July 14, 2009 02:08 PM BSUTTON -----
A814 01	7/15/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001793793
	7/14/09	AP	15 CROSS ROADS CT LOT 33 ----- BROADWAY 27505 ----- T/S: 07/14/2009 11:59 AM TWARD -----
R327 01	8/21/09	TI	THREE TRADE ROUGH IN >2500 VRU #: 001811926
	8/20/09	CA	T/S: 08/20/2009 02:48 PM NTART -----
R427 01	8/21/09	MR	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001812007
	8/21/09	DA	T/S: 08/20/2009 02:49 PM NTART ----- T/S: 08/21/2009 12:05 PM MREARIC ----- 1. flash at front porch 2. fireblock garage walls 3. check all trusses and strap for uplift per specs 4. # 8 range wire too small 5. ok to ins. and side
I129 01	8/28/09	TI	R*INSULATION INSPECTION VRU #: 001814326
	<del>8-28-09</del>	<del>AP-MR</del>	
R427 02	8/28/09	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001814318
	<del>8-28-9</del>	<del>AP-MR</del>	

COMMENTS AND NOTES

ADDRESS : 15 CROSS ROADS CT  
CONTRACTOR : INFINITI HOMES CORP  
OWNER : INFINITIT HOMES CORP  
PARCEL : 03-9597- - -0033- -28-  
APPL NUMBER: 09-50021938 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : TINGEN PLACE LOT 33  
WEST ON NC 27 13 MILES GO LEFT ON TIGNE  
RD THEN LEFT INTO TINGEN PLACE S/D JB

SUBDIV: TINGEN PLACE PH 2 28LOTS  
PHONE : (919) 669-4579  
PHONE : (919) 669-4579

STRUCTURE: 000 000 68X35 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 3.00 PROPOSED USE : SFD  
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/19/09	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001783950
	6/19/09	AP	
B103 01	6/25/09	MR	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001' 86284
	6/25/09	AP	T/S: 06/24/2009 01:56 PM NTART ----- T/S: 06/25/2009 02:22 PM MREARIC -----
B105 01	7/14/09	BS	R*OPEN FLOOR VRU #: 001793686
	7/14/09	AP	Please inspect after 2:00 pm. If you cannot, schedule or following day (Wed). If you have any questions, please call me at 919-669-4579. Thanks John Fronk T/S: July 14, 2009 02:08 PM BSUTTON -----
A814 01	7/15/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001793793
	7/14/09	AP	15 CROSS ROADS CT LOT 33 BROADWAY 27505 T/S: 07/14/2009 11:59 AM TWARD -----
R327 01	8/21/09	TI	THREE TRADE ROUGH IN >2500 VRU #: 001811926
	8/20/09	CA	T/S: 08/20/2009 02:48 PM NTART -----
R427 01	8/21/09	MR	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001812007
	8/21/09	DA	T/S: 08/20/2009 02:49 PM NTART ----- T/S: 08/21/2009 12:05 PM MREARIC ----- 1. flash at front porch 2. fireblock garage walls 3. check all trusses and strap for uplift per specs 4. # 8 range were too small 5. ok to ins. and side
I129 01	8/28/09	MR	R*INSULATION INSPECTION VRU #: 001814326
	8/28/09	AP	T/S: 08/28/2009 11:38 AM MREARIC -----
R427 02	8/28/09	MR	FOUR TRADE ROUGH IN >2500 VRU #: 001814318
	8/28/09	AP	T/S: 08/28/2009 11:38 AM MREARIC -----
H824 01	10/29/09	JW	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001843936
	12/22/09	AP	T/S: 10/29/2009 10:18 AM SSTEWARD -----
R429 01	1/15/10	TI	FOUR TRADE FINAL VRU #: 001871488

1-15-10 APC/MF

COMMENTS AND NOTES

**COUNTY OF HARNETT  
DEPARTMENT OF BUILDING INSPECTION  
AND PLANNING/DEVELOPMENT  
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: R-3 Conditional Use Permit No.: \_\_\_\_\_  
Type of Construction: II Building Permit No.: 09-50021938  
Owner of Building: Infinity Homes Electrical Permit No.: \_\_\_\_\_  
Building Address: 15 Cross Roads Insulation Permit No.: \_\_\_\_\_  
Zoning District: \_\_\_\_\_ Plumbing Permit No.: \_\_\_\_\_  
Zoning Permit No.: \_\_\_\_\_ Mech. Permit No.: \_\_\_\_\_  
Date: 1-15-10 Envir. C.O. No.: \_\_\_\_\_  
M. Michael Kean  
Building Official Zoning Official