

ADDRESS : 106 BLUEBONNET OAK CT
CONTRACTOR : CAVINESS LAND DEVELOPMENT
OWNER : WOODSHIRE PARTNERS LLC
PARCEL : 01-0536-05- -0028- -68-
APPL NUMBER: 09-50021956 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : FOREST OAKS LOT 181
HWY 27 TO NURSERY RD TO LEMUEL BLACK RD
TO FOREST OAKS S/D JB

SUBDIV: FOREST OAKS PH 3 99LOTS
PHONE : (919) 481-0503
PHONE :

STRUCTURE: 000 000 42X38 3BDR SLAB W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00
SEPTIC - EXISTING? : NEW
PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	6/02/09 <u>6/2/09</u>	TI <u>AP DT</u>	R*PLUMB UNDER SLAB VRU #: 001775813

COMMENTS AND NOTES

ADDRESS : 106 BLUEBONNET OAK CT
CONTRACTOR : CAVINESS LAND DEVELOPMENT
OWNER : WOODSHIRE PARTNERS LLC
PARCEL : 01-0536-05- -0028- -68-
APPL NUMBER: 09-50021956 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : FOREST OAKS LOT 181
HWY 27 TO NURSERY RD TO LEMUEL BLACK RD
TO FOREST OAKS S/D JB

SUBDIV: FOREST OAKS PH 3 99LOTS
PHONE : (919) 481-0503
PHONE :

STRUCTURE: 000 000 42X38 3BDR SLAB W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00
SEPTIC - EXISTING? : NEW
PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	6/02/09	DT	R*PLUMB UNDER SLAB VRU #: 001775813
	6/02/09	AP	
B111 01	6/05/09	TI	R*BLDG SLAB INSP VRU #: 001777192
	<u>6/15/09</u>	<u>AP DT</u>	

COMMENTS AND NOTES

PREPARED 6/30/09, 13:58:01
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 18
DATE 7/01/09

ADDRESS . : 106 BLUEBONNET OAK CT
CONTRACTOR : CAVINESS LAND DEVELOPMENT
OWNER . . : WOODSHIRE PARTNERS LLC
PARCEL . . : 01-0536-05- -0028- -68-
APPL NUMBER: 09-50021956 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : FOREST OAKS LOT 181
 HWY 27 TO NURSERY RD TO LEMUEL BLACK RD
 TO FOREST OAKS S/D JB

SUBDIV: FOREST OAKS PH 3 99LOTS
PHONE : (919) 481-0503
PHONE :

STRUCTURE: 000 000 42X38 3BDR SLAB W/ GARAGE

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

SEPTIC - EXISTING? : NEW

PROPOSED USE : SFD

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	6/02/09	DT	R*PLUMB UNDER SLAB VRU #: 001775813
	6/02/09	AP	
B111 01	6/05/09	DT	R*BLDG SLAB INSP VRU #: 001777192
	6/05/09	AP	
R425 01	7/01/09	TI	FOUR TRADE ROUGH IN VRU #: 001788658

7-1-09 *OA JH*

----- COMMENTS AND NOTES -----

Violation Notice Do Not Remove

Harnett County Inspection Department

Jimmy Hall (910)984-4768

Permit #09-50021956

Date: 7/01/09

- 1) Anchor straps for walls are over 3' & 12" from end joints.
- 2) Missing nails in floor truss hangers @ bottom of stairs

ADDRESS : 106 BLUEBONNET OAK CT
CONTRACTOR : CAVINESS LAND DEVELOPMENT
OWNER : WOODSHIRE PARTNERS LLC
PARCEL : 01-0536-05- -0028- -68-
APPL NUMBER: 09-50021956 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : FOREST OAKS LOT 181
HWY 27 TO NURSERY RD TO LEMUEL BLACK RD
TO FOREST OAKS S/D JB

SUBDIV: FOREST OAKS PH 3 99LOTS
PHONE : (919) 481-0503
PHONE :

STRUCTURE: 000 000 42X38 3BDR SLAB W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	6/02/09	DT	R*PLUMB UNDER SLAB VRU #: 001775813
	6/02/09	AP	
B111 01	6/05/09	DT	R*BLDG SLAB INSP VRU #: 001777192
	6/05/09	AP	
R425 01	7/01/09	JH	FOUR TRADE ROUGH IN VRU #: 001788658
	7/01/09	DA	1)Anchor straps for walls are 3' & 12" from end joints. 2)Missing nails in floor truss hangers @ bottom of stairs.
A814 01	7/07/09	TI	ADDRESS CONFIRMATION VRU #: 001788603
R425 02	7/07/09 <i>7/7/09</i>	TI <i>DP DT</i>	FOUR TRADE ROUGH IN VRU #: 001790850

----- COMMENTS AND NOTES -----

ADDRESS : 106 BLUEBONNET OAK CT SUBDIV: FOREST OAKS PH 3 99LOTS
 CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503
 OWNER : WOODSHIRE PARTNERS LLC PHONE :
 PARCEL : 01-0536-05- -0028- -68-
 APPL NUMBER: 09-50021956 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : FOREST OAKS LOT 181
 HWY 27 TO NURSERY RD TO LEMUEL BLACK RD
 TO FOREST OAKS S/D JB

STRUCTURE: 000 000 42X38 3BDR SLAB W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	6/02/09	DT	R*PLUMB UNDER SLAB VRU #: 001775813
	6/02/09	AP	
B111 01	6/05/09	DT	R*BLDG SLAB INSP VRU #: 001777192
	6/05/09	AP	
R425 01	7/01/09	JH	FOUR TRADE ROUGH IN VRU #: 001788658
	7/01/09	DA	1)Anchor straps for walls are 3' & 12" from end joints. 2)Missing nails in floor truss hangers @ bottom of stairs.
A814 01	7/07/09	TI	ADDRESS CONFIRMATION VRU #: 001788603
R425 02	7/07/09	DT	FOUR TRADE ROUGH IN VRU #: 001790850
	7/07/09	DA	Violation 1 not fixed. T/S: 07/07/2009 01:00 PM DETAYLOR -----
R425 03	7/09/09	TI	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001792092
	7-9	AP	T/S: 07/08/2009 01:53 PM JBROCK -----

KS

COMMENTS AND NOTES

ADDRESS : 106 BLUEBONNET OAK CT
CONTRACTOR : CAVINESS LAND DEVELOPMENT
OWNER : WOODSHIRE PARTNERS LLC
PARCEL : 01-0536-05- -0028- -68-
APPL NUMBER: 09-50021956 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : FOREST OAKS LOT 181
HWY 27 TO NURSERY RD TO LEMUEL BLACK RD
TO FOREST OAKS S/D JB

SUBDIV: FOREST OAKS PH 3 99LOTS
PHONE : (919) 481-0503
PHONE :

STRUCTURE: 000 000 42X38 3BDR SLAB W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00
SEPTIC - EXISTING? : NEW
PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	6/02/09	DT	R*PLUMB UNDER SLAB VRU #: 001775813
	6/02/09	AP	
B111 01	6/05/09	DT	R*BLDG SLAB INSP VRU #: 001777192
	6/05/09	AP	
R425 01	7/01/09	JH	FOUR TRADE ROUGH IN VRU #: 001788658
	7/01/09	DA	1)Anchor straps for walls are 3' & 12" from end joints. 2)Missing nails in floor truss hangers @ bottom of stairs.
A814 01	7/07/09	TI	ADDRESS CONFIRMATION VRU #: 001788603
R425 02	7/07/09	DT	FOUR TRADE ROUGH IN VRU #: 001790850
	7/07/09	DA	Violation 1 not fixed. T/S: 07/07/2009 01:00 PM DETAYLOR -----
R425 03	7/09/09	KS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001792092
	7/09/09	AP	T/S: 07/08/2009 01:53 PM JBROCK -----
I129 01	7/13/09	TI	R*INSULATION INSPECTION VRU #: 001792974

7-13-09 AL JB

COMMENTS AND NOTES

Harnett County

INSPECTOR: IVR

DATE 11/06/09

ADDRESS : 106 BLUEBONNET OAK CT
 CONTRACTOR : CAVINESS LAND DEVELOPMENT
 OWNER : WOODSHIRE PARTNERS LLC
 PARCEL : 01-0536-05- -0028- -68-
 APPL NUMBER: 09-50021956 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : FOREST OAKS LOT 181
 HWY 27 TO NURSERY RD TO LEMUEL BLACK RD
 TO FOREST OAKS S/D JB

SUBDIV: FOREST OAKS PH 3 99LOTS
 PHONE : (919) 481-0503
 PHONE :

STRUCTURE: 000 000 42X38 3BDR SLAB W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00
 SEPTIC - EXISTING? : NEW
 PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	6/02/09	DT	R*PLUMB UNDER SLAB VRU #: 001775813
	6/02/09	AP	
B111 01	6/05/09	DT	R*BLDG SLAB INSP VRU #: 001777192
	6/05/09	AP	
R425 01	7/01/09	JH	FOUR TRADE ROUGH IN VRU #: 001788658
	7/01/09	DA	1)Anchor straps for walls are 3' & 12" from end joints. 2)Missing nails in floor truss hangers @ bottom of stairs.
R425 02	7/07/09	DT	FOUR TRADE ROUGH IN VRU #: 001790850
	7/07/09	DA	Violation 1 not fixed. T/S: 07/07/2009 01:00 PM DETAYLOR -----
A814 01	7/07/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001788603
	7/14/09	AP	✓ 106 BLUEBONNET OAK CT LOT 181 ----- BUNNLEVEL 28323 T/S: 07/14/2009 11:55 AM TWARD -----
R425 03	7/09/09	KS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001792092
	7/09/09	AP	T/S: 07/08/2009 01:53 PM JBROCK -----
I129 01	7/13/09	JH	R*INSULATION INSPECTION VRU #: 001792974
	7/13/09	AP	T/S: 07/13/2009 01:06 PM JHALL -----
H824 01	7/15/09	OT	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001795871
	7/15/09	AP	T/S: 07/16/2009 11:03 AM SSTEWARD ----- T/S: 07/16/2009 11:03 AM SSTEWARD -----
R429 01	11/06/09	TI	FOUR TRADE FINAL VRU #: 001847185
	11/6/09	AP IVR	

----- COMMENTS AND NOTES -----

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: Residential

Conditional Use Permit No.: _____

Type of Construction: _____

Building Permit No.: _____

Owner of Building: Caviness Land Dev.

Electrical Permit No.: _____

Building Address: 106 Bluebonnet Oak Ct

Insulation Permit No.: _____

Zoning District: Bunlevel, NC 28323

Plumbing Permit No.: _____

Zoning Permit No.: _____

Mech. Permit No.: 09 50021 956

Date: 11/6/09

Envir. C.O. No.: _____

[Signature]
Building Official

Zoning Official