

Sheet:
 Property ID:
 Lot #:
 File #:
 Code:

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Owner:

Applicant:

Address:

Date Evaluated: 5/4/09

Proposed Facility: 3 Bedroom Home Design Flow (.1949): 360 gpd

Property Size:

Location of Site:

Property Recorded:

Water Supply: Public Individual Well

Spring Other

Evaluation Method: Auger Boring Pit

Cut

Type of Wastewater: Sewage Industrial Process

Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1936 Sapra Class	.1944 Restr. Horiz	
1	L5 7-10%	0-16"	GS	VFL NS/NP					RS .5
		16-42"	SBK SL	FL SS/NP					
		42"	GS LAN	VFL NS/NP					
2		0-48"	GS	VFL NS/NP					RS .2
3		0-14"	GS	VFL NS/NP					RS .4
		14-28"	SBK SL	FL SS/NP					
		28-40"	SBK SL	VFL NS/NP					
		40"	MC		10x27/2 @ 40"				

Description	Initial System	Repair System
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
System Type(s)	CON	25% REP
Site LTAR	.5	.4

Other Factors (.1946):

Site Classification (.1948): RS

Evaluated By: OT

Others Present:

3x20' @ 18-30" REPAIR 3x20' @ 25% REP
 18-24"