

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner:
 Address:
 Proposed Facility: Bedroom Home Design Flow (.1949): 480 gpd
 Location of Site:
 Water Supply: Public Individual Well
 Evaluation Method: Auger Boring Pit
 Type of Wastewater: Sewage Industrial Process

Applicant:
 Date Evaluated: 5/18/09
 Property Size:
 Property Recorded:
 Spring Other
 Cut
 Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Saprot Class	.1944 Restr. Hortz	
1	LS 0-2°/1	0-24	G LS	VFN NS/NP					PS .5
		24-36	SBK SCL	FR SS/NP					
		36-48	G SL	VFN NS/NP					
2		0-16"	G LS	VFN NS/NP					US
		16-39"	SBK SCL	FR SS/NP	more than 20"				
3		0-24"	G LS	VFN NS/NP					PS .5
		24-42"	SBK SCL	FR SS/NP					
		42"	G SL	VFN NS/NP	CR 2 @ 42"				

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	CEN	25% RLB
Site LTAR	.3	.5

Other Factors (.1946): _____
 Site Classification (.1948): PS
 Evaluated By: OK
 Others Present: _____

1x320 @ 24-36"