

Property ID:
 Lot #:
 File #:
 Code:

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner:
 Address:
 Proposed Facility: Design Flow (.1949):
 Location of Site:
 Water Supply: Public Individual Well
 Evaluation Method: Auger Boring Pit
 Type of Wastewater: Sewage Industrial Process

Applicant:
 Date Evaluated: 5/19/09
 Property Size:
 Property Recorded:
 Spring Other
 Cut
 Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
2-	LS	0-42	G/LS	UW-NSP					PS.5
	4% 42-48		G/SL	UW-NSP	10YR 7/1 46"				
		0-48	G/LS	UW-NSP					PS.6
		42-48	SANDY CL	FR-SSP					
		0-40	G/LS	UW-NSP					PS.5
		40-48	SANDY CL	FR-SSP	10YR 8/1 40"				
		0-48	G/SL	UW-NSP	37"				PS.75

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	257	257
Site LTAR	.5	.5

Other Factors (.1946): _____
 Site Classification (.1948): PS
 Evaluated By: [Signature]
 Others Present: