

Sheet:
 Property ID:
 Lot #:
 File #:
 Code:

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner:

Applicant:

Address:

Date Evaluated: 5/29/09

Proposed Facility: 3 Bedroom Home Design Flow (.1949): 360 gpd

Property Size:

Location of Site:

Property Recorded:

Water Supply: Public [] Individual [] Well

[] Spring [] Other

Evaluation Method: Auger Boring [] Pit

[] Cut

Type of Wastewater: Sewage [] Industrial Process

[] Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro: Class	.1944 Restr: Horiz	
1	26 S-1086	0-10"	GS	VF2 NS/NP					PS .45
		10-43"	SBX SCL	FL SS/NP	10YR 7/1 @ 39"				
2		0-48"	GS	VF2 NS/NP	PHY. WAT @ 40"				S 8
3		0-48"	GS	VF2 NS/NP	CR2 @ 39"				S 8

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	CON	CON
Site LTAR	.8	.45

Other Factors (.1946): _____
 Site Classification (.1948): PS
 Evaluated By: OT
 Others Present: