

ADDRESS : 85 BLUEBONNET OAK CT
CONTRACTOR : CAVINESS LAND DEVELOPMENT
OWNER : WOODSHIRE PARTNERS LLC
PARCEL : 01-0536-05- -0028- -76-
APPL NUMBER: 09-50022108 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : FOREST OAKS #189

SUBDIV: FOREST OAKS PH 3 99LOTS
PHONE : (919) 481-0503
PHONE :

TAKE NC 27 WEST, TURN LEFT ON NURSERY
ROAD. TURN LEFT ON WOOD POINT DRIVE.
TURN RIGHT ON KIMBROUGH DRIVE. TURN
LEFT ON BLUE OAK DRIVE. TURN LEFT ON
VALLEY OAK DRIVE.
PWR CO: WAITING ON CUS
T/S: 05/18/2009 11:09 AM RDCONTE ---

STRUCTURE: 000 000 48.17X58 SLAB 3BED/2BATH W/GAR

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW TANK

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	7/09/09 <u>7-9</u>	TI <u>AP</u>	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 001792118 T/S: 07/08/2009 01:54 PM JBROCK

COMMENTS AND NOTES

ADDRESS : 85 BLUEBONNET OAK CT
CONTRACTOR : CAVINESS LAND DEVELOPMENT
OWNER : WOODSHIRE PARTNERS LLC
PARCEL : 01-0536-05- -0028- -76-
APPL NUMBER: 09-50022108 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : FOREST OAKS #189

SUBDIV: FOREST OAKS PH 3 99LOTS
PHONE : (919) 481-0503
PHONE :

TAKE NC 27 WEST, TURN LEFT ON NURSERY
ROAD. TURN LEFT ON WOOD POINT DRIVE.
TURN RIGHT ON KIMBROUGH DRIVE. TURN
LEFT ON BLUE OAK DRIVE. TURN LEFT ON
VALLEY OAK DRIVE.

PWR CO: WAITING ON CUS
T/S: 05/18/2009 11:09 AM RDCONTE ---

STRUCTURE: 000 000 48.17X58 SLAB 3BED/2BATH W/GAR

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW TANK

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	7/09/09	KS	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 001792118
	7/09/09	AP	T/S: 07/08/2009 01:54 PM JBROCK -----
B111 01	7/10/09	TI	R*BLDG SLAB INSP VRU #: 001792704
	<u>7-10</u>	<u>AP</u>	

----- COMMENTS AND NOTES -----

ADDRESS : 85 BLUEBONNET OAK CT
CONTRACTOR : CAVINESS LAND DEVELOPMENT
OWNER : WOODSHIRE PARTNERS LLC
PARCEL : 01-0536-05- -0028- -76-
APPL NUMBER: 09-50022108 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : FOREST OAKS #189

SUBDIV: FOREST OAKS PH 3 99LOTS
PHONE : (919) 481-0503
PHONE :

TAKE NC 27 WEST, TURN LEFT ON NURSERY
ROAD. TURN LEFT ON WOOD POINT DRIVE.
TURN RIGHT ON KIMBROUGH DRIVE. TURN
LEFT ON BLUE OAK DRIVE. TURN LEFT ON
VALLEY OAK DRIVE.

PWR CO: WAITING ON CUS
T/S: 05/18/2009 11:09 AM RDCONTE ---

STRUCTURE: 000 000 48.17X58 SLAB 3BED/2BATH W/GAR

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW TANK

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	7/09/09	KS	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 001792118
	7/09/09	AP	T/S: 07/08/2009 01:54 PM JBROCK -----
B111 01	7/10/09	KS	R*BLDG SLAB INSP VRU #: 001792704
	7/10/09	AP	
E207 01	7/15/09 <u>7-18</u>	TI <u>AP</u>	R*ELEC TEMP SERVICE POLE VRU #: 001794222

----- COMMENTS AND NOTES -----

ADDRESS : 85 BLUEBONNET OAK CT
CONTRACTOR : CAVINESS LAND DEVELOPMENT
OWNER : WOODSHIRE PARTNERS LLC
PARCEL : 01-0536-05- -0028- -76-
APPL NUMBER: 09-50022108 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : FOREST OAKS #189

SUBDIV: FOREST OAKS PH 3 99LOTS
PHONE : (919) 481-0503
PHONE :

TAKE NC 27 WEST, TURN LEFT ON NURSERY
ROAD. TURN LEFT ON WOOD POINT DRIVE.
TURN RIGHT ON KIMBROUGH DRIVE. TURN
LEFT ON BLUE OAK DRIVE. TURN LEFT ON
VALLEY OAK DRIVE.
PWR CO: WAITING ON CUS
T/S: 05/18/2009 11:09 AM RDCONTE ---

STRUCTURE: 000 000 48.17X58 SLAB 3BED/2BATH W/GAR

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW TANK

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	7/09/09	KS	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 001792118
	7/09/09	AP	T/S: 07/08/2009 01:54 PM JBROCK -----
B111 01	7/10/09	KS	R*BLDG SLAB INSP VRU #: 001792704
	7/10/09	AP	
E207 01	7/15/09	KS	R*ELEC TEMP SERVICE POLE VRU #: 001794222
	7/15/09	AP	
R425 01	8/04/09	TI	FOUR TRADE ROUGH IN VRU #: 001804408
	<u>8/4/09</u>	<u>DA DT</u>	

----- COMMENTS AND NOTES -----

ADDRESS : 85 BLUEBONNET OAK CT
CONTRACTOR : CAVINESS LAND DEVELOPMENT
OWNER : WOODSHIRE PARTNERS LLC
PARCEL : 01-0536-05- -0028- -76-
APPL NUMBER: 09-50022108 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : FOREST OAKS #189
TAKE NC 27 WEST, TURN LEFT ON NURSERY
ROAD. TURN LEFT ON WOOD POINT DRIVE.
TURN RIGHT ON KIMBROUGH DRIVE. TURN
LEFT ON BLUE OAK DRIVE. TURN LEFT ON
VALLEY OAK DRIVE.
PWR CO: WAITING ON CUS
T/S: 05/18/2009 11:09 AM RDCONTE ---

SUBDIV: FOREST OAKS PH 3 99LOTS
PHONE : (919) 481-0503
PHONE :

STRUCTURE: 000 000 48.17X58 SLAB 3BED/2BATH W/GAR
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00
SEPTIC - EXISTING? : NEW TANK

PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	7/09/09	KS	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 001792118
	7/09/09	AP	T/S: 07/08/2009 01:54 PM JBROCK -----
B111 01	7/10/09	KS	R*BLDG SLAB INSP VRU #: 001792704
	7/10/09	AP	
E207 01	7/15/09	KS	R*ELEC TEMP SERVICE POLE VRU #: 001794222
	7/15/09	AP	
R425 01	8/04/09	DT	FOUR TRADE ROUGH IN VRU #: 001804408
	8/04/09	DA	1. Trusses not strapped or braced properly. 2. Fire block wall between garage door and stairs at top. T/S: 08/04/2009 12:39 PM DETAYLOR -----
R425 02	8/06/09	TI	FOUR TRADE ROUGH IN VRU #: 001805452
	8/6/09	Ar DT	

----- COMMENTS AND NOTES -----

ADDRESS : 85 BLUEBONNET OAK CT
CONTRACTOR : CAVINESS LAND DEVELOPMENT
OWNER : WOODSHIRE PARTNERS LLC
PARCEL : 01-0536-05- -0028- -76-
APPL NUMBER: 09-50022108 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : FOREST OAKS #189

SUBDIV: FOREST OAKS PH 3 99LOTS
PHONE : (919) 481-0503
PHONE :

TAKE NC 27 WEST, TURN LEFT ON NURSERY ROAD. TURN LEFT ON WOOD POINT DRIVE. TURN RIGHT ON KIMBROUGH DRIVE. TURN LEFT ON BLUE OAK DRIVE. TURN LEFT ON VALLEY OAK DRIVE.

PWR CO: WAITING ON CUS
T/S: 05/18/2009 11:09 AM RDCONTE ---

STRUCTURE: 000 000 48.17X58 SLAB 3BED/2BATH W/GAR

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW TANK

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

Table with 4 columns: TYP/SQ, REQUESTED COMPLETED, INSP RESULT, DESCRIPTION RESULTS/COMMENTS. Contains multiple rows of inspection records with dates, times, and descriptions.

12-23-9 DP-MR

HARNETT COUNTY

Building Inspections Dept.

108 E. Front St.

Lillington, NC 27546

910-893-7525

DO NOT REMOVE

DATE: 12-23-09

PERMIT # 09-50022108

ADDRESS: 85 bluebonnet

VIOLATIONS:

1. Secure the romex feed to the water heater per code
2. Protect the water heater from auto damage
3. Install an inter system bonding terminal

Harnett County Building Department

Mike Rearic cell# (910) 984- 4772

ADDRESS : 85 BLUEBONNET OAK CT
 CONTRACTOR : CAVINESS LAND DEVELOPMENT
 OWNER : WOODSHIRE PARTNERS LLC
 PARCEL : 01-0536-05- -0028- -76-
 APPL NUMBER: 09-50022108 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : FOREST OAKS #189

SUBDIV: FOREST OAKS PH 3 99LOTS
 PHONE : (919) 481-0503
 PHONE :

TAKE NC 27 WEST, TURN LEFT ON NURSERY
 ROAD. TURN LEFT ON WOOD POINT DRIVE.
 TURN RIGHT ON KIMBROUGH DRIVE. TURN
 LEFT ON BLUE OAK DRIVE. TURN LEFT ON
 VALLEY OAK DRIVE.
 PWR CO: WAITING ON CUS
 T/S: 05/18/2009 11:09 AM RDCONTE ---

STRUCTURE: 000 000 48.17X58 SLAB 3BED/2BATH W/GAR

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00
 SEPTIC - EXISTING? : NEW TANK
 PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	7/09/09	KS	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 001792118
	7/09/09	AP	T/S: 07/08/2009 01:54 PM JBROCK -----
B111 01	7/10/09	KS	R*BLDG SLAB INSP VRU #: 001792704
	7/10/09	AP	
E207 01	7/15/09	KS	R*ELEC TEMP SERVICE POLE VRU #: 001794222
	7/15/09	AP	
R425 01	8/04/09	DT	FOUR TRADE ROUGH IN VRU #: 001804408
	8/04/09	DA	1. Trusses not strapped or braced properly. 2. Fire block wall between garage door and stairs at top. T/S: 08/04/2009 12:39 PM DETAYLOR -----
R425 02	8/06/09	DT	FOUR TRADE ROUGH IN VRU #: 001805452
	8/06/09	AP	
I129 01	8/10/09	JH	R*INSULATION INSPECTION VRU #: 001806512
	8/10/09	AP	T/S: 08/10/2009 02:41 PM JHALL -----
H824 01	10/07/09	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001833342
	10/07/09	DA	PER OLIVER TOLKSDORF PUMP, ALARM AND UTILITY LINES STILL TO BE CHECKED. T/S: 10/07/2009 03:48 PM SSTEWARD -----
R429 01	12/10/09	TI	FOUR TRADE FINAL VRU #: 001860070
	12/09/09	CA	T/S: 12/09/2009 02:11 PM NTART ----- CANCELLED FINAL INSPECTION...NO ADDRESS CONFIRMATION OR ENVIRO. COMPLETION. NJT 12/09/09
A814 01	12/16/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001860515
	12/22/09	AP	✓ 85 BLUEBONNET OAK CT LOT 189----- BUNNLEVEL 28323 T/S: 12/22/2009 11:16 AM TWARD -----
H824 02	12/18/09	OT	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001863968
	12/18/09	AP	T/S: 12/21/2009 10:00 AM SSTEWARD ----- T/S: 12/21/2009 10:00 AM SSTEWARD -----
R429 02	12/23/09	MR	FOUR TRADE FINAL VRU #: 001864664
	12/23/09	DP	T/S: 12/23/2009 01:16 PM MREARIC ----- 1. secure romex to water heater per code

PREPARED 12/28/09, 13:58:51
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 13
DATE 12/29/09

ADDRESS : 85 BLUEBONNET OAK CT
CONTRACTOR : CAVINESS LAND DEVELOPMENT
OWNER : WOODSHIRE PARTNERS LLC
PARCEL : 01-0536-05- -0028- -76-
APPL NUMBER: 09-50022108 CP NEW RESIDENTIAL (SFD)

SUBDIV: FOREST OAKS PH 3 99LOTS
PHONE : (919) 481-0503
PHONE :

REQUESTED INSP DESCRIPTION
TYP/SQ COMPLETED RESULT RESULTS/COMMENTS

R431 01 12/29/09 TI
12-29 MP
2. protect the water heater from auto damage
3. install an inter-system bonding terminal
FOUR TRADE FINAL >2500 VRU #: 001865831

----- COMMENTS AND NOTES -----

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: Residential

Type of Construction: V

Owner of Building: Caviness Land

Building Address: 85 Bluebonnet

Zoning District: _____

Zoning Permit No.: _____

Date: 12-29-09

K. Slatts

Building Official

Conditional Use Permit No.: _____

Building Permit No.: _____

Electrical Permit No.: _____

Insulation Permit No.: _____

Plumbing Permit No.: _____

Mech. Permit No.: _____

Envir. C.O. No.: _____

Zoning Official

05-58822106