
ADDRESS . . : 42 EASTWOOD CT
 CONTRACTOR : DUSTIN BLACKWELL, INC
 OWNER . . : WOODSHIRE PARTNERS LLC
 PARCEL . . : 01-0536-06- -0028- -39-
 APPL NUMBER: 09-50022133 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 42 EASTWOOD, WOODSHIRE SUB DIV #199.
 27W, LEFT ON NURSERY, LEFT ON LEMUEL
 BLACK, LEFT IN WOODSHIRE, RIGHT ON
 SON---, LEFT ON K--BRA-R, RIGHT ON BLUE
 ---, LEFT ON EASTWOOD.
 T/S: 05/20/2009 09:54 AM VBROWN ----

STRUCTURE: 000 000 45X45 4BDR 3.5 BATH SFD, GAR, DECK, CRAWL
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4.00
 SEPTIC - EXISTING? : NEW

PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/08/09 <i>7/8/09</i>	TI <i>AP DT</i>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001791367

COMMENTS AND NOTES

ADDRESS . . : 42 EASTWOOD CT
 CONTRACTOR : DUSTIN BLACKWELL, INC
 OWNER . . : WOODSHIRE PARTNERS LLC
 PARCEL . . : 01-0536-06- -0028- -39-
 APPL NUMBER: 09-50022133 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 42 EASTWOOD, WOODSHIRE SUB DIV #199.
 27W, LEFT ON NURSERY, LEFT ON LEMUEL
 BLACK, LEFT IN WOODSHIRE, RIGHT ON
 SON---, LEFT ON K--BRA-R, RIGHT ON BLUE
 ---, LEFT ON EASTWOOD.
 T/S: 05/20/2009 09:54 AM VBROWN ----

STRUCTURE: 000 000 45X45 4BDR 3.5 BATH SFD, GAR,DECK, CRAWL
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4.00
 SEPTIC - EXISTING? : NEW

PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/08/09	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001791367
	7/08/09	AP	
B103 01	7/13/09	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001793215

7-13-09 AD Jlt

COMMENTS AND NOTES

ADDRESS : 42 EASTWOOD CT SUBDIV: WOODSHIRE PH 5
CONTRACTOR : DUSTIN BLACKWELL, INC PHONE : (919) 606-4696
OWNER : WOODSHIRE PARTNERS LLC PHONE :
PARCEL : 01-0536-06- -0028- -39-
APPL NUMBER: 09-50022133 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 42 EASTWOOD, WOODSHIRE SUB DIV #199.
27W, LEFT ON NURSERY, LEFT ON LEMUEL
BLACK, LEFT IN WOODSHIRE, RIGHT ON
SON---, LEFT ON K--BRA-R, RIGHT ON BLUE
---, LEFT ON EASTWOOD.
T/S: 05/20/2009 09:54 AM VBROWN ----

STRUCTURE: 000 000 45X45 4BDR 3.5 BATH SFD, GAR, DECK, CRAWL
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/08/09	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001791367
	7/08/09	AP	
B103 01	7/13/09	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001793215
	7/13/09	AP	T/S: 07/13/2009 01:07 PM JHALL -----
A814 01	7/15/09	TI	ADDRESS CONFIRMATION VRU #: 001794197
B105 01	7/16/09	TI	R*OPEN FLOOR VRU #: 001795178
	<u>7-16-09</u>	<u>AP JH</u>	

----- COMMENTS AND NOTES -----

ADDRESS . . : 42 EASTWOOD CT SUBDIV: WOODSHIRE PH 5
CONTRACTOR : DUSTIN BLACKWELL, INC PHONE : (919) 606-4696
OWNER . . . : WOODSHIRE PARTNERS LLC PHONE :
PARCEL . . . : 01-0536-06- -0028- -39-
APPL NUMBER: 09-50022133 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 42 EASTWOOD, WOODSHIRE SUB DIV #199.
27W, LEFT ON NURSERY, LEFT ON LEMUEL
BLACK, LEFT IN WOODSHIRE, RIGHT ON
SON---, LEFT ON K--BRA-R, RIGHT ON BLUE
---, LEFT ON EASTWOOD.
T/S: 05/20/2009 09:54 AM VBROWN ----

STRUCTURE: 000 000 45X45 4BDR 3.5 BATH SFD, GAR,DECK, CRAWL
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY


PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/08/09	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001791367
	7/08/09	AP	
B103 01	7/13/09	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001793215
	7/13/09	AP	T/S: 07/13/2009 01:07 PM JHALL -----
A814 01	7/15/09	FB	ADDRESS CONFIRMATION VRU #: 001794197
	7/17/09	AP	T/S: 07/17/2009 11:25 AM FBURGESS ----- 42 EASTWOOD CT LOT 199 LILLINGTON, NC 27546
B105 01	7/16/09	JH	R*OPEN FLOOR VRU #: 001795178
	7/16/09	AP	T/S: 07/16/2009 01:04 PM JHALL -----
R427 01	7/28/09	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001800564

7-28-09 DAJH

----- COMMENTS AND NOTES -----

Functions Help



7/26/2009 11:21:04 AM

Application number, type 09 50022133 CP NEW RESIDENTIAL (SFD)

Property address 42 EASTWOOD CT

- 1) Strap all pex water lines throughout house per code 32".
- 2) Need @ least a 2 1/2" nails in 45 degree angle holes in all floor truss hangers.
- 3) Nail 3ply truss per drawings.
- 4) 3' head of water on drain lines.
- 5) Missing stud in spare bath upstairs.
- 6) Fire caulk hole in bottom plate @ playroom door.
- 7) repair floor truss damage per letter.



OK

Exit

Cancel

Copy

Insert

Delete

Time stamp

User defaults

ADDRESS : 42 EASTWOOD CT SUBDIV: WOODSHIRE PH 5
 CONTRACTOR : DUSTIN BLACKWELL, INC PHONE : (919) 606-4696
 OWNER : WOODSHIRE PARTNERS LLC PHONE :
 PARCEL : 01-0536-06- -0028- -39-
 APPL NUMBER: 09-50022133 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 42 EASTWOOD, WOODSHIRE SUB DIV #199.
 27W, LEFT ON NURSERY, LEFT ON LEMUEL
 BLACK, LEFT IN WOODSHIRE, RIGHT ON
 SON---, LEFT ON K--BRA-R, RIGHT ON BLUE
 ---, LEFT ON EASTWOOD.
 T/S: 05/20/2009 09:54 AM VBROWN ----

STRUCTURE: 000 000 45X45 4BDR 3.5 BATH SFD, GAR, DECK, CRAWL
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/08/09	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001791367
	7/08/09	AP	
B103 01	7/13/09	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001793215
	7/13/09	AP	T/S: 07/13/2009 01:07 PM JHALL -----
A814 01	7/15/09	FB	ADDRESS CONFIRMATION VRU #: 001794197
	7/17/09	AP	T/S: 07/17/2009 11:25 AM FBURGESS ----- 42 EASTWOOD CT LOT 199 LILLINGTON, NC 27546
B105 01	7/16/09	JH	R*OPEN FLOOR VRU #: 001795178
	7/16/09	AP	T/S: 07/16/2009 01:04 PM JHALL -----
R427 01	7/28/09	JH	FOUR TRADE ROUGH IN >2500 VRU #: 001800564
	7/28/09	DA	1)Strap all pex water lines throughout house per code 32". 2)Need @ least a 2 1/2" nails in 45 degree angle holes in all floor truss hangers. 3)Nail 3ply truss per drawings. 4)3' head of water on drain lines. 5)Missing stud in spare bath upstairs. 6)Fire caulk hole in bottom plate @ playroom door. 7)repair floor truss damage per letter.
I129 01	7/30/09	TI	R*INSULATION INSPECTION VRU #: 001801687
	7/30/09	TI	
R427 02	7/30/09	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001801679
	7/30/09	TI	Re-inspect 4 trade Insulation

----- COMMENTS AND NOTES -----

ADDRESS : 42 EASTWOOD CT SUBDIV: WOODSHIRE PH 5
 CONTRACTOR : DUSTIN BLACKWELL, INC PHONE : (919) 606-4696
 OWNER : WOODSHIRE PARTNERS LLC PHONE :
 PARCEL : 01-0536-06- -0028- -39-
 APPL NUMBER: 09-50022133 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : 42 EASTWOOD, WOODSHIRE SUB DIV #199.
 27W, LEFT ON NURSERY, LEFT ON LEMUEL
 BLACK, LEFT IN WOODSHIRE, RIGHT ON
 SON---, LEFT ON K--BRA-R, RIGHT ON BLUE
 ---, LEFT ON EASTWOOD.
 T/S: 05/20/2009 09:54 AM VBROWN ----

STRUCTURE: 000 000 45X45 4BDR 3.5 BATH SFD, GAR, DECK, CRAWL
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/08/09	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001791367
	7/08/09	AP	
B103 01	7/13/09	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001793215
	7/13/09	AP	T/S: 07/13/2009 01:07 PM JHALL -----
A814 01	7/15/09	FB	ADDRESS CONFIRMATION VRU #: 001794197
	7/17/09	AP	T/S: 07/17/2009 11:25 AM FBURGESS ----- 42 EASTWOOD CT LOT 199 LILLINGTON, NC 27546
B105 01	7/16/09	JH	R*OPEN FLOOR VRU #: 001795178
	7/16/09	AP	T/S: 07/16/2009 01:04 PM JHALL -----
R427 01	7/28/09	JH	FOUR TRADE ROUGH IN >2500 VRU #: 001800564
	7/28/09	DA	1)Strap all pex water lines throughout house per code 32". 2)Need @ least a 2 1/2" nails in 45 degree angle holes in all floor truss hangers. 3)Nail 3ply truss per drawings. 4)3' head of water on drain lines. 5)Missing stud in spare bath upstairs. 6)Fire caulk hole in bottom plate @ playroom door. 7)repair floor truss damage per letter.
I129 01	7/30/09	DT	R*INSULATION INSPECTION VRU #: 001801687
	7/30/09	DA	Insulation needed under attic platform T/S: 07/30/2009 12:42 PM DETAYLOR -----
R427 02	7/30/09	DT	FOUR TRADE ROUGH IN >2500 VRU #: 001801679
	7/30/09	DA	Re-inspect 4 trade Insulation Damaged trusses not repaired per engineer. T/S: 07/30/2009 12:42 PM DETAYLOR -----
I129 02	7/31/09	TI	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001803089
	<u>7/31/09</u>	<u>AP DT</u>	T/S: 07/30/2009 02:33 PM NTART -----
R427 03	7/31/09	TI	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001803097
	<u>7/31/09</u>	<u>AP DT</u>	T/S: 07/30/2009 02:33 PM NTART -----

COMMENTS AND NOTES

Harnett County

INSPECTOR: IVR

DATE 9/11/09

ADDRESS : 42 EASTWOOD CT SUBDIV: WOODSHIRE PH 5
 CONTRACTOR : DUSTIN BLACKWELL, INC PHONE : (919) 606-4696
 OWNER : WOODSHIRE PARTNERS LLC PHONE :
 PARCEL : 01-0536-06- -0028- -39-
 APPL NUMBER: 09-50022133 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : 42 EASTWOOD, WOODSHIRE SUB DIV #199.
 27W, LEFT ON NURSERY, LEFT ON LEMUEL
 BLACK, LEFT IN WOODSHIRE, RIGHT ON
 SON---, LEFT ON K--BRA-R, RIGHT ON BLUE
 ---, LEFT ON EASTWOOD.
 T/S: 05/20/2009 09:54 AM VBROWN ----

STRUCTURE: 000 000 45X45 4BDR 3.5 BATH SFD, GAR, DECK, CRAWL

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/08/09	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001791367
	7/08/09	AP	
B103 01	7/13/09	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001793215
	7/13/09	AP	T/S: 07/13/2009 01:07 PM JHALL -----
A814 01	7/15/09	FB	ADDRESS CONFIRMATION VRU #: 001794197
	7/17/09	AP	T/S: 07/17/2009 11:25 AM FBURGESS ----- <u>42 EASTWOOD CT LOT 199 LILLINGTON, NC 27546</u>
B105 01	7/16/09	JH	R*OPEN FLOOR VRU #: 001795178
	7/16/09	AP	T/S: 07/16/2009 01:04 PM JHALL -----
R427 01	7/28/09	JH	FOUR TRADE ROUGH IN >2500 VRU #: 001800564
	7/28/09	DA	1)Strap all pex water lines throughout house per code 32". 2)Need @ least a 2 1/2" nails in 45 degree angle holes in all floor truss hangers. 3)Nail 3ply truss per drawings. 4)3' head of water on drain lines. 5)Missing stud in spare bath upstairs. 6)Fire caulk hole in bottom plate @ playroom door. 7)repair floor truss damage per letter.
I129 01	7/30/09	DT	R*INSULATION INSPECTION VRU #: 001801687
	7/30/09	DA	Insulation needed under attic platform T/S: 07/30/2009 12:42 PM DETAYLOR -----
R427 02	7/30/09	DT	FOUR TRADE ROUGH IN >2500 VRU #: 001801679
	7/30/09	DA	Re-inspect 4 trade Insulation Damaged trusses not repaired per engineer. T/S: 07/30/2009 12:42 PM DETAYLOR -----
I129 02	7/31/09	DT	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001803089
	7/31/09	AP	T/S: 07/30/2009 02:33 PM NTART -----
R427 03	7/31/09	DT	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001803097
	7/31/09	AP	T/S: 07/30/2009 02:33 PM NTART -----
R431 01	9/08/09	DJ	FOUR TRADE FINAL >2500 VRU #: 001817915
	9/08/09	CA	T/S: 09/08/2009 10:03 AM DJOHNSON ----- NO OPERATIONS PERMIT ISSUED
H824 01	9/09/09	DJ	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001820448

Harnett County

INSPECTOR: IVR

DATE 9/11/09

ADDRESS : 42 EASTWOOD CT
 CONTRACTOR : DUSTIN BLACKWELL, INC
 OWNER : WOODSHIRE PARTNERS LLC
 PARCEL : 01-0536-06- -0028- -39-
 APPL NUMBER: 09-50022133 CP NEW RESIDENTIAL (SFD)

SUBDIV: WOODSHIRE PH 5
 PHONE : (919) 606-4696
 PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
	9/10/09	AP	T/S: 09/10/2009 04:07 PM DJOHNSON ----- PER PHONE CALL TODAY OPERATIONS PERMIT IS APPROVED PER JOE WEST AT EHEALTH. T/S: 09/10/2009 04:08 PM DJOHNSON ----- PER PHONE CONVERSATION WITH JOE WEST ON 9/10/09 OPERATIONS PERMIT IS APPROVED.
R431 02	9/11/09 <u>9/11/09</u>	TI <u>AP DT</u>	FOUR TRADE FINAL >2500 TIME: 17:00 VRU #: 001820455 T/S: 09/10/2009 04:12 PM DJOHNSON -----

----- COMMENTS AND NOTES -----

Operations permit is approved by Joe West on 9.10.09.

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: Residential

Conditional Use Permit No.: _____

Type of Construction: _____

Building Permit No.: _____

Owner of Building: Dustin Blackwell

Electrical Permit No.: _____

Building Address: 42 Eastwood Ct

Insulation Permit No.: _____

Zoning District: Lillington, NC 27546

Plumbing Permit No.: _____

Zoning Permit No.: _____

Mech. Permit No.: _____

Envir. C.O. No.: _____

Date: 9/11/09

[Signature]
Building Official

Zoning Official