

HTE# 09-5-22161

# Harnett County Department of Public Health

25413

## Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Benny Joe Sears PROPERTY LOCATION: SR 1418 REVER RD  
 NEW  REPAIR  EXPANSION  SUBDIVISION: Captains Landing LOT # 10  
 Type of Structure: SFD Site Improvements required prior to Construction Authorization Issuance: \_\_\_\_\_  
 Proposed Wastewater System Type: CONVENTIONAL  
 Projected Daily Flow: 360 GPD  
 Number of bedrooms: 3 Number of Occupants: 6 max  
 Basement  Yes  No  
 Pump Required:  Yes  No  May be required based on final location and elevations of facilities  
 Type of Water Supply:  Community  Public  Well Distance from well \_\_\_\_\_ feet Permit valid for:  Five years  
 Permit conditions: SEE CONSULTANTS LAYOUT - TO BE FOLLOWED EXACTLY  No expiration  
PERMIT ISSUED BASED ON CONSULTANTS PROPOSAL

Authorized State Agent: James E. Markham Date: 6-15-09 SEE ATTACHED SITE SKETCH  
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

## Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Benny Joe Sears PROPERTY LOCATION: SR 1418 REVER RD  
 Facility Type: SFD  New  Expansion  Repair  
 Basement?  Yes  No Basement Fixtures?  Yes  No  
 Type of Wastewater System\*\* CONVENTIONAL (FILL SYSTEM) (Initial) Wastewater Flow: 360 GPD  
 (See note below, if applicable ) \*NO REPAIR NEEDED! (Repair)

**Installation Requirements/Conditions**  
 Septic Tank Size 1000 gallons Number of trenches 3  
 Pump Tank Size \_\_\_\_\_ gallons Exact length of each trench 70-67' APPROX feet Trench Spacing: 9 Feet on Center  
 Trenches shall be installed on contour at a \_\_\_\_\_ Soil Cover: 6 inches  
 Maximum Trench Depth of: 12" to fill inches (Maximum soil cover shall not exceed  
 (Trench bottoms shall be level to +1-1/4" 18" to bot. 36" above the trench bottom)  
 in all directions)  
 Pump Requirements: \_\_\_\_\_ ft. TDH vs. \_\_\_\_\_ GPM Aggregate Depth: 6 inches below pipe  
SEE CONSULTANTS LAYOUT SKETCH Aggregate Depth: 2 inches above pipe  
TO BE FOLLOWED EXACTLY 12 inches total  
PERMIT ISSUED BASED ON CONSULTANTS PROPOSAL.

\*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: \_\_\_\_\_ Date: \_\_\_\_\_

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: James E. Markham Date: 6-15-09  
 Construction Authorization Expiration Date: 6-15-14

HTE# 09-5-22161

Permit # 25413

# Harnett County Department of Public Health Site Sketch

ISSUED TO: Benny JOE SEARS PROPERTY LOCATOR: 561418 RIVER RD  
SUBDIVISION: Captains Landing LOT # 10  
Authorized State Agent: James E. Manda Date: 6-15-09

*\* Follow consultant's layout for Septic System  
Exactly!*



