
ADDRESS . . : 10 WINGED FOOT DR SUBDIV: WALNUT GROVE 37LOTS
 CONTRACTOR : STEPHENSON BUILDERS, INC. PHONE : (919) 427-8654
 OWNER . . : EVEN PAR DEVELOPMENT LLC PHONE :
 PARCEL . . : 01-0525- - -0062- -26-
 APPL NUMBER: 09-50022184 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : WALNUT GROVE #17
 TAKE 210 TOWARD SPRING LAKE. TURN LEFT
 ON LASSITER ROAD. GO APPROX 1MI, TURN
 LEFT INTO WALNUT GROVE.
 PREMISE# WAITING ON CUS
 T/S: 05/28/2009 04:26 PM RDCONTE ---

STRUCTURE: 000 000 58X66 CRAWL 3BED/3BATH W/GAR & DECK
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS	VRU #:
B101 01	6/22/09 <u>6/22/09</u>	TI <u>AP DT</u>	R*BLDG FOOTING / TEMP SVC POLE	001783760

----- COMMENTS AND NOTES -----

ADDRESS : 10 WINGED FOOT DR
CONTRACTOR : STEPHENSON BUILDERS, INC.
OWNER : EVEN PAR DEVELOPMENT LLC
PARCEL : 01-0525- - -0062- -26-
APPL NUMBER: 09-50022184 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : WALNUT GROVE #17

SUBDIV: WALNUT GROVE 37LOTS
PHONE : (919) 427-8654
PHONE :

TAKE 210 TOWARD SPRING LAKE. TURN LEFT
ON LASSITER ROAD. GO APPROX 1MI, TURN
LEFT INTO WALNUT GROVE.
PREMISE# WAITING ON CUS
T/S: 05/28/2009 04:26 PM RDCONTE ---

STRUCTURE: 000 000 58X66 CRAWL 3BED/3BATH W/GAR & DECK

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/22/09	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001783760
	6/22/09	AP	
A814 01	6/25/09	TI	ADDRESS CONFIRMATION VRU #: 001785708
A814 02	6/25/09	TI	ADDRESS CONFIRMATION VRU #: 001785716
B103 01	6/25/09 <u>6/25/09</u>	TI <u>AP DT</u>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001785724

COMMENTS AND NOTES

ADDRESS : 10 WINGED FOOT DR
CONTRACTOR : STEPHENSON BUILDERS, INC.
OWNER : EVEN PAR DEVELOPMENT LLC
PARCEL : 01-0525- - -0062- -26-
APPL NUMBER: 09-50022184 CP NEW RESIDENTIAL (SFD)

SUBDIV: WALNUT GROVE 37LOTS
PHONE : (919) 427-8654
PHONE :

DIRECTIONS : WALNUT GROVE #17
TAKE 210 TOWARD SPRING LAKE. TURN LEFT
ON LASSITER ROAD. GO APPROX 1MI, TURN
LEFT INTO WALNUT GROVE.
PREMISE# WAITING ON CUS
T/S: 05/28/2009 04:26 PM RDCONTE ---

STRUCTURE: 000 000 58X66 CRAWL 3BED/3BATH W/GAR & DECK

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/22/09	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001783760
	6/22/09	AP	
A814 02	6/25/09	TI	ADDRESS CONFIRMATION VRU #: 001785716
A814 01	6/25/09	TI	ADDRESS CONFIRMATION VRU #: 001785708
	6/29/09	CA	T/S: 06/29/2009 02:10 PM NTART -----
B103 01	6/25/09	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001785724
	6/25/09	AP	
B105 01	6/30/09	TI	R*OPEN FLOOR VRU #: 001788231
	<u>6/30/09</u>	<u>ABDT</u>	after 11am inpection if possible

----- COMMENTS AND NOTES -----

ADDRESS . : 10 WINGED FOOT DR SUBDIV: WALNUT GROVE 37LOTS
 CONTRACTOR : STEPHENSON BUILDERS, INC. PHONE : (919) 427-8654
 OWNER . . : EVEN PAR DEVELOPMENT LLC PHONE :
 PARCEL . . : 01-0525- - -0062- -26-
 APPL NUMBER: 09-50022184 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : WALNUT GROVE #17
 TAKE 210 TOWARD SPRING LAKE. TURN LEFT
 ON LASSITER ROAD. GO APPROX 1MI, TURN
 LEFT INTO WALNUT GROVE.
 PREMISE# WAITING ON CUS
 T/S: 05/28/2009 04:26 PM RDCONTE ---

STRUCTURE: 000 000 58X66 CRAWL 3BED/3BATH W/GAR & DECK
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/22/09	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001783760
	6/22/09	AP	
A814 01	6/25/09	TI	ADDRESS CONFIRMATION VRU #: 001785708
	6/29/09	CA	T/S: 06/29/2009 02:10 PM NTART -----
B103 01	6/25/09	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001785724
	6/25/09	AP	
A814 02	6/25/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001785716
	6/29/09	AP	10 WINGED FOOT DR ----- BUNNLEVEL 28323 T/S: 06/29/2009 03:14 PM TWARD -----
B105 01	6/30/09	DT	R*OPEN FLOOR VRU #: 001788231
	6/30/09	AP	after 11am inspection if possible
R425 01	7/20/09	TI	FOUR TRADE ROUGH IN VRU #: 001795780

7-20-09 OAJH

----- COMMENTS AND NOTES -----

Application number, type 09 50022184 CP NEW RESIDENTIAL (SFD)

Property address 10 WINGED FOOT DR

- 1)Nail guard on wire in kitchen to left of window on back wall @ top plate.
- 2)Nail guard & fire caulk on 14/2 wire @ top plate behind refrig.
- 3)Support pex water lines every 32" @ tubs.
- 4)Rafters can not be wider than ridge beam throughout house.
- 5)Drain lines under house need to be supported every 4'.



OK Exit Cancel Copy Insert Delete Time stamp User defaults

ADDRESS : 10 WINGED FOOT DR
 CONTRACTOR : STEPHENSON BUILDERS, INC.
 OWNER : EVEN PAR DEVELOPMENT LLC
 PARCEL : 01-0525- - -0062- -26-
 APPL NUMBER: 09-50022184 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : WALNUT GROVE #17
 TAKE 210 TOWARD SPRING LAKE. TURN LEFT
 ON LASSITER ROAD. GO APPROX 1MI, TURN
 LEFT INTO WALNUT GROVE.
 PREMISE# WAITING ON CUS
 T/S: 05/28/2009 04:26 PM RDCONTE ---

SUBDIV: WALNUT GROVE 37LOTS
 PHONE : (919) 427-8654
 PHONE :

STRUCTURE: 000 000 58X66 CRAWL 3BED/3BATH W/GAR & DECK

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/22/09	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001783760
	6/22/09	AP	
A814 01	6/25/09	TI	ADDRESS CONFIRMATION VRU #: 001785708
	6/29/09	CA	T/S: 06/29/2009 02:10 PM NTART -----
B103 01	6/25/09	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001785724
	6/25/09	AP	
A814 02	6/25/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001785716
	6/29/09	AP	10 WINGED FOOT DR ----- BUNNLEVEL 28323 T/S: 06/29/2009 03:14 PM TWARD -----
B105 01	6/30/09	DT	R*OPEN FLOOR VRU #: 001788231
	6/30/09	AP	after 11am inpection if possible
R425 01	7/20/09	JH	FOUR TRADE ROUGH IN VRU #: 001795780
	7/20/09	DA	✓ Nail guard on wire in kitchen to left of window on back wall @ top plate. ✓ Nail guard & fire caulk on 14/2 wire @ top plate behind refrig. ✓ Support pex water lines every 32" @ tubs. ✓ Rafters can not be wider than ridge beam throughout house. 5) Drain lines under house need to be supported every 4'.
I129 01	7/22/09	TI	R*INSULATION INSPECTION VRU #: 001797489
	<u>7-22-09</u>	<u>APJH</u>	
R425 02	7/22/09	TI	FOUR TRADE ROUGH IN VRU #: 001797497
	<u>7-22-09</u>	<u>APJH</u>	

COMMENTS AND NOTES

ADDRESS : 10 WINGED FOOT DR
 CONTRACTOR : STEPHENSON BUILDERS, INC.
 OWNER : EVEN PAR DEVELOPMENT LLC
 PARCEL : 01-0525- - -0062- -26-
 APPL NUMBER: 09-50022184 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : WALNUT GROVE #17
 TAKE 210 TOWARD SPRING LAKE. TURN LEFT
 ON LASSITER ROAD. GO APPROX 1MI, TURN
 LEFT INTO WALNUT GROVE.
 PREMISE# WAITING ON CUS
 T/S: 05/28/2009 04:26 PM RDCONTE ---

SUBDIV: WALNUT GROVE 37LOTS
 PHONE : (919) 427-8654
 PHONE :

STRUCTURE: 000 000 58X66 CRAWL 3BED/3BATH W/GAR & DECK

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

SEPTIC - EXISTING? : NEW

PROPOSED USE : SFD

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/22/09	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001783760
	6/22/09	AP	
A814 01	6/25/09	TI	ADDRESS CONFIRMATION VRU #: 001785708
	6/29/09	CA	T/S: 06/29/2009 02:10 PM NTART -----
B103 01	6/25/09	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001785724
	6/25/09	AP	
A814 02	6/25/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001785716
	6/29/09	AP	✓ 10 WINGED FOOT DR BUNNLEVEL 28323 T/S: 06/29/2009 03:14 PM TWARD -----
B105 01	6/30/09	DT	R*OPEN FLOOR VRU #: 001788231
	6/30/09	AP	after 11am inpection if possible
R425 01	7/20/09	JH	FOUR TRADE ROUGH IN VRU #: 001795780
	7/20/09	DA	1)Nail guard on wire in kitchen to left of window on back wall @ top plate. 2)Nail guard & fire caulk on 14/2 wire @ top plate behind refrig. 3)Support pex water lines every 32" @ tubs. 4)Rafters can not be widder than ridge beam throughout house. 5)Drain lines under house need to be supported every 4'.
I129 01	7/22/09	JH	R*INSULATION INSPECTION VRU #: 001797489
	7/22/09	AP	T/S: 07/22/2009 09:56 AM JHALL -----
R425 02	7/22/09	JH	FOUR TRADE ROUGH IN VRU #: 001797497
	7/22/09	AP	T/S: 07/22/2009 09:56 AM JHALL -----
H824 01	9/11/09	BM	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001821560
	9/11/09	AP	T/S: 09/14/2009 02:08 PM CPIERCE ----- T/S: 09/14/2009 02:08 PM CPIERCE -----
R429 01	9/30/09	TI	FOUR TRADE FINAL VRU #: 001829212

9-30 AP KS

COMMENTS AND NOTES

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:-

Use Classification: Residential Conditional Use Permit No.: _____
Type of Construction: V Building Permit No.: _____
Owner of Building: Stephan Building Electrical Permit No.: _____
Building Address: 10 Winged Foot Dr. Insulation Permit No.: _____
Zoning District: _____ Plumbing Permit No.: _____
Zoning Permit No.: _____ Mech. Permit No.: _____
Date: 9-30-09 Envir. C.O. No.: 0750022184

Ken Stall
Building Official

Zoning Official