Department of Environment, Health, and Natural Resources
Division of Environmental Health
On-site Wastewater Section

Sheet:
Property ID:
Lot #:
File #:
Code:

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Owner: Applicant:

Address: Date Evaluated:

Proposed Facility: 3 BEDROOM HOME Design Flow (.1949): 360 gpd Property Size:

Location of Site: Property Recorded:

Water Supply: [X] Public [ ] Individual [ ] Well [ ] Spring [ ] Other

Evaluation Method: [X] Auger Boring [ ] Pit [ ] Cut

Type of Wastewater: [X] Sewage [ ] Industrial Process [ ] Mixed

PROFILE #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
	LS	0-12	G SS	VFR NS/NP					PS
1	0-2%	12-24	SBK SCL	FR SS/SP					.45
		24-48"	GR SBK SCL	VFR SS/NP	10YR 7/2 @ 42"				
		0-24"	G LS	VFR NS/NP	CR2 @ 48"				PS
2									.8
		0-14	G LS	VFR NS/NP					
3		14-28"	SBK SCL	FR SS/SP					PS
		28"	GR SCL	VFR SS/NP					.45
			BK @ 37"						

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	CON	CON
Site LTAR	.45	.45

Other Factors (.1946):

Site Classification (.1948): PS

Evaluated By: OT

Others Present: —