

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner:

Applicant:

Address:

Date Evaluated:

Proposed Facility: 4 Bedroom Home Design Flow (.1949): 200 gpd

Property Size:

Location of Site:

Property Recorded:

Water Supply:  Public     Individual     Well     Spring     Other  
 Evaluation Method:  Auger Boring     Pit     Cut  
 Type of Wastewater:  Sewage     Industrial Process     Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 5-7%	0-16 16-38"	GS SXSCL	FR S/SR	10YR 7/2R 37"				P <sub>5</sub> 45
2		0-28"	GS	VFR NS/HP					S <sub>5</sub>
3		0-14" 14-38"	GS SXSCL	VFR NS/HP FR S/SR	10YR 7/2R 34"				P <sub>5</sub> 45
4		0-28"	GS	VFR NS/HP					S <sub>5</sub>
5		0-28"	GS	VFR NS/HP					S <sub>5</sub>
6		0-24"	GS	VFR NS/HP					S <sub>5</sub>
7		0-28"	GS	VFR NS/HP					S <sub>5</sub>

Description	Initial System	Repair System
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
System Type(s)	CON	CON
Site LTAR	3	45

Other Factors (.1946): \_\_\_\_\_  
 Site Classification (.1948): P<sub>5</sub>  
 Evaluated By: BT  
 Others Present: \_\_\_\_\_

2x100 @ 24"