

### SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Owner:  
 Address:  
 Proposed Facility: 4 BEDROOM HOME Design Flow (.1949): 480 gpd  
 Location of Site:  
 Water Supply:  Public  Individual  Well  
 Evaluation Method:  Auger Boring  Pit  
 Type of Wastewater:  Sewage  Industrial Process

Applicant:  
 Date Evaluated:  
 Property Size:  
 Property Recorded:  
 Spring  Other  
 Cut  Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1958 Sapra Class	.1944 Restr Horiz	
1	LS 5-10%	0-10"	G LS	VFR NS/NP					US
		10-28"	SBK SCL	FR SS/SP	10yr 7/2 @ 22"				
2		0-14"	G LS	VFR NS/NP					PS .5
		14-36"	SBK SCL	FR SS/SP					
3		0-12"	G LS	VFR NS/NP					PS .5
		12-40"	SBK SCL	FR SS/SP					
4		0-12"	G LS	VFR NS/NP					PS .5
		12-40"	SBK SCL	FR SS/SP					

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	CON	CON
Site LTAR	B	S

Other Factors (.1946): \_\_\_\_\_  
 Site Classification (.1948): PS  
 Evaluated By: JK  
 Others Present: CB  
4x80 @ 20-26"