

ADDRESS : 120 WINGED FOOT DR  
CONTRACTOR : STEPHENSON BUILDERS, INC.  
OWNER : EVEN PAR DEVELOPMENT LLC  
PARCEL : 01-0525- - -0062- -19-  
APPL NUMBER: 09-50022322 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : HWY 210W TOWARD BUNNLEVEL LEFT ON  
LASSITER RD GO 3/4 MILE LEFT INTO S/D  
LOT ON LEFT ON ON WINGED FOOT DR LOT 10  
JB

SUBDIV: WALNUT GROVE 37LOTS  
PHONE : (919) 427-8654  
PHONE :

**STRUCTURE: 000 000 58X66 4BDR CRAWL W/ GARAGE & DECK**

FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 4.00 PROPOSED USE : SFD  
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/06/09 <u>7-6</u>	TI <u>TI</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001789871

----- COMMENTS AND NOTES -----

ADDRESS : 120 WINGED FOOT DR  
CONTRACTOR : STEPHENSON BUILDERS, INC.  
OWNER : EVEN PAR DEVELOPMENT LLC  
PARCEL : 01-0525- - -0062- -19-  
APPL NUMBER: 09-50022322 CP NEW RESIDENTIAL (SFD)

SUBDIV: WALNUT GROVE 37LOTS  
PHONE : (919) 427-8654  
PHONE :

DIRECTIONS : HWY 210W TOWARD BUNNLEVEL LEFT ON  
LASSITER RD GO 3/4 MILE LEFT INTO S/D  
LOT ON LEFT ON ON WINGED FOOT DR LOT 10  
JB

STRUCTURE: 000 000 58X66 4BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X

# BEDROOMS : 4.00

SEPTIC - EXISTING? : NEW

PROPOSED USE : SFD

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/06/09	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001789871
	7/06/09	AP	
B103 01	7/10/09	TI	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001792928
	<u>7-10</u>	<u>AP</u>	T/S: 07/10/2009 08:03 AM NTART -----

KS

COMMENTS AND NOTES

ADDRESS . . : 120 WINGED FOOT DR  
CONTRACTOR : STEPHENSON BUILDERS, INC.  
OWNER . . : EVEN PAR DEVELOPMENT LLC  
PARCEL . . : 01-0525- - -0062- -19-  
APPL NUMBER: 09-50022322 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : HWY 210W TOWARD BUNNLEVEL LEFT ON  
LASSITER RD GO 3/4 MILE LEFT INTO S/D  
LOT ON LEFT ON ON WINGED FOOT DR LOT 10  
JB

SUBDIV: WALNUT GROVE 37LOTS  
PHONE : (919) 427-8654  
PHONE :

STRUCTURE: 000 000 58X66 4BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . . : 4.00 PROPOSED USE . . . . . : SFD  
SEPTIC - EXISTING? . . . . : NEW WATER SUPPLY . . . . . : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/06/09	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001789871
	7/06/09	AP	
B103 01	7/10/09	KS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001792928
	7/10/09	AP	T/S: 07/10/2009 08:03 AM NTART ----- tpole ok T/S: 07/10/2009 12:47 PM KSLATTUM
A814 01	7/16/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001793189
	7/14/09	AP	120 WINGED FOOT DR LOT 10 ----- BUNNLEVEL 28323 T/S: 07/14/2009 08:50 AM TWARD -----
B105 01	7/28/09	TI	R*OPEN FLOOR VRU #: 001800580
	<u>7-28-09</u>	<u>AP JH</u>	Midday would be great. Thanks

----- COMMENTS AND NOTES -----

ADDRESS : 120 WINGED FOOT DR  
CONTRACTOR : STEPHENSON BUILDERS, INC.  
OWNER : EVEN PAR DEVELOPMENT LLC  
PARCEL : 01-0525- - -0062- -19-  
APPL NUMBER: 09-50022322 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : HWY 210W TOWARD BUNNLEVEL LEFT ON  
LASSITER RD GO 3/4 MILE LEFT INTO S/D  
LOT ON LEFT ON ON WINGED FOOT DR LOT 10  
JB

SUBDIV: WALNUT GROVE 37LOTS  
PHONE : (919) 427-8654  
PHONE :

STRUCTURE: 000 000 58X66 4BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 4.00 PROPOSED USE : SFD  
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/06/09	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001789871
	7/06/09	AP	
B103 01	7/10/09	KS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001792928
	7/10/09	AP	T/S: 07/10/2009 08:03 AM NTART tpole ok T/S: 07/10/2009 12:47 PM KSLATTUM
A814 01	7/16/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001793189
	7/14/09	AP	120 WINGED FOOT DR LOT 10 BUNNLEVEL 28323 T/S: 07/14/2009 08:50 AM TWARD
B105 01	7/28/09	JH	R*OPEN FLOOR VRU #: 001800580
	7/28/09	AP	Midday would be great. Thanks T/S: 07/28/2009 01:20 PM JHALL
R425 01	8/14/09	TI	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001807932
	8-14-09	DA JH	T/S: 08/13/2009 08:42 AM NTART

COMMENTS AND NOTES  
① missing callout ties up stairs  
② Block back wall of bonus room & top of stairs

ADDRESS : 120 WINGED FOOT DR  
CONTRACTOR : STEPHENSON BUILDERS, INC.  
OWNER : EVEN PAR DEVELOPMENT LLC  
PARCEL : 01-0525- - -0062- -19-  
APPL NUMBER: 09-50022322 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : HWY 210W TOWARD BUNNLEVEL LEFT ON  
LASSITER RD GO 3/4 MILE LEFT INTO S/D  
LOT ON LEFT ON ON WINGED FOOT DR LOT 10  
JB

SUBDIV: WALNUT GROVE 37LOTS  
PHONE : (919) 427-8654  
PHONE :

STRUCTURE: 000 000 58X66 4BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 4.00 PROPOSED USE : SFD  
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/06/09 7/06/09	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001789871
B103 01	7/10/09 7/10/09	KS AP	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001792928 T/S: 07/10/2009 08:03 AM NTART ----- tpole ok T/S: 07/10/2009 12:47 PM KSLATTUM
A814 01	7/16/09 7/14/09	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001793189 120 WINGED FOOT DR LOT 10 ----- BUNNLEVEL 28323 T/S: 07/14/2009 08:50 AM TWARD -----
B105 01	7/28/09 7/28/09	JH AP	R*OPEN FLOOR VRU #: 001800580 Midday would be great. Thanks T/S: 07/28/2009 01:20 PM JHALL -----
R425 01	8/14/09 8/14/09	JH DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001807932 T/S: 08/13/2009 08:42 AM NTART ----- 1)Missing collar ties upstairs. 2)Block back wall of bonus room @ top of stairs.
I129 01	8/17/09 8-17-09	TI AP JV	R*INSULATION INSPECTION VRU #: 001808880
R425 02	8/17/09 8-17-09	TI AP JV	FOUR TRADE ROUGH IN VRU #: 001809375

COMMENTS AND NOTES

ADDRESS : 120 WINGED FOOT DR SUBDIV: WALNUT GROVE 37LOTS  
 CONTRACTOR : STEPHENSON BUILDERS, INC. PHONE : (919) 427-8654  
 OWNER : EVEN PAR DEVELOPMENT LLC PHONE :  
 PARCEL : 01-0525- - -0062- -19-  
 APPL NUMBER: 09-50022322 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : HWY 210W TOWARD BUNNLEVEL LEFT ON  
 LASSITER RD GO 3/4 MILE LEFT INTO S/D  
 LOT ON LEFT ON ON WINGED FOOT DR LOT 10  
 JB

**STRUCTURE: 000 000 58X66 4BDR CRAWL W/ GARAGE & DECK**

FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 4.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/06/09	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001789871
	7/06/09	AP	
B103 01	7/10/09	KS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001792928
	7/10/09	AP	T/S: 07/10/2009 08:03 AM NTART ----- tpole ok T/S: 07/10/2009 12:47 PM KSLATTUM
A814 01	7/16/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001793189
	7/14/09	AP	✓ 120 WINGED FOOT DR LOT 10 ----- BUNNLEVEL 28323 T/S: 07/14/2009 08:50 AM TWARD -----
B105 01	7/28/09	JH	R*OPEN FLOOR VRU #: 001800580
	7/28/09	AP	Midday would be great. Thanks T/S: 07/28/2009 01:20 PM JHALL -----
R425 01	8/14/09	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001807932
	8/14/09	DA	T/S: 08/13/2009 08:42 AM NTART ----- 1)Missing collar ties upstairs. 2)Block back wall of bonus room @ top of stairs.
I129 01	8/17/09	JH	R*INSULATION INSPECTION VRU #: 001808880
	8/17/09	AP	T/S: 08/17/2009 12:46 PM JHALL -----
R425 02	8/17/09	JH	FOUR TRADE ROUGH IN VRU #: 001809375
	8/17/09	AP	T/S: 08/17/2009 12:47 PM JHALL -----
H824 01	10/07/09	OT	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001833219
	10/20/09	AP	PER OLIVER TOLKSDORF WATER AND POWER LINE STILL TO BE VERIFIED. T/S: 10/07/2009 02:46 PM SSTEWARD
R429 01	10/21/09	TI	FOUR TRADE FINAL VRU #: 001838598

18-21 DA

COMMENTS AND NOTES

ADDRESS : 120 WINGED FOOT DR  
 CONTRACTOR : STEPHENSON BUILDERS, INC.  
 OWNER : EVEN PAR DEVELOPMENT LLC  
 PARCEL : 01-0525- - -0062- -19-  
 APPL NUMBER: 09-50022322 CP NEW RESIDENTIAL (SFD)

SUBDIV: WALNUT GROVE 37LOTS  
 PHONE : (919) 427-8654  
 PHONE :

DIRECTIONS : HWY 210W TOWARD BUNNLEVEL LEFT ON  
 LASSITER RD GO 3/4 MILE LEFT INTO S/D  
 LOT ON LEFT ON ON WINGED FOOT DR LOT 10  
 JB

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/06/09	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001789871
	7/06/09	AP	
B103 01	7/10/09	KS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001792928
	7/10/09	AP	T/S: 07/10/2009 08:03 AM NTART ----- tpole ok T/S: 07/10/2009 12:47 PM KSLATTUM
A814 01	7/16/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001793189
	7/14/09	AP	120 WINGED FOOT DR LOT 10 ----- BUNNLEVEL 28323 T/S: 07/14/2009 08:50 AM TWARD -----
B105 01	7/28/09	JH	R*OPEN FLOOR VRU #: 001800580
	7/28/09	AP	Midday would be great. Thanks T/S: 07/28/2009 01:20 PM JHALL -----
R425 01	8/14/09	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001807932
	8/14/09	DA	T/S: 08/13/2009 08:42 AM NTART ----- 1)Missing collar ties upstairs. 2)Block back wall of bonus room @ top of stairs.
I129 01	8/17/09	JH	R*INSULATION INSPECTION VRU #: 001808880
	8/17/09	AP	T/S: 08/17/2009 12:46 PM JHALL -----
R425 02	8/17/09	JH	FOUR TRADE ROUGH IN VRU #: 001809375
	8/17/09	AP	T/S: 08/17/2009 12:47 PM JHALL -----
H824 01	10/07/09	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001833219
	10/20/09	AP	PER OLIVER TOLKSDORF WATER AND POWER LINE STILL TO BE VERIFIED. T/S: 10/07/2009 02:46 PM SSTEWARD
R429 01	10/21/09	KS	FOUR TRADE FINAL VRU #: 001838598
	10/21/09	DA	T/S: 10/21/2009 10:06 AM NTART -----
R429 02	10/22/09	TI	NEEDS R30 IN THE ATTIC. FOUR TRADE FINAL VRU #: 001839935

10/22/09 APBS

COMMENTS AND NOTES

**COUNTY OF HARNETT  
DEPARTMENT OF BUILDING INSPECTION  
AND PLANNING/DEVELOPMENT  
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: SFD

Conditional Use Permit No.: \_\_\_\_\_

Type of Construction: V

Building Permit No.: 09-50022322

Owner of Building: Stephenson Bldrs Inc

Electrical Permit No.: 09-50022322

Building Address: 120 Winged Foot Drive

Insulation Permit No.: 09-50022322

Zoning District: NA

Plumbing Permit No.: 09-50022322

Zoning Permit No.: NA

Mech. Permit No.: 09-50022322

Date: 10-22-09

Envir. C.O. No.: 09-50022322

Brad Sutton

Building Official

Zoning Official