
ADDRESS . . : BILL AVERY RD
CONTRACTOR : MARSHALL JOHNSON CONST INC
OWNER . . . : WHITTINGTON ELWOOD LEON
PARCEL . . . : 07-0691- - -0044- - -
APPL NUMBER: 09-50022335 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : AC ROWLAND ESTATE #5
TAKE 421 TO BUIES CREEK. TURN ON HWY 27
TOWARDS COATS. T/L ON BILL AVERY ROAD.
GO APPROX 1/2MI, LOT IS ON THE RIGHT.
****PREMISE # 35347053
T/S: 06/23/2009 10:26 AM RDCONTE ---

SUBDIV: A C ROWLAND ESTATE
PHONE : (919) 894-2064
PHONE :

STRUCTURE: 000 000 78X78 CRAWL 4BD/2BA W/GAR NO DECK/PATIO

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4.00
SEPTIC - EXISTING? : NEW
PROPOSED USE : SFD
WATER SUPPLY : EXT WELL

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/22/09 <u>10-22</u>	TI <u>AT</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001840226

----- COMMENTS AND NOTES -----

ADDRESS . . : BILL AVERY RD
CONTRACTOR : MARSHALL JOHNSON CONST INC
OWNER . . . : WHITTINGTON ELWOOD LEON
PARCEL . . . : 07-0691- - -0044- - -
APPL NUMBER: 09-50022335 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : AC ROWLAND ESTATE #5
TAKE 421 TO BUIES CREEK. TURN ON HWY 27
TOWARDS COATS. T/L ON BILL AVERY ROAD.
GO APPROX 1/2MI, LOT IS ON THE RIGHT.
****PREMISE # 35347053
T/S: 06/23/2009 10:26 AM RDCONTE ---

SUBDIV: A C ROWLAND ESTATE
PHONE : (919) 894-2064
PHONE :

STRUCTURE: 000 000 78X78 CRAWL 4BD/2BA W/GAR NO DECK/PATIO

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4.00
SEPTIC - EXISTING? : NEW
PROPOSED USE : SFD
WATER SUPPLY : EXT WELL

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/22/09 10/22/09	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001840226
A814 01	11/12/09	TI	ADDRESS CONFIRMATION VRU #: 001849272
B103 01	11/12/09 <u>11-12-09</u>	TI <u>AP KS</u>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001849280

----- COMMENTS AND NOTES -----

ADDRESS . . : 920 BILL AVERY RD SUBDIV: A C ROWLAND ESTATE
CONTRACTOR : MARSHALL JOHNSON CONST INC PHONE : (919) 894-2064
OWNER . . : WHITTINGTON ELWOOD LEON PHONE :
PARCEL . . : 07-0691- - -0044- - -
APPL NUMBER: 09-50022335 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : AC ROWLAND ESTATE #5
TAKE 421 TO BUIES CREEK. TURN ON HWY 27
TOWARDS COATS. T/L ON BILL AVERY ROAD.
GO APPROX 1/2MI, LOT IS ON THE RIGHT.
****PREMISE # 35347053
T/S: 06/23/2009 10:26 AM RDCONTE ---

STRUCTURE: 000 000 78X78 CRAWL 4BD/2BA W/GAR NO DECK/PATIO
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : EXT WELL

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/22/09 10/22/09	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001840226
B103 01	11/12/09 11/12/09	KS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001849280
A814 01	11/12/09 11/18/09	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001849272 920 BILL AVERY RD COATS 27521 T/S: 11/18/2009 12:03 PM TWARD
B105 01	11/19/09 <u>11-19</u>	TI <u>AP</u>	R*OPEN FLOOR VRU #: 001852178

----- COMMENTS AND NOTES -----

ADDRESS : 920 BILL AVERY RD SUBDIV: A C ROWLAND ESTATE
CONTRACTOR : MARSHALL JOHNSON CONST INC PHONE : (919) 894-2064
OWNER : WHITTINGTON ELWOOD LEON PHONE :
PARCEL : 07-0691- - -0044- - -
APPL NUMBER: 09-50022335 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : AC ROWLAND ESTATE #5
TAKE 421 TO BUIES CREEK. TURN ON HWY 27
TOWARDS COATS. T/L ON BILL AVERY ROAD.
GO APPROX 1/2MI, LOT IS ON THE RIGHT.
****PREMISE # 35347053
T/S: 06/23/2009 10:26 AM RDCONTE ---

STRUCTURE: 000 000 78X78 CRAWL 4BD/2BA W/GAR NO DECK/PATIO

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : EXT WELL

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/22/09	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001840226
	10/22/09	AP	
B103 01	11/12/09	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001849280
	11/12/09	AP	
A814 01	11/12/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001849272
	11/18/09	AP	920 BILL AVERY RD COATS 27521 T/S: 11/18/2009 12:03 PM TWARD
B105 01	11/19/09	KS	R*OPEN FLOOR VRU #: 001852178
	11/19/09	AP	
R427 01	1/14/10	KS	FOUR TRADE ROUGH IN >2500 VRU #: 001869858
	1/14/10	DA	1. Horizontal branch drain shall be 3 inch for washer. 2. Support valley rafters back to load point. ok to side and insulate T/S: 01/14/2010 01:50 PM KSLATTUM
I129 01	1/19/10	TI	R*INSULATION INSPECTION VRU #: 001871649
	1-19	AP	
R427 02	1/19/10	TI	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001872233
	1-19	BP	T/S: 01/15/2010 02:35 PM DJOHNSON

COMMENTS AND NOTES

ADDRESS : 920 BILL AVERY RD
CONTRACTOR : MARSHALL JOHNSON CONST INC
OWNER : WHITTINGTON ELWOOD LEON
PARCEL : 07-0691- - -0044- - -
APPL NUMBER: 09-50022335 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : AC ROWLAND ESTATE #5
TAKE 421 TO BUIES CREEK. TURN ON HWY 27
TOWARDS COATS. T/L ON BILL AVERY ROAD.
GO APPROX 1/2MI, LOT IS ON THE RIGHT.
****PREMISE # 35347053
T/S: 06/23/2009 10:26 AM RDCONTE ---

SUBDIV: A C ROWLAND ESTATE
PHONE : (919) 894-2064
PHONE :

STRUCTURE: 000 000 78X78 CRAWL 4BD/2BA W/GAR NO DECK/PATIO

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : EXT WELL

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/22/09	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001840226
	10/22/09	AP	
B103 01	11/12/09	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001849280
	11/12/09	AP	
A814 01	11/12/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001849272
	11/18/09	AP	920 BILL AVERY RD COATS 27521 T/S: 11/18/2009 12:03 PM TWARD
B105 01	11/19/09	KS	R*OPEN FLOOR VRU #: 001852178
	11/19/09	AP	
R427 01	1/14/10	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001869858

1-14 DA

COMMENTS AND NOTES

**Violation Notice
Do Not Remove**

**Harnett County Inspection Department
102 East Front St P.O. Box 65
Lillington, NC 27546
Phone (910) 893-7525 Fax (910) 893-2793**

09-50022335

January 14, 2010

1. Horizontal branch drain shall be 3 inch.
2. Valley rafter shall be braced back to load point.

OK to side and insulate

**Ken Slattum
Harnett County Code Official**

ADDRESS : 920 BILL AVERY RD SUBDIV: A C ROWLAND ESTATE
CONTRACTOR : MARSHALL JOHNSON CONST INC PHONE : (919) 894-2064
OWNER : WHITTINGTON ELWOOD LEON PHONE :
PARCEL : 07-0691- - -0044- - -
APPL NUMBER: 09-50022335 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : AC ROWLAND ESTATE #5
TAKE 421 TO BUIES CREEK. TURN ON HWY 27
TOWARDS COATS. T/L ON BILL AVERY ROAD.
GO APPROX 1/2MI, LOT IS ON THE RIGHT.
****PREMISE # 35347053
T/S: 06/23/2009 10:26 AM RDCONTE ---

STRUCTURE: 000 000 78X78 CRAWL 4BD/2BA W/GAR NO DECK/PATIO

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : EXT WELL

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/22/09	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001840226
	10/22/09	AP	
B103 01	11/12/09	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001849280
	11/12/09	AP	
A814 01	11/12/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001849272
	11/18/09	AP	✓ 920 BILL AVERY RD COATS 27521 T/S: 11/18/2009 12:03 PM TWARD
B105 01	11/19/09	KS	R*OPEN FLOOR VRU #: 001852178
	11/19/09	AP	
R427 01	1/14/10	KS	FOUR TRADE ROUGH IN >2500 VRU #: 001869858
	1/14/10	DA	1. Horizontal branch drain shall be 3 inch for washer. 2. Support valley rafters back to load point. ok to side and insulate T/S: 01/14/2010 01:50 PM KSLATTUM
I129 01	1/19/10	KS	R*INSULATION INSPECTION VRU #: 001871649
	1/19/10	AP	
R427 02	1/19/10	KS	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001872233
	1/19/10	AP	T/S: 01/15/2010 02:35 PM DJOHNSON
H824 01	3/17/10	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001896232
	3/17/10	DA	PER JAMES MANHART NEEDS DRIVESWAY AND SIDEWALK ESTABLISHED BEFORE FINAL CAN BE ISSUED. T/S: 03/17/2010 09:11 AM SSTEWART T/S: 03/17/2010 09:12 AM SSTEWART T/S: 03/17/2010 09:13 AM SSTEWART
H824 02	3/29/10	JM	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001901875
	3/29/10	AP	T/S: 03/29/2010 11:25 AM SSTEWART T/S: 03/29/2010 11:26 AM SSTEWART
R431 01	4/07/10	TI	FOUR TRADE FINAL >2500 VRU #: 001905488

919 291-1868

4-7 AP

COMMENTS AND NOTES

02343105

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: Occupancy:

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential

Name: Marshall Johnson

Address: 920 Bill Avery Rd

Date: 4-7-10

Building Official: Ken Stall

Permit Numbers

Building: _____

Electrical: _____

Insulation: _____

Plumbing: _____

Mechanical: 05-50022335

MFG Home: _____