
ADDRESS . . : 407 BASKET OAK DR SUBDIV: FOREST OAKS PH 3 99LOTS
 CONTRACTOR : H & H CONSTRUCTORS INC PHONE : (910) 486-4864
 OWNER . . : H & H CONSTRUCTORS INC PHONE : (910) 486-4864
 PARCEL . . : 01-0536-05- -0028- -23-
 APPL NUMBER: 09-50022342 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : FOREST OAKS SUB DIV PH 3 LOT #136,
 BASKET OAK DRIVE. 27W TO NURSERY RD,
 LEFT ON LEMUEL BLACK RD, LEFT ON VALLEY
 OAK DRIVE, INTO FOREST OAKS SUB DIV,
 BASKET OAK DRIVE #136.
 T/S: 06/25/2009 09:09 AM VBROWN ----

STRUCTURE: 000 000 50X59 3BDR 2BATH WITH GAR, DECK, SLAB
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/27/09	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001800010
	7/27/09	AP	
A814 01	7/28/09	TI	ADDRESS CONFIRMATION VRU #: 001801190
B103 01	7/29/09 <u>7/29/09</u>	TI <u>AP DT</u>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001801208

----- COMMENTS AND NOTES -----

ADDRESS : 407 BASKET OAK DR
CONTRACTOR : H & H CONSTRUCTORS INC
OWNER : H & H CONSTRUCTORS INC
PARCEL : 01-0536-05- -0028- -23-
APPL NUMBER: 09-50022342 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : FOREST OAKS SUB DIV PH 3 LOT #136,
BASKET OAK DRIVE. 27W TO NURSERY RD,
LEFT ON LEMUEL BLACK RD, LEFT ON VALLEY
OAK DRIVE, INTO FOREST OAKS SUB DIV,
BASKET OAK DRIVE #136.
T/S: 06/25/2009 09:09 AM VBROWN ----

SUBDIV: FOREST OAKS PH 3 99LOTS
PHONE : (910) 486-4864
PHONE : (910) 486-4864

STRUCTURE: 000 000 50X59 3BDR 2BATH WITH GAR, DECK, SLAB

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/27/09	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001800010
	7/27/09	AP	
A814 01	7/28/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001801190
	8/05/09	AP	407 BASKET OAK DR LOT 136 BUNNLEVEL 28323 T/S: 08/05/2009 01:31 PM TWARD
B103 01	7/29/09	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001801208
	7/29/09	AP	
P309 01	8/06/09	TI	R*PLUMB UNDER SLAB VRU #: 001805175
	8/6/09	AP DT	

COMMENTS AND NOTES

ADDRESS : 407 BASKET OAK DR SUBDIV: FOREST OAKS PH 3 99LOTS
CONTRACTOR : H & H CONSTRUCTORS INC PHONE : (910) 486-4864
OWNER : H & H CONSTRUCTORS INC PHONE : (910) 486-4864
PARCEL : 01-0536-05- -0028- -23-
APPL NUMBER: 09-50022342 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : FOREST OAKS SUB DIV PH 3 LOT #136,
BASKET OAK DRIVE. 27W TO NURSERY RD,
LEFT ON LEMUEL BLACK RD, LEFT ON VALLEY
OAK DRIVE, INTO FOREST OAKS SUB DIV,
BASKET OAK DRIVE #136.
T/S: 06/25/2009 09:09 AM VBROWN ----

STRUCTURE: 000 000 50X59 3BDR 2BATH WITH GAR, DECK, SLAB
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/27/09	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001800010
	7/27/09	AP	
A814 01	7/28/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001801190
	8/05/09	AP	407 BASKET OAK DR LOT 136 ----- BUNNLEVEL 28323 T/S: 08/05/2009 01:31 PM TWARD -----
B103 01	7/29/09	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001801208
	7/29/09	AP	
F309 01	8/06/09	DT	R*PLUMB UNDER SLAB VRU #: 001805175
	8/06/09	AP	
B111 01	8/11/09	JH	R*BLDG SLAB INSP VRU #: 001806801
	8/11/09	CA	per John11/2009 02:07 PM JHALL ----- T/S: 08/12/2009 07:18 AM JHALL -----
B111 02	8/13/09	TI	R*BLDG SLAB INSP VRU #: 001808377
	<u>8/13/09</u>	<u>APDT</u>	

----- COMMENTS AND NOTES -----

ADDRESS : 407 BASKET OAK DR SUBDIV: FOREST OAKS PH 3 99LOTS
 CONTRACTOR : H & H CONSTRUCTORS INC PHONE : (910) 486-4864
 OWNER : H & H CONSTRUCTORS INC PHONE : (910) 486-4864
 PARCEL : 01-0536-05- -0028- -23-
 APPL NUMBER: 09-50022342 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : FOREST OAKS SUB DIV PH 3 LOT #136,
 BASKET OAK DRIVE. 27W TO NURSERY RD,
 LEFT ON LEMUEL BLACK RD, LEFT ON VALLEY
 OAK DRIVE, INTO FOREST OAKS SUB DIV,
 BASKET OAK DRIVE #136.
 T/S: 06/25/2009 09:09 AM VBROWN -----

STRUCTURE: 000 000 50X59 3BDR 2BATH WITH GAR, DECK, SLAB
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/27/09	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001800010
	7/27/09	AP	
A814 01	7/28/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001801190
	8/05/09	AP	407 BASKET OAK DR LOT 136 ----- BUNNLEVEL 28323 T/S: 08/05/2009 01:31 PM TWARD -----
B103 01	7/29/09	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001801208
	7/29/09	AP	
P309 01	8/06/09	DT	R*PLUMB UNDER SLAB VRU #: 001805175
	8/06/09	AP	
B111 01	8/11/09	JH	R*BLDG SLAB INSP VRU #: 001806801
	8/11/09	CA	per John11/2009 02:07 PM JHALL ----- T/S: 08/12/2009 07:18 AM JHALL -----
B111 02	8/13/09	DT	R*BLDG SLAB INSP VRU #: 001808377
	8/13/09	AP	
R425 01	9/10/09	TI	FOUR TRADE ROUGH IN VRU #: 001819275
	<u>9/10/09</u>	<u>DADI</u>	

----- COMMENTS AND NOTES -----

VIOLATION NOTICE

DO NOT REMOVE!

Harnett County Inspection Department

108 East Front Street • P.O. Box 65

Lillington, NC 27546

Phone: (910) 893-7525 Ext. 1 • Fax: (910) 893-2793

Job Name: H & H Date: 9/10/09

Address: 407 Basket Oak

Lot No.: 136 Permit No.: _____

(Check Box for Violation)

- | | | | | | | | |
|-------------------------------------|-------------------------------------|----------------------------------|--|-------------------------------------|---------------------------------------|---------------------------------|--------------------------------------|
| <input type="checkbox"/> Footing | <input type="checkbox"/> Foundation | <input type="checkbox"/> Bldg. | <input type="checkbox"/> Elec. | <input type="checkbox"/> Plumb. | <input type="checkbox"/> Mech. | <input type="checkbox"/> Insul. | <input type="checkbox"/> Floor Fram. |
| <input type="checkbox"/> Floor Slab | <input type="checkbox"/> MFG. Home | <input type="checkbox"/> Modular | <input type="checkbox"/> Damp/Water Proof. | <input type="checkbox"/> Structural | <input type="checkbox"/> Wall Sheath. | <input type="checkbox"/> Other | |

Violations Found: 1) BO3 truss not strapped enough at joint "0"
2) Foundation bolts missing nuds between garage + master
and in front bedroom.

Okay to side

Code Enforcement Official

Signature:  Date: _____

It is unlawful for any subcontractor, general contractor, or owner to cover or cause to be covered any part of the work with flooring, sheetrock, earth or other material until the proper inspector had ample time to approve the installation

ADDRESS . . : 407 BASKET OAK DR SUBDIV: FOREST OAKS PH 3 99LOTS
CONTRACTOR : H & H CONSTRUCTORS INC PHONE : (910) 486-4864
OWNER . . . : H & H CONSTRUCTORS INC PHONE : (910) 486-4864
PARCEL . . . : 01-0536-05- -0028- -23-
APPL NUMBER: 09-50022342 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : FOREST OAKS SUB DIV PH 3 LOT #136,
BASKET OAK DRIVE. 27W TO NURSERY RD,
LEFT ON LEMUEL BLACK RD, LEFT ON VALLEY
OAK DRIVE, INTO FOREST OAKS SUB DIV,
BASKET OAK DRIVE #136.
T/S: 06/25/2009 09:09 AM VBROWN ----

STRUCTURE: 000 000 50X59 3BDR 2BATH WITH GAR, DECK, SLAB
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/27/09 7/27/09	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001800010
A814 01	7/28/09 8/05/09	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001801190 407 BASKET OAK DR LOT 136 ----- BUNNLEVEL 28323 T/S: 08/05/2009 01:31 PM TWARD -----
B103 01	7/29/09 7/29/09	DT AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001801208
P309 01	8/06/09 8/06/09	DT AP	R*PLUMB UNDER SLAB VRU #: 001805175
B111 01	8/11/09 8/11/09	JH CA	R*BLDG SLAB INSP VRU #: 001806801 per John11/2009 02:07 PM JHALL ----- T/S: 08/12/2009 07:18 AM JHALL -----
B111 02	8/13/09 8/13/09	DT AP	R*BLDG SLAB INSP VRU #: 001808377
R425 01	9/10/09 9/10/09	DT DA	FOUR TRADE ROUGH IN VRU #: 001819275 1. B03 truss not strapped enough at joint O 2. Missing foundation bolts at garage and front bedroom. T/S: 09/10/2009 03:25 PM DETAYLOR -----
R425 02	8/14/09 9/14/09	TI AP DT	FOUR TRADE ROUGH IN VRU #: 001820463

----- COMMENTS AND NOTES -----

ADDRESS : 407 BASKET OAK DR SUBDIV: FOREST OAKS PH 3 99LOTS
CONTRACTOR : H & H CONSTRUCTORS INC PHONE : (910) 486-4864
OWNER : H & H CONSTRUCTORS INC PHONE : (910) 486-4864
PARCEL : 01-0536-05- -0028- -23-
APPL NUMBER: 09-50022342 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : FOREST OAKS SUB DIV PH 3 LOT #136,
BASKET OAK DRIVE. 27W TO NURSERY RD,
LEFT ON LEMUEL BLACK RD, LEFT ON VALLEY
OAK DRIVE, INTO FOREST OAKS SUB DIV,
BASKET OAK DRIVE #136.
T/S: 06/25/2009 09:09 AM VBROWN ----

STRUCTURE: 000 000 50X59 3BDR 2BATH WITH GAR, DECK, SLAB
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/27/09	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001800010
	7/27/09	AP	
A814 01	7/28/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001801190
	8/05/09	AP	407 BASKET OAK DR LOT 136 BUNNLEVEL 28323 T/S: 08/05/2009 01:31 PM TWARD -----
B103 01	7/29/09	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001801208
	7/29/09	AP	
P309 01	8/06/09	DT	R*PLUMB UNDER SLAB VRU #: 001805175
	8/06/09	AP	
B111 01	8/11/09	JH	R*BLDG SLAB INSP VRU #: 001806801
	8/11/09	CA	per John11/2009 02:07 PM JHALL ----- T/S: 08/12/2009 07:18 AM JHALL -----
B111 02	8/13/09	DT	R*BLDG SLAB INSP VRU #: 001808377
	8/13/09	AP	
R425 01	9/10/09	DT	FOUR TRADE ROUGH IN VRU #: 001819275
	9/10/09	DA	1. BO3 truss not strapped enough at joint O 2. Missing foundation bolts at garage and front bedroom. T/S: 09/10/2009 03:25 PM DETAYLOR -----
R425 02	9/14/09	DT	FOUR TRADE ROUGH IN VRU #: 001820463
	9/14/09	AP	
I129 01	9/16/09	TI	R*INSULATION INSPECTION VRU #: 001821669
	9/16/09	AP DI	

----- COMMENTS AND NOTES -----

ADDRESS : 407 BASKET OAK DR SUBDIV: FOREST OAKS PH 3 99LOTS
 CONTRACTOR : H & H CONSTRUCTORS INC PHONE : (910) 486-4864
 OWNER : H & H CONSTRUCTORS INC PHONE : (910) 486-4864
 PARCEL : 01-0536-05- -0028- -23-
 APPL NUMBER: 09-50022342 CP NEW RESIDENTIAL (SFD)


DIRECTIONS : FOREST OAKS SUB DIV PH 3 LOT #136,
 BASKET OAK DRIVE. 27W TO NURSERY RD,
 LEFT ON LEMUEL BLACK RD, LEFT ON VALLEY
 OAK DRIVE, INTO FOREST OAKS SUB DIV,
 BASKET OAK DRIVE #136.
 T/S: 06/25/2009 09:09 AM VBROWN ----

STRUCTURE: 000 000 50X59 3BDR 2BATH WITH GAR, DECK, SLAB
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/27/09	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001800010
	7/27/09	AP	
A814 01	7/28/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001801190
	8/05/09	AP	✓ 407 BASKET OAK DR LOT 136 ----- BUNNLEVEL 28323 T/S: 08/05/2009 01:31 PM TWARD -----
B103 01	7/29/09	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001801208
	7/29/09	AP	
P309 01	8/06/09	DT	R*PLUMB UNDER SLAB VRU #: 001805175
	8/06/09	AP	
B111 01	8/11/09	JH	R*BLDG SLAB INSP VRU #: 001806801
	8/11/09	CA	per John11/2009 02:07 PM JHALL ----- T/S: 08/12/2009 07:18 AM JHALL -----
B111 02	8/13/09	DT	R*BLDG SLAB INSP VRU #: 001808377
	8/13/09	AP	
R425 01	9/10/09	DT	FOUR TRADE ROUGH IN VRU #: 001819275
	9/10/09	DA	1. BO3 truss not strapped enough at joint O 2. Missing foundation bolts at garage and front bedroom. T/S: 09/10/2009 03:25 PM DETAYLOR -----
R425 02	9/14/09	DT	FOUR TRADE ROUGH IN VRU #: 001820463
	9/14/09	AP	
I129 01	9/16/09	DT	R*INSULATION INSPECTION VRU #: 001821669
	9/16/09	AP	
H824 01	10/15/09	BM	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001837897
	10/15/09	AP	T/S: 10/16/2009 10:37 AM SSTEWARD ----- T/S: 10/16/2009 10:38 AM SSTEWARD -----
R329 01	12/03/09	TI	THREE TRADE FINAL VRU #: 001857135
	12/02/09	CA	T/S: 12/02/2009 02:06 PM NTART -----
R429 01	12/03/09	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 001857309
	12/3/09	DP DT	T/S: 12/02/2009 02:07 PM NTART -----

COMMENTS AND NOTES



12/03/2009 11:17:53 AM

Application number, type 09 50022342 CP NEW RESIDENTIAL (SFD)
Property address 407 BASKET OAK DR

- 1. Repair sheetrock at door frames.
 - 2. No ladder to access attic.
 - 3. Toilets not caulked.
 - 4. Rear steps missing.
- House not ready, \$50.00 re-inspection fee.
T/S: 12/03/2009 11:14 AM DETAYLOR -----



OK Exit Cancel Copy Insert Delete Time stamp User defaults

ADDRESS : 407 BASKET OAK DR SUBDIV: FOREST OAKS PH 3 99LOTS
 CONTRACTOR : H & H CONSTRUCTORS INC PHONE : (910) 486-4864
 OWNER : H & H CONSTRUCTORS INC PHONE : (910) 486-4864
 PARCEL : 01-0536-05- -0028- -23-
 APPL NUMBER: 09-50022342 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : FOREST OAKS SUB DIV PH 3 LOT #136,
 BASKET OAK DRIVE. 27W TO NURSERY RD,
 LEFT ON LEMUEL BLACK RD, LEFT ON VALLEY
 OAK DRIVE, INTO FOREST OAKS SUB DIV,
 BASKET OAK DRIVE #136.
 T/S: 06/25/2009 09:09 AM VBROWN ----

STRUCTURE: 000 000 50X59 3BDR 2BATH WITH GAR, DECK, SLAB
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/27/09	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001800010
	7/27/09	AP	
A814 01	7/28/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001801190
	8/05/09	AP	✓ 407 BASKET OAK DR LOT 136 ----- BUNNLEVEL 28323 T/S: 08/05/2009 01:31 PM TWARD -----
B103 01	7/29/09	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001801208
	7/29/09	AP	
P309 01	8/06/09	DT	R*PLUMB UNDER SLAB VRU #: 001805175
	8/06/09	AP	
B111 01	8/11/09	JH	R*BLDG SLAB INSP VRU #: 001806801
	8/11/09	CA	per John11/2009 02:07 PM JHALL ----- T/S: 08/12/2009 07:18 AM JHALL -----
B111 02	8/13/09	DT	R*BLDG SLAB INSP VRU #: 001808377
	8/13/09	AP	
R425 01	9/10/09	DT	FOUR TRADE ROUGH IN VRU #: 001819275
	9/10/09	DA	1. BO3 truss not strapped enough at joint O 2. Missing foundation bolts at garage and front bedroom. T/S: 09/10/2009 03:25 PM DETAYLOR -----
R425 02	9/14/09	DT	FOUR TRADE ROUGH IN VRU #: 001820463
	9/14/09	AP	
I129 01	9/16/09	DT	R*INSULATION INSPECTION VRU #: 001821669
	9/16/09	AP	
H824 01	10/15/09	BM	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001837897
	10/15/09	AP	T/S: 10/16/2009 10:37 AM SSTEWARD ----- T/S: 10/16/2009 10:38 AM SSTEWARD -----
R329 01	12/03/09	TI	THREE TRADE FINAL VRU #: 001857135
	12/02/09	CA	T/S: 12/02/2009 02:06 PM NTART -----
R429 01	12/03/09	DT	FOUR TRADE FINAL TIME: 17:00 VRU #: 001857309
	12/03/09	DP	T/S: 12/02/2009 02:07 PM NTART ----- 1. Repair sheetrock at door frames. 2. No ladder to access attic. 3. Toilets not caulked. 4. Rear steps missing. House not ready, \$50.00 re-inspection fee.

ADDRESS . . : 407 BASKET OAK DR
CONTRACTOR : H & H CONSTRUCTORS INC
OWNER . . . : H & H CONSTRUCTORS INC
PARCEL . . . : 01-0536-05- -0028- -23-
APPL NUMBER: 09-50022342 CP NEW RESIDENTIAL (SFD)

SUBDIV: FOREST OAKS PH 3 99LOTS
PHONE : (910) 486-4864
PHONE : (910) 486-4864

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R429 02	12/11/09 <u>12/11/09</u>	TI <u>AP DT</u>	T/S: 12/03/2009 11:14 AM DETAYLOR ----- FOUR TRADE FINAL TIME: 17:00 VRU #: 001860287 T/S: 12/10/2009 08:47 AM VBROWN -----

----- COMMENTS AND NOTES -----

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: Residential

Owner: H&H Construction

911 Address: 707 Basket Oak Dr
Bunnlevel

State: NC Zip Code: 28323

Date: 12/11/09

D-ETC
Building Official

PERMIT NUMBERS

Building Permit No.: _____

Electrical Permit No.: _____

Insulation Permit No.: _____

Plumbing Permit No.: _____

Mech. Permit No.: 09-50022342

MFG. Home: _____