## Harmen County Department of Public mealth

## **Improvement Permit**

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: Hwy27W ISSUED TO: AMERICAN HOMESMITH SUBDIVISION TIMEEN POINTE LOT # 77 Type of Structure: SED (45 × 49) Site Improvements required prior to Construction Authorization Issuance: Proposed Wastewater System Type: Pume To 25% REDUCTION SYSTEM Projected Daily Flow: 360 GPD Number of bedrooms: 3 Number of Occupants: 6 Basement Yes Pump Required: Yes ☐ No ☐ May be required based on final location and elevations of facilities Type of Water Supply: 

Community Public 

Well Distance from well 100 feet Five years Permit valid for: Permit conditions: ■ No expiration REHS Authorized State Agent:: SEE ATTACHED SITE SKETCH The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: AMERICAN HOMESMITH PROPERTY LOCATION: HWYSTN SUBDIVISION TIMEEN POINTE Facility Type: SFD (45 × 44)

New | Expansion | Repair

Basement? | Yes | No Basement Fixtures? | Yes | Xho

Type of Wastewater System\*\* | Pume To D. 20 | REDUCTOR SYSTEM (Initial) Wastewater Flow: 360 (See note below, if applicable 

) PUMETO CON. W PRETRUATMENT (Repair) Installation Requirements/Conditions Exact length of each trench 260 feet Septic Tank Size 1000 gallons Trench Spacing: Pump Tank Size 1000 gallons Trenches shall be installed on contour at a Maximum Trench Depth of: 18 (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: \_\_\_\_\_ ft. TDH vs. inches below pipe Aggregate Depth: \_\_\_\_\_ inches above pipe Conditions: THIS PEAN IT BASED ON PROPOSAL FROM APPLICANT L.S.S. WATER LINE MUST BE inches total 10' FROM SECTIC SYSTEM. NO UTILITIES MAY ENCROPPY ON INITIAL OF REPAIR AREAS \*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. Date: 10/12/09 Authorized State Agent: Construction Authorization Expiration Date: 10 24

## Harnett County Department of Public Health Site Sketch

ISSUED TO: AMERICAN HOMESMITH	PROPERTY LOCATON: HWY 27 W SUBDIVISION TINGEN POINTE	LOT # <u>77</u>
add the	REHS (DIVER TOLKSOOF) Date: 10 12/09	
365	PUMP TO  CONVENTIONAL  PRETREATMENT  OPEN SPACE WETLAND PRESERVATION  EASEMENT  INCLUDES DECX  OTILITY EASEMENT  V	
OMAHA DRIVE		