HTE# REPAIR

...arnett County Department of Public Health

29148

PAGE 1 00 ?

Improvement Permit A building permit cannot be issued with only an Improvement Permit ISSUED TO: PROPERTY LOCATION: NEW REPAIR SUBDIVISION EXPANSION Type of Structure: Site Improvements required prior to Construction Authorization Issuance: Proposed Wastewater System Type: Projected Daily Flow: GPD Number of bedrooms: Number of Occupants: _____max Pump Required: □Yes ☐ No \square May be required based on final location and elevations of facilities Type of Water Supply:

Community Public Well Distance from well feet Permit valid for: ☐ Five years ☐ No expiration Authorized State Agent:: The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of Construction Authorization The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958. and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance ISSUED TO: ZACHARY ABOOD PROPERTY LOCATION: 518 OMAHA DR.
SUBDIVISION TIMEEN POINT LOT # 81 Basement? Yes No Basement Fixtures? Yes No Type of Wastewater System** (See note below, if applicable []) (Initial) Wastewater Flow: 360 GPD Pume To Low PROFILE CHAMBER(Repair) Installation Requirements/Conditions Number of trenches 1 Septic Tank Size Existing gallons Exact length of each trench 415 feet Pump Tank Size Existing gallons Trenches shall be installed on contour at a Trench Spacing: Soil Cover: Maximum Trench Depth of: 12 (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) Pump Requirements: _____ft. TDH vs. _____ GPM in all directions) Conditions: PERMIT BASED ON PROPOSAL FROM APPLICANTS _____ inches below pipe Aggregate Depth: ______ inches above pipe WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. inches total NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. **|f applicable: | understand the system type specified is different from the type specified on the application. | accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH Authorized State Agent: _

Construction Authorization Expiration Date: 2/2/22

PROPOSED SU	JBSURFACE WASTE DISPOS	SAL SYSTEM DETA	IL SHEET (REPAIR SYSTEM)	
	TINGEN POINT		LOT 8 (
	EM: APPROVED 25% RECUC	TION 🕌	PREPAIR: LOW PROFICE CHAMBE	B
			DISTRIBUTION SERIAL	-P3 F3
DISTRIBUTION:				
BENCHMARK	: 100.0		LOCATION	
NO. BEDROO	MS: 3		LTAR 0.3 6P0 / FT2	-
LINE	FLAG COLOR	ELEVATION	LENGTH	
				-
	P	98.42	65°	
3	<u> </u>	97.75	50	-
4	В	96.25	25:"	-
5	P	95.50	70′	
6	B	94.42	50'	-
		94.34	415'	
				n 10°9
BY M. EAKER		DATE 0//201:7	-	
TYPICAL PROFILE		THERE SHALL BE NO GRADING		
0-10 L3 (VF, mg.)		RUTTING CUTTING OR OTHER SOIL		
10-24 SCC (Fo/F: , shk)			DISTURBANCE IN SEPTIC AREA	
cil/2m e 24" or greater		le-	ANY DISTURBANCE MAY CAUSE A SITE	
ISE LOW PROFILE INSTANTED ATT 12"			TO BECOME UNSUITABLE	
5	7-71-6		OPIGINAL SYSTEM WAS	cu

INSTAULATION

JUNGEMENT FOR WORKING

SYSTEM

Harnett County GIS

