

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: D Walsh Construction
NEW [x] REPAIR [] EXPANSION []
Type of Structure: SFD 40' x 38'
Proposed Wastewater System Type: Conventional
Projected Daily Flow: 360 GPD
Number of bedrooms: 3 Number of Occupants: 6 max
Basement [] Yes [x] No
Pump Required: [] Yes [x] No [] May be required based on final location and elevations of facilities
Type of Water Supply: [] Community [x] Public [] Well Distance from well _____ feet
Permit conditions: _____

PROPERTY LOCATION: SR 1139 Tingen Rd.
SUBDIVISION Tingen Place LOT # 35
Site Improvements required prior to Construction Authorization Issuance: _____

Permit valid for: [x] Five years [] No expiration

Authorized State Agent: Ryan McSwain, E.S. Date: 7/8/2009 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: D Walsh Construction

PROPERTY LOCATION: SR 1139
SUBDIVISION Tingen Place LOT # 35

Facility Type: SFD [x] New [] Expansion [] Repair
Basement? [] Yes [x] No Basement Fixtures? [] Yes [] No

Type of Wastewater System** Conventional (Initial) Wastewater Flow: 360 GPD
(See note below, if applicable [])

Installation Requirements/Conditions

Septic Tank Size 1000 gallons Number of trenches 1
Exact length of each trench 200 feet Trench Spacing: 9 Feet on Center
Pump Tank Size _____ gallons Trenches shall be installed on contour at a Soil Cover: 12-18 inches
Maximum Trench Depth of: 24.30 inches (Maximum soil cover shall not exceed 36" above the trench bottom)
(Trench bottoms shall be level to +/- 1/4" in all directions)

Pump Requirements: _____ ft. TDH vs. _____ GPM Aggregate Depth: 6 inches below pipe 2 inches above pipe 12 inches total
Conditions: Run drian lines on contour, Step downs may be avoided by utilizing ditch depths.

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: Ryan McSwain, E.S. Date: 7/8/2009
Construction Authorization Expiration Date: 7/8/2014

HTE# 09-5-22382

Permit # 25288

Harnett County Department of Public Health Site Sketch

ISSUED TO: D Walsh Construction PROPERTY LOCATOR: SR 439, Tingen Rd.
SUBDIVISION Tingen Place LOT # 35

Authorized State Agent: Bryan McSwain, L.S. Date: 7/8/2009

