HE# 09-5-22398

Harnett County Department of Public Health

25554

Improvement Permit A building permit cannot be issued with only an Improvement Permit

ISSUED TO: KEMMETH CUMMINGS PROPERTY LOCATION: LEMUEL BLACK ROSUBDIVISION MODOSHIZE NEW 🔀 Site Improvements required prior to Construction Authorization Issuance: Type of Structure: SFD (57 7347) Proposed Wastewater System Type: Convertional Projected Daily Flow: 360 GPD Number of bedrooms: 3 Number of Occupants: 6 max Basement Yes No Pump Required: Tes No May be required based on final location and elevations of facilities Type of Water Supply:
Community Public Well Distance from well 100 feet Five years Permit valid for: Permit conditions: ☐ No expiration The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. **Construction Authorization** (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958. and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: KEMMETH CUMMINGS PROPERTY LOCATION: LETTEL BLACK RD SUBDIVISION WOODSHIRE LOT # 1779 Facility Type: SFO(57 X347) | New | Expansion | Repair Basement? ☐ Yes ☑ No Basement Fixtures? ☐ Yes ☒ No Basement Fixtures?
Yes KNo

CONVENTION BL (Initial) Wastewater Flow: 360 GPD Type of Wastewater System** (See note below, if applicable DNYENTWNAL Number of trenches 4 Installation Requirements/Conditions Septic Tank Size 1000 gallons Exact length of each trench _50 feet Trench Spacing: Feet on Center Pump Tank Size gallons Trenches shall be installed on contour at a Soil Cover: 12-24 inches Maximum Trench Depth of: 24-36 inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) inches below pipe inches above pipe Pump Requirements: ______ft. TDH vs. _____ GPM **If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH Authorized State Agent: Construction Authorization Expiration Date: 79

HTE#	09-5-27395	δ

Permit # __ 25554

Harnett County Department of Public Health Site Sketch

Authorized State Agent: PROPERTY LOCATON: LEMVEZ BLACK RD

SUBDIVISION WOODSHIRE LOT # 179

Date: 7/9/09

