

-----

ADDRESS . . : 221 KIMBROUGH DR  
 CONTRACTOR : CAVINESS LAND DEVELOPMENT  
 OWNER . . : CAVINESS LAND DEVELOPMENT INC  
 PARCEL . . : 01-0536-06- -0028- -18-  
 APPL NUMBER: 09-50022445 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : WOODSHIRE SUB DIV #178, KIMBROUGH  
 DRIVE. 27W, LEFT ON NURSERY RD, ELFT  
 ON WOOD POINT DR, RIGHT KIMBROUGH  
 DRIVE.  
 T/S: 07/13/2009 09:51 AM VBROWN -----

-----

**STRUCTURE: 000 000 65X50 4BDR 2BATH SFD WITH GAR, DECK, SLAB**  
 FLOOD ZONE . . . . : FLOOD ZONE X  
 # BEDROOMS . . . . . : 4.00  
 SEPTIC - EXISTING? . . . . : NEW SEPTIC

PROPOSED USE . . . . . : SFD  
 WATER SUPPLY . . . . . : COUNTY

-----

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/23/09 <u>9/23/09</u>	TI <u>APDI</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001826206

----- COMMENTS AND NOTES -----

ADDRESS : 221 KIMBROUGH DR  
CONTRACTOR : CAVINESS LAND DEVELOPMENT  
OWNER : CAVINESS LAND DEVELOPMENT INC  
PARCEL : 01-0536-06- -0028- -18-  
APPL NUMBER: 09-50022445 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : WOODSHIRE SUB DIV #178, KIMBROUGH  
DRIVE. 27W, LEFT ON NURSERY RD, ELFT  
ON WOOD POINT DR, RIGHT KIMBROUGH  
DRIVE.  
T/S: 07/13/2009 09:51 AM VBROWN ----

SUBDIV: WOODSHIRE PH 5  
PHONE : (919) 481-0503  
PHONE :

STRUCTURE: 000 000 65X50 4BDR 2BATH SFD WITH GAR, DECK, SLAB

FLOOD ZONE : FLOOD ZONE X

# BEDROOMS : 4.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW SEPTIC

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/23/09	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001826206
	9/23/09	AP	
B103 01	10/01/09	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001829613

*10-1-09 AP JV T-pole passed*

COMMENTS AND NOTES

-----  
ADDRESS . . : 221 KIMBROUGH DR SUBDIV: WOODSHIRE PH 5  
CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503  
OWNER . . . : CAVINESS LAND DEVELOPMENT INC PHONE :  
PARCEL . . . : 01-0536-06- -0028- -18-  
APPL NUMBER: 09-50022445 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : WOODSHIRE SUB DIV #178, KIMBROUGH  
DRIVE. 27W, LEFT ON NURSERY RD, ELFT  
ON WOOD POINT DR, RIGHT KIMBROUGH  
DRIVE.  
T/S: 07/13/2009 09:51 AM VBROWN ----  
-----

STRUCTURE: 000 000 65X50 4BDR 2BATH SFD WITH GAR, DECK, SLAB  
FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . . : 4.00 PROPOSED USE . . . . . : SFD  
SEPTIC - EXISTING? . . . . : NEW SEPTIC WATER SUPPLY . . . . . : COUNTY  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/23/09 9/23/09	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001826206
B103 01	10/01/09 10/01/09	JH AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001829613 t-pole passed-----
A814 01	10/02/09 10/02/09	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001828473 221 kimbrough dr lot 178 ----- lillington, nc 27546 T/S: 10/02/2009 11:17 AM TWARD -----
P309 01	10/13/09 <u>10/13/09</u>	TI <u>AP DT</u>	R*PLUMB UNDER SLAB VRU #: 001835303

----- COMMENTS AND NOTES -----

-----

ADDRESS . . : 221 KIMBROUGH DR SUBDIV: WOODSHIRE PH 5  
 CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503  
 OWNER . . : CAVINESS LAND DEVELOPMENT INC PHONE :  
 PARCEL . . : 01-0536-06- -0028- -18-  
 APPL NUMBER: 09-50022445 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : WOODSHIRE SUB DIV #178, KIMBROUGH  
 DRIVE. 27W, LEFT ON NURSERY RD, ELFT  
 ON WOOD POINT DR, RIGHT KIMBROUGH  
 DRIVE.  
 T/S: 07/13/2009 09:51 AM VBROWN ----

-----

**STRUCTURE: 000 000 65X50 4BDR 2BATH SFD WITH GAR, DECK, SLAB**

FLOOD ZONE . . . . : FLOOD ZONE X  
 # BEDROOMS . . . . : 4.00 PROPOSED USE . . . . . : SFD  
 SEPTIC - EXISTING? . . . . : NEW SEPTIC WATER SUPPLY . . . . . : COUNTY

-----

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/23/09 9/23/09	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001826206
B103 01	10/01/09 10/01/09	JH AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001829613 t-pole
A814 01	10/02/09 10/02/09	TW AP	passed----- ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001828473 221 kimbrough dr lot 178 ----- lillington, nc 27546 T/S: 10/02/2009 11:17 AM TWARD -----
P309 01	10/13/09 10/13/09	DT AP	R*PLUMB UNDER SLAB VRU #: 001835303
B111 01	10/15/09 10/15/09	DT CA	R*BLDG SLAB INSP VRU #: 001836712
B111 02	10/19/09	TI	R*BLDG SLAB INSP VRU #: 001837935

10.19.09 AP-MR

----- COMMENTS AND NOTES -----

ADDRESS : 221 KIMBROUGH DR SUBDIV: WOODSHIRE PH 5  
 CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503  
 OWNER : CAVINESS LAND DEVELOPMENT INC PHONE :  
 PARCEL : 01-0536-06- -0028- -18-  
 APPL NUMBER: 09-50022445 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : WOODSHIRE SUB DIV #178, KIMBROUGH  
 DRIVE. 27W, LEFT ON NURSERY RD, ELFT  
 ON WOOD POINT DR, RIGHT KIMBROUGH  
 DRIVE.  
 T/S: 07/13/2009 09:51 AM VBROWN ----

**STRUCTURE: 000 000 65X50 4BDR 2BATH SFD WITH GAR, DECK, SLAB**  
 FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 4.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/23/09 9/23/09	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001826206
B103 01	10/01/09 10/01/09	JH AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001829613 t-pole passed-----
A814 01	10/02/09 10/02/09	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001828473 221 kimbrough dr lot 178 ----- lillington, nc 27546 T/S: 10/02/2009 11:17 AM TWARD -----
P309 01	10/13/09 10/13/09	DT AP	R*PLUMB UNDER SLAB VRU #: 001835303
B111 01	10/15/09 10/15/09	DT CA	R*BLDG SLAB INSP VRU #: 001836712
B111 02	10/19/09 10/19/09	MR AE	R*BLDG SLAB INSP VRU #: 001837935 damp proofing required vby open floorT/S: 10/19/2009 11:07 AM MREARIC -----
R425 01	11/10/09 <u>11-10</u>	TI <u>DA</u>	FOUR TRADE ROUGH IN VRU #: 001848594

COMMENTS AND NOTES

ADDRESS : 221 KIMBROUGH DR SUBDIV: WOODSHIRE PH 5  
 CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503  
 OWNER : CAVINESS LAND DEVELOPMENT INC PHONE :  
 PARCEL : 01-0536-06- -0028- -18-  
 APPL NUMBER: 09-50022445 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : WOODSHIRE SUB DIV #178, KIMBROUGH  
 DRIVE. 27W, LEFT ON NURSERY RD, ELFT  
 ON WOOD POINT DR, RIGHT KIMBROUGH  
 DRIVE.  
 T/S: 07/13/2009 09:51 AM VBROWN ----

STRUCTURE: 000 000 65X50 4BDR 2BATH SFD WITH GAR, DECK, SLAB  
 FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 4.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/23/09 9/23/09	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001826206
B103 01	10/01/09 10/01/09	JH AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001829613 t-pole
A814 01	10/02/09 10/02/09	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001828473 221 kimbrough dr lot 178 lillington, nc 27546 T/S: 10/02/2009 11:17 AM TWARD -----
P309 01	10/13/09 10/13/09	DT AP	R*PLUMB UNDER SLAB VRU #: 001835303
B111 01	10/15/09 10/15/09	DT CA	R*BLDG SLAB INSP VRU #: 001836712
B111 02	10/19/09 10/19/09	MR AE	R*BLDG SLAB INSP VRU #: 001837935 damp proofing required vby open floor T/S: 10/19/2009 11:07 AM MREARIC -----
R425 01	11/10/09 11/10/09	KS DA	FOUR TRADE ROUGH IN VRU #: 001848594 1. Insulation baffles shall be installed for rough-in 2. Plan calls for ladder framing between stair trusses 16 inches on center. 3. Plan calls for lvl across back door--not there 4. Front bedroom wall engineer called for balloon framing 12 inch on center. Do not insulate Ok to side T/S: 11/10/2009 01:43 PM KSLATTUM -----
R425 02	11/12/09 <u>11/12/09</u>	TI <u>AR DT</u>	FOUR TRADE ROUGH IN VRU #: 001849557

COMMENTS AND NOTES

ADDRESS : 221 KIMBROUGH DR SUBDIV: WOODSHIRE PH 5  
CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503  
OWNER : CAVINESS LAND DEVELOPMENT INC PHONE :  
PARCEL : 01-0536-06- -0028- -18-  
APPL NUMBER: 09-50022445 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : WOODSHIRE SUB DIV #178, KIMBROUGH  
DRIVE. 27W, LEFT ON NURSERY RD, ELFT  
ON WOOD POINT DR, RIGHT KIMBROUGH  
DRIVE.  
T/S: 07/13/2009 09:51 AM VBROWN ----

STRUCTURE: 000 000 65X50 4BDR 2BATH SFD WITH GAR, DECK, SLAB  
FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 4.00 PROPOSED USE : SFD  
SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/23/09	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001826206
	9/23/09	AP	
B103 01	10/01/09	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001829613
	10/01/09	AP	t-pole passed-----
A814 01	10/02/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001828473
	10/02/09	AP	221 kimbrough dr lot 178 lillington, nc 27546 T/S: 10/02/2009 11:17 AM TWARD -----
P309 01	10/13/09	DT	R*PLUMB UNDER SLAB VRU #: 001835303
	10/13/09	AP	
B111 01	10/15/09	DT	R*BLDG SLAB INSP VRU #: 001836712
	10/15/09	CA	
B111 02	10/19/09	MR	R*BLDG SLAB INSP VRU #: 001837935
	10/19/09	AE	damp proofing required vby open floorT/S: 10/19/2009 11:07 AM MREARIC -----
R425 01	11/10/09	KS	FOUR TRADE ROUGH IN VRU #: 001848594
	11/10/09	DA	1. Insulation baffles shall be installed for rough-in 2. Plan calls for ladder framing between stair trusses 16 inches on center. 3. Plan calls for lvl across back door--not there 4. Front bedroom wall engineer called for balloon framing 12 inch on center. Do not insulate Ok to side T/S: 11/10/2009 01:43 PM KSLATTUM -----
R425 02	11/12/09	TI	FOUR TRADE ROUGH IN VRU #: 001849557
I129 01	11/16/09	TI	R*INSULATION INSPECTION VRU #: 001850223
	11-16-9	DA MR	

COMMENTS AND NOTES

NO INS behind Shower or tubs  
water pipe ins outside walls  
Access MBR

Field notes  
Show Dean signed off on 11-12-9

ADDRESS : 221 KIMBROUGH DR SUBDIV: WOODSHIRE PH 5  
 CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503  
 OWNER : CAVINESS LAND DEVELOPMENT INC PHONE :  
 PARCEL : 01-0536-06- -0028- -18-  
 APPL NUMBER: 09-50022445 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : WOODSHIRE SUB DIV #178, KIMBROUGH  
 DRIVE. 27W, LEFT ON NURSERY RD, ELFT  
 ON WOOD POINT DR, RIGHT KIMBROUGH  
 DRIVE.  
 T/S: 07/13/2009 09:51 AM VBROWN ----

STRUCTURE: 000 000 65X50 4BDR 2BATH SFD WITH GAR, DECK, SLAB  
 FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 4.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/23/09 9/23/09	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001826206
B103 01	10/01/09 10/01/09	JH AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001829613 t-pole passed-----
A814 01	10/02/09 10/02/09	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001828473 221 kimbrough dr lot 178 ----- lillington, nc 27546 T/S: 10/02/2009 11:17 AM TWARD -----
P309 01	10/13/09 10/13/09	DT AP	R*PLUMB UNDER SLAB VRU #: 001835303
B111 01	10/15/09 10/15/09	DT CA	R*BLDG SLAB INSP VRU #: 001836712
B111 02	10/19/09 10/19/09	MR AE	R*BLDG SLAB INSP VRU #: 001837935 damp proofing required vby open floorT/S: 10/19/2009 11:07 AM MREARIC -----
R425 01	11/10/09 11/10/09	KS DA	FOUR TRADE ROUGH IN VRU #: 001848594 1. Insulation baffles shall be installed for rough-in 2. Plan calls for ladder framing between stair trusses 16 inches on center. 3. Plan calls for lvl across back door--not there 4. Front bedroom wall engineer called for balloon framing 12 inch on center. Do not insulate Ok to side T/S: 11/10/2009 01:43 PM KSLATTUM -----
R425 02	11/12/09 <u>11/12/09</u>	TI <u>AP DT</u>	FOUR TRADE ROUGH IN VRU #: 001849557
I129 01	11/16/09 11/16/09	MR DA	R*INSULATION INSPECTION VRU #: 001850223 T/S: 11/16/2009 11:26 AM MREARIC ----- insulation is not done behind tubs and showers water pipes are on outside of envelope no visible access to attic areas
I129 02	11/17/09 <u>11/17/09</u>	TI <u>AP DT</u>	R*INSULATION INSPECTION VRU #: 001851099



-----  
ADDRESS : 221 KIMBROUGH DR SUBDIV: WOODSHIRE PH 5  
CONTRACTOR: CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503  
OWNER : CAVINESS LAND DEVELOPMENT INC PHONE :  
PARCEL : 01-0536-06- -0028- -18-  
APPL NUMBER: 09-50022445 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : WOODSHIRE SUB DIV #178, KIMBROUGH  
DRIVE. 27W, LEFT ON NURSERY RD, ELFT  
ON WOOD POINT DR, RIGHT KIMBROUGH  
DRIVE.  
T/S: 07/13/2009 09:51 AM VBROWN ----  
-----

STRUCTURE: 000 000 65X50 4BDR 2BATH SFD WITH GAR,DECK,SLAB  
FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 4.00 PROPOSED USE : SFD  
SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/23/09 9/23/09	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001826206
B103 01	10/01/09 10/01/09	JH AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001829613 t-pole passed-----
A814 01	10/02/09 10/02/09	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001828473 ✓ 221 kimbrough dr lot 178 ----- lillington, nc 27546 T/S: 10/02/2009 11:17 AM TWARD -----
P309 01	10/13/09 10/13/09	DT AP	R*PLUMB UNDER SLAB VRU #: 001835303
B111 01	10/15/09 10/15/09	DT CA	R*BLDG SLAB INSP VRU #: 001836712
B111 02	10/19/09 10/19/09	MR AE	R*BLDG SLAB INSP VRU #: 001837935 damp proofing required vby open floorT/S: 10/19/2009 11:07 AM MREARIC -----
R425 01	11/10/09 11/10/09	KS DA	FOUR TRADE ROUGH IN VRU #: 001848594 1. Insulation baffles shall be installed for rough-in 2. Plan calls for ladder framing between stair trusses 16 inches on center. 3. Plan calls for lvl across back door--not there 4. Front bedroom wall engineer called for balloon framing 12 inch on center. Do not insulate Ok to side T/S: 11/10/2009 01:43 PM KSLATTUM -----
R425 02	11/12/09 11/18/09	DT AP	FOUR TRADE ROUGH IN VRU #: 001849557
I129 01	11/16/09 11/16/09	MR DA	R*INSULATION INSPECTION VRU #: 001850223 T/S: 11/16/2009 11:26 AM MREARIC ----- insulation is not done behind tubs and showers water pipes are on outside of envelope no visible access to attic areas
I129 02	11/17/09 11/17/09	DT AP	R*INSULATION INSPECTION VRU #: 001851099
H824 01	1/07/10	BM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001868488

ADDRESS : 221 KIMBROUGH DR  
CONTRACTOR,: CAVINESS LAND DEVELOPMENT  
OWNER . . : CAVINESS LAND DEVELOPMENT INC  
PARCEL . . : 01-0536-06- -0028- -18-  
APPL NUMBER: 09-50022445 CP NEW RESIDENTIAL (SFD)

SUBDIV: WOODSHIRE PH 5  
PHONE : (919) 481-0503  
PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
	1/07/10	DA	PER BRYAN MCSWAIN NEEDS TANK, PUMP, ALARM, D-BOX AND WATERLINE CHECKED BEFORE FINAL CAN BE ISSUED. T/S: 01/07/2010 09:46 AM SSTEWARD ----- T/S: 01/07/2010 09:48 AM SSTEWARD -----
H824 02	1/19/10	BM	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001873728
	1/19/10	AP	T/S: 01/20/2010 11:01 AM SSTEWARD ----- T/S: 01/20/2010 11:02 AM SSTEWARD -----
R429 01	3/09/10 <u>2/9/10</u>	TI <u>DA DT</u>	FOUR TRADE FINAL VRU #: 001892367

----- COMMENTS AND NOTES -----

ADDRESS : 221 KIMBROUGH DR SUBDIV: WOODSHIRE PH 5  
 CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503  
 OWNER : CAVINESS LAND DEVELOPMENT INC PHONE :  
 PARCEL : 01-0536-06- -0028- -18-  
 APPL NUMBER: 09-50022445 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : WOODSHIRE SUB DIV #178, KIMBROUGH  
 DRIVE. 27W, LEFT ON NURSERY RD, ELFT  
 ON WOOD POINT DR, RIGHT KIMBROUGH  
 DRIVE.  
 T/S: 07/13/2009 09:51 AM VBROWN ----

**STRUCTURE: 000 000 65X50 4BDR 2BATH SFD WITH GAR, DECK, SLAB**

FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 4.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/23/09 9/23/09	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001826206
B103 01	10/01/09 10/01/09	JH AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001829613 t-pole
A814 01	10/02/09 10/02/09	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001828473 ✓ 221 kimbrough dr lot 178 lillington, nc 27546 T/S: 10/02/2009 11:17 AM TWARD ----- passed-----
P309 01	10/13/09 10/13/09	DT AP	R*PLUMB UNDER SLAB VRU #: 001835303
B111 01	10/15/09 10/15/09	DT CA	R*BLDG SLAB INSP VRU #: 001836712
B111 02	10/19/09 10/19/09	MR AE	R*BLDG SLAB INSP VRU #: 001837935 damp proofing required vby open floor T/S: 10/19/2009 11:07 AM MREARIC -----
R425 01	11/10/09 11/10/09	KS DA	FOUR TRADE ROUGH IN VRU #: 001848594 1. Insulation baffles shall be installed for rough-in 2. Plan calls for ladder framing between stair trusses 16 inches on center. 3. Plan calls for lvl across back door--not there 4. Front bedroom wall engineer called for balloon framing 12 inch on center. Do not insulate Ok to side T/S: 11/10/2009 01:43 PM KSLATTUM -----
R425 02	11/12/09 11/18/09	DT AP	FOUR TRADE ROUGH IN VRU #: 001849557
I129 01	11/16/09 11/16/09	MR DA	R*INSULATION INSPECTION VRU #: 001850223 T/S: 11/16/2009 11:26 AM MREARIC ----- insulation is not done behind tubs and showers water pipes are on outside of envelope no visible access to attic areas
I129 02	11/17/09 11/17/09	DT AP	R*INSULATION INSPECTION VRU #: 001851099
H824 01	1/07/10	BM	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001868488

ADDRESS : 221 KIMBROUGH DR SUBDIV: WOODSHIRE PH 5  
CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503  
OWNER : CAVINESS LAND DEVELOPMENT INC PHONE :  
PARCEL : 01-0536-06- -0028- -18-  
APPL NUMBER: 09-50022445 CP NEW RESIDENTIAL (SFD)

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
	1/07/10	DA	PER BRYAN MCSWAIN NEEDS TANK, PUMP, ALARM, D-BOX AND WATERLINE CHECKED BEFORE FINAL CAN BE ISSUED. T/S: 01/07/2010 09:46 AM SSTEWARD ----- T/S: 01/07/2010 09:48 AM SSTEWARD -----
H824 02	1/19/10	BM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001873728
	1/19/10	AP	T/S: 01/20/2010 11:01 AM SSTEWARD ----- T/S: 01/20/2010 11:02 AM SSTEWARD -----
R429 01	3/09/10	DT	FOUR TRADE FINAL VRU #: 001892367
	3/09/10	DA	1. No smoke detector outside of upstairs bedroom. 2. Exhaust fan for downstairs spare bath not vented to outside 3. Need 10 inches settled depth for blown insulation. Need depth guage visible every 300 sq ft. T/S: 03/09/2010 01:31 PM DETAYLOR-----
R429 02	3/11/10	TI	FOUR TRADE FINAL VRU #: 001893339
	<u>3/11/10</u>	<u>AP DT</u>	

----- COMMENTS AND NOTES -----

County of Harnett  
Building Inspections Department  
Planning Services

Certificate of Compliance: \_\_\_\_\_ Occupancy: ✓

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential  
Name: Caviness Land Development

Address: 221 Kimbrough Dr  
Lillington, NC 27546

Date: 3/11/10

Building Official: [Signature]

Permit Numbers

Building: \_\_\_\_\_  
Electrical: \_\_\_\_\_  
Insulation: \_\_\_\_\_  
Plumbing: \_\_\_\_\_  
Mechanical: 09-50022445  
MFG Home: \_\_\_\_\_