

HTE# 09-5-22445RR

Harnett County Department of Public Health

25810

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Cariners Land Development PROPERTY LOCATION: Norsury Rd.
NEW REPAIR EXPANSION SUBDIVISION Woodshire LOT # 178

Type of Structure: SFD Site Improvements required prior to Construction Authorization Issuance:

Proposed Wastewater System Type: Pump to 25% Reduction System
Projected Daily Flow: 360 GPD

Number of bedrooms: 3 Number of Occupants: 6 max
Basement Yes No

Pump Required: Yes No May be required based on final location and elevations of facilities
Type of Water Supply: Community Public Well Distance from well _____ feet Permit valid for: Five years

Permit conditions: _____ No expiration

Authorized State Agent: Bryan McLean REID Date: 12/14/2009 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Cariners Land Development PROPERTY LOCATION: Norsury Rd.
SUBDIVISION Woodshire LOT # 178

Facility Type: SFD New Expansion Repair
Basement? Yes No Basement Fixtures? Yes No

Type of Wastewater System** Pump to 25% Reduction System (Initial) Wastewater Flow: 360 GPD
(See note below, if applicable)

Pump to 25% Reduction System (Repair)

Installation Requirements/Conditions

Septic Tank Size 1000 gallons Number of trenches 1
Pump Tank Size 1000 gallons Exact length of each trench 230 feet Trench Spacing: 9 Feet on Center

Trenches shall be installed on contour at a Maximum Trench Depth of: 18 inches Soil Cover: 6 inches
(Trench bottoms shall be level to +/-1/4" (Maximum soil cover shall not exceed 36" above the trench bottom)

in all directions)

Pump Requirements: _____ ft. TDH vs. _____ GPM _____ inches below pipe
Aggregate Depth: _____ inches above pipe

Conditions: System based on consultants proposal. No utilities
Allowed in System for Repair Areas. Water line must be at least 10ft. from
any part of septic system repair area

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: Bryan McLean REID Date: 12/14/2009

Construction Authorization Expiration Date: 12/14/2009

HTE# 09-5-22445 RR

Permit # 25810

Harnett County Department of Public Health Site Sketch

PROPERTY LOCATOR: Nursery Rd.

ISSUED TO: Carvers Land Development

SUBDIVISION Woodshire

LOT # 178

Authorized State Agent: Guya McSwain, R.E.H.S.

Date: 12/14/2009

* Supply line to be
36 inches deep

