

Harnett County

INSPECTOR: IVR

DATE 10/06/09

-----

ADDRESS . . : 232 KIMBROUGH DR SUBDIV: WOODSHIRE PH 5  
 CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503  
 OWNER . . : CAVINESS LAND DEVELOPMENT INC PHONE :  
 PARCEL . . : 01-0536-06- -0028- -29-  
 APPL NUMBER: 09-50022447 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : WOODSHIRE SUB DIV #189, KIMBROUGH  
 DRIVE. 27W, LEFT ON NURSERY RD, LEFT  
 ON WOOD POINT DR, RIGHT KIMBROUGH DR.  
 T/S: 07/13/2009 12:49 PM VBROWN -----

-----

**STRUCTURE: 000 000 58X48 4BDR 3BATH SFD WITH GAR, DECK, SLAB**  
 FLOOD ZONE . . . . : FLOOD ZONE X  
 # BEDROOMS . . . . . : 4.00 PROPOSED USE . . . . . : SFD  
 SEPTIC - EXISTING? . . . . : NEW SEPTIC WATER SUPPLY . . . . . : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED	INSP	DESCRIPTION
	COMPLETED	RESULT	RESULTS/COMMENTS
B101 01	10/06/09 <u>10/6/09</u>	TI <u>DA DT</u> <u>DT</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001831361

----- COMMENTS AND NOTES -----



-----  
ADDRESS : 232 KIMBROUGH DR  
CONTRACTOR : CAVINESS LAND DEVELOPMENT  
OWNER : CAVINESS LAND DEVELOPMENT INC  
PARCEL : 01-0536-06- -0028- -29-  
APPL NUMBER: 09-50022447 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : WOODSHIRE SUB DIV #189, KIMBROUGH  
DRIVE. 27W, LEFT ON NURSERY RD, LEFT  
ON WOOD POINT DR, RIGHT KIMBROUGH DR.  
T/S: 07/13/2009 12:49 PM VBROWN -----

SUBDIV: WOODSHIRE PH 5  
PHONE : (919) 481-0503  
PHONE :

-----  
**STRUCTURE: 000 000 58X48 4BDR 3BATH SFD WITH GAR, DECK, SLAB**

FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 4.00  
SEPTIC - EXISTING? : NEW SEPTIC  
PROPOSED USE : SFD  
WATER SUPPLY : COUNTY

-----  
**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/06/09 10/06/09	DT DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001831361 Footing not dug T/S: 10/06/2009 12:47 PM DETAYLOR -----
B101 02	10/08/09 10/08/09	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001832903
B103 01	10/16/09 <u>10/16/09</u>	TI <u>AP DT</u>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001837631

-----  
COMMENTS AND NOTES  
-----

ADDRESS : 232 KIMBROUGH DR SUBDIV: WOODSHIRE PH 5  
CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503  
OWNER : CAVINESS LAND DEVELOPMENT INC PHONE :  
PARCEL : 01-0536-06- -0028- -29-  
APPL NUMBER: 09-50022447 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : WOODSHIRE SUB DIV #189, KIMBROUGH  
DRIVE. 27W, LEFT ON NURSERY RD, LEFT  
ON WOOD POINT DR, RIGHT KIMBROUGH DR.  
T/S: 07/13/2009 12:49 PM VBROWN ----

STRUCTURE: 000 000 58X48 4BDR 3BATH SFD WITH GAR, DECK, SLAB  
FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 4.00 PROPOSED USE : SFD  
SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/06/09	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001831361
	10/06/09	DA	Footing not dug T/S: 10/06/2009 12:47 PM DETAYLOR -----
B101 02	10/08/09	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001832903
	10/08/09	AP	
B103 01	10/16/09	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001837631
	10/16/09	AP	
A814 01	10/20/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001836981
	10/22/09	AP	232 kimbrough dr lot 189 ----- T/S: 10/22/2009 04:49 PM TWARD -----
P309 01	10/26/09	TI	R*PLUMB UNDER SLAB VRU #: 001841671
	<u>10/26/09</u>	<u>DA DT</u>	

----- COMMENTS AND NOTES -----

Application number, type	09 50022447 CP NEW RESIDENTIAL (SFD)
Property address	232 KIMBROUGH DR

Drain must be sleeved through foundation wall.  
 T/S: 10/26/2009 11:49 AM DETAYLOR -----



OK Exit Cancel Copy Insert Delete Time stamp User defaults

-----  
ADDRESS . . : 232 KIMBROUGH DR SUBDIV: WOODSHIRE PH 5  
CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503  
OWNER . . . : CAVINESS LAND DEVELOPMENT INC PHONE :  
PARCEL . . . : 01-0536-06- -0028- -29-  
APPL NUMBER: 09-50022447 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : WOODSHIRE SUB DIV #189, KIMBROUGH  
DRIVE. 27W, LEFT ON NURSERY RD, LEFT  
ON WOOD POINT DR, RIGHT KIMBROUGH DR.  
T/S: 07/13/2009 12:49 PM VBROWN ----  
-----

**STRUCTURE: 000 000 58X48 4BDR 3BATH SFD WITH GAR, DECK, SLAB**

FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . : 4.00 PROPOSED USE . . . . . : SFD  
SEPTIC - EXISTING? . . . . : NEW SEPTIC WATER SUPPLY . . . . . : COUNTY  
-----

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/06/09 10/06/09	DT DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001831361 Footing not dug T/S: 10/06/2009 12:47 PM DETAYLOR -----
B101 02	10/08/09 10/08/09	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001832903
B103 01	10/16/09 10/16/09	DT AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001837631
A814 01	10/20/09 10/22/09	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001836981 232 kimbrough dr lot 189 ----- T/S: 10/22/2009 04:49 PM TWARD -----
P309 01	10/26/09 10/26/09	DT DA	R*PLUMB UNDER SLAB VRU #: 001841671 Drain must be sleeved through foundation wall. T/S: 10/26/2009 11:49 AM DETAYLOR -----
P309 02	10/27/09 <u>10/27/09</u>	TI <u>AP DT</u>	R*PLUMB UNDER SLAB VRU #: 001842518
B111 01	11/02/09 <u>11/02/09</u>	TI <u>AP DT</u>	R*BLDG SLAB INSP VRU #: 001844776

----- COMMENTS AND NOTES -----  
-----

-----  
ADDRESS : 232 KIMBROUGH DR SUBDIV: WOODSHIRE PH 5  
CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503  
OWNER : CAVINESS LAND DEVELOPMENT INC PHONE :  
PARCEL : 01-0536-06- -0028- -29-  
APPL NUMBER: 09-50022447 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : WOODSHIRE SUB DIV #189, KIMBROUGH  
DRIVE. 27W, LEFT ON NURSERY RD, LEFT  
ON WOOD POINT DR, RIGHT KIMBROUGH DR.  
T/S: 07/13/2009 12:49 PM VBROWN -----

-----  
STRUCTURE: 000 000 58X48 4BDR 3BATH SFD WITH GAR, DECK, SLAB  
FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 4.00 PROPOSED USE : SFD  
SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/06/09 10/06/09	DT DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001831361 Footing not dug T/S: 10/06/2009 12:47 PM DETAYLOR -----
B101 02	10/08/09 10/08/09	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001832903
B103 01	10/16/09 10/16/09	DT AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001837631
A814 01	10/20/09 10/22/09	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001836981 232 kimbrough dr lot 189 ----- T/S: 10/22/2009 04:49 PM TWARD -----
P309 01	10/26/09 10/26/09	DT DA	R*PLUMB UNDER SLAB VRU #: 001841671 Drain must be sleeved through foundation wall. T/S: 10/26/2009 11:49 AM DETAYLOR -----
P309 02	10/27/09 <u>10/27/09</u>	TI <u>AP DT</u>	R*PLUMB UNDER SLAB VRU #: 001842518
B111 01	11/02/09 11/02/09	DT AP	R*BLDG SLAB INSP VRU #: 001844776
R425 01	11/25/09 <u>11/25</u>	TI <u>DA DT</u>	FOUR TRADE ROUGH IN VRU #: 001855371

----- COMMENTS AND NOTES -----

Application number, type	09 50022447 CP NEW RESIDENTIAL (SFD)
Property address	232 KIMBROUGH DR

1. Fire caulk three inch by fireplace.
  2. Repair holes at upstairs tub.
  3. Fire block top corners of upstairs gables.
  4. Plumbing boots not installed.
- Okay to side.
- T/S: 11/25/2009 10:27 AM DETAYLOR -----





ADDRESS : 232 KIMBROUGH DR SUBDIV: WOODSHIRE PH 5  
 CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503  
 OWNER : CAVINESS LAND DEVELOPMENT INC PHONE :  
 PARCEL : 01-0536-06- -0028- -29-  
 APPL NUMBER: 09-50022447 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : WOODSHIRE SUB DIV #189, KIMBROUGH  
 DRIVE. 27W, LEFT ON NURSERY RD, LEFT  
 ON WOOD POINT DR, RIGHT KIMBROUGH DR.  
 T/S: 07/13/2009 12:49 PM VBROWN ----

STRUCTURE: 000 000 58X48 4BDR 3BATH SFD WITH GAR, DECK, SLAB  
 FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 4.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/06/09 10/06/09	DT DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001831361 Footing not dug T/S: 10/06/2009 12:47 PM DETAYLOR -----
B101 02	10/08/09 10/08/09	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001832903
B103 01	10/16/09 10/16/09	DT AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001837631
A814 01	10/20/09 10/22/09	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001836981 232 kimbrough dr lot 189 ----- T/S: 10/22/2009 04:49 PM TWARD -----
P309 01	10/26/09 10/26/09	DT DA	R*PLUMB UNDER SLAB VRU #: 001841671 Drain must be sleeved through foundation wall. T/S: 10/26/2009 11:49 AM DETAYLOR -----
P309 02	10/27/09 <u>10/27/09</u>	TI <u>AP DT</u>	R*PLUMB UNDER SLAB VRU #: 001842518
B111 01	11/02/09 11/02/09	DT AP	R*BLDG SLAB INSP VRU #: 001844776
R425 01	11/25/09 11/25/09	DT <u>DA</u>	FOUR TRADE ROUGH IN VRU #: 001855371 1. Fire caulk three inch by fireplace. 2. Repair holes at upstairs tub. 3. Fire block top corners of upstairs gables. 4. Plumbing boots not installed. Okay to side. T/S: 11/25/2009 10:27 AM DETAYLOR -----
R425 02	12/02/09 <u>12/02/09</u>	TI <u>AP DT</u>	FOUR TRADE ROUGH IN VRU #: 001856735

COMMENTS AND NOTES

ADDRESS : 232 KIMBROUGH DR SUBDIV: WOODSHIRE PH 5  
 CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503  
 OWNER : CAVINESS LAND DEVELOPMENT INC PHONE :  
 PARCEL : 01-0536-06- -0028- -29-  
 APPL NUMBER: 09-50022447 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : WOODSHIRE SUB DIV #189, KIMBROUGH  
 DRIVE. 27W, LEFT ON NURSERY RD, LEFT  
 ON WOOD POINT DR, RIGHT KIMBROUGH DR.  
 T/S: 07/13/2009 12:49 PM VBROWN ----

STRUCTURE: 000 000 58X48 4BDR 3BATH SFD WITH GAR, DECK, SLAB  
 FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 4.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/06/09 10/06/09	DT DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001831361 Footing not dug T/S: 10/06/2009 12:47 PM DETAYLOR -----
B101 02	10/08/09 10/08/09	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001832903
B103 01	10/16/09 10/16/09	DT AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001837631
A814 01	10/20/09 10/22/09	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001836981 232 kimbrough dr lot 189 ----- T/S: 10/22/2009 04:49 PM TWARD -----
P309 01	10/26/09 10/26/09	DT DA	R*PLUMB UNDER SLAB VRU #: 001841671 Drain must be sleeved through foundation wall. T/S: 10/26/2009 11:49 AM DETAYLOR -----
P309 02	10/27/09 <u>10/27/09</u>	TI <u>AP DT</u>	R*PLUMB UNDER SLAB VRU #: 001842518
B111 01	11/02/09 11/02/09	DT AP	R*BLDG SLAB INSP VRU #: 001844776
R425 01	11/25/09 11/25/09	DT DA	FOUR TRADE ROUGH IN VRU #: 001855371 1. Fire caulk three inch by fireplace. 2. Repair holes at upstairs tub. 3. Fire block top corners of upstairs gables. 4. Plumbing boots not installed. Okay to side. T/S: 11/25/2009 10:27 AM DETAYLOR -----
R425 02	12/02/09 12/02/09	DT AP	FOUR TRADE ROUGH IN VRU #: 001856735
I129 01	12/04/09 <u>12/4/09</u>	TI <u>AP DT</u>	R*INSULATION INSPECTION VRU #: 001857636

COMMENTS AND NOTES

ADDRESS : 232 KIMBROUGH DR SUBDIV: WOODSHIRE PH 5  
 CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503  
 OWNER : CAVINESS LAND DEVELOPMENT INC PHONE :  
 PARCEL : 01-0536-06- -0028- -29-  
 APPL NUMBER: 09-50022447 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : WOODSHIRE SUB DIV #189, KIMBROUGH  
 DRIVE. 27W, LEFT ON NURSERY RD, LEFT  
 ON WOOD POINT DR, RIGHT KIMBROUGH DR.  
 T/S: 07/13/2009 12:49 PM VBROWN ----

STRUCTURE: 000 000 58X48 4BDR 3BATH SFD WITH GAR, DECK, SLAB  
 FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 4.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/06/09	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001831361
	10/06/09	DA	Footing not dug T/S: 10/06/2009 12:47 PM DETAYLOR -----
B101 02	10/08/09	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001832903
	10/08/09	AP	
B103 01	10/16/09	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001837631
	10/16/09	AP	
A814 01	10/20/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001836981
	10/22/09	AP	✓ 232 kimbrough dr lot 189 ----- T/S: 10/22/2009 04:49 PM TWARD -----
P309 01	10/26/09	DT	R*PLUMB UNDER SLAB VRU #: 001841671
	10/26/09	DA	Drain must be sleeved through foundation wall. T/S: 10/26/2009 11:49 AM DETAYLOR -----
P309 02	10/27/09	TI	R*PLUMB UNDER SLAB VRU #: 001842518
	<u>10/27/09</u>	<u>AP DT</u>	
B111 01	11/02/09	DT	R*BLDG SLAB INSP VRU #: 001844776
	11/02/09	AP	
R425 01	11/25/09	DT	FOUR TRADE ROUGH IN VRU #: 001855371
	11/25/09	DA	1. Fire caulk three inch by fireplace. 2. Repair holes at upstairs tub. 3. Fire block top corners of upstairs gables. 4. Plumbing boots not installed. Okay to side. T/S: 11/25/2009 10:27 AM DETAYLOR -----
R425 02	12/02/09	DT	FOUR TRADE ROUGH IN VRU #: 001856735
	12/02/09	AP	
I129 01	12/04/09	DT	R*INSULATION INSPECTION VRU #: 001857636
	12/04/09	AP	
H824 01	1/05/10	BM	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001868546
	1/05/10	AP	T/S: 01/07/2010 10:48 AM SSTEWARD ----- T/S: 01/07/2010 10:48 AM SSTEWARD -----
R429 01	3/09/10	TI	FOUR TRADE FINAL VRU #: 001892385
	<u>3/31/10</u>	<u>DA DT</u>	

COMMENTS AND NOTES

ADDRESS : 232 KIMBROUGH DR SUBDIV: WOODSHIRE PH 5  
 CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503  
 OWNER : CAVINESS LAND DEVELOPMENT INC PHONE :  
 PARCEL : 01-0536-06- -0028- -29-  
 APPL NUMBER: 09-50022447 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : WOODSHIRE SUB DIV #189, KIMBROUGH  
 DRIVE. 27W, LEFT ON NURSERY RD, LEFT  
 ON WOOD POINT DR, RIGHT KIMBROUGH DR.  
 T/S: 07/13/2009 12:49 PM VBROWN ----

STRUCTURE: 000 000 58X48 4BDR 3BATH SFD WITH GAR, DECK, SLAB  
 FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 4.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/06/09 10/06/09	DT DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001831361 Footing not dug T/S: 10/06/2009 12:47 PM DETAYLOR -----
B101 02	10/08/09 10/08/09	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001832903
B103 01	10/16/09 10/16/09	DT AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001837631
A814 01	10/20/09 10/22/09	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001836981 ✓ 232 kimbrough dr lot 189 ----- T/S: 10/22/2009 04:49 PM TWARD -----
P309 01	10/26/09 10/26/09	DT DA	R*PLUMB UNDER SLAB VRU #: 001841671 Drain must be sleeved through foundation wall. T/S: 10/26/2009 11:49 AM DETAYLOR -----
P309 02	10/27/09 3/09/10	DT AP	R*PLUMB UNDER SLAB VRU #: 001842518
B111 01	11/02/09 11/02/09	DT AP	R*BLDG SLAB INSP VRU #: 001844776
R425 01	11/25/09 11/25/09	DT DA	FOUR TRADE ROUGH IN VRU #: 001855371 1. Fire caulk three inch by fireplace. 2. Repair holes at upstairs tub. 3. Fire block top corners of upstairs gables. 4. Plumbing boots not installed. Okay to side. T/S: 11/25/2009 10:27 AM DETAYLOR -----
R425 02	12/02/09 12/02/09	DT AP	FOUR TRADE ROUGH IN VRU #: 001856735
I129 01	12/04/09 12/04/09	DT AP	R*INSULATION INSPECTION VRU #: 001857636
H824 01	1/05/10 1/05/10	BM AP	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001868546 T/S: 01/07/2010 10:48 AM SSTEWARD ----- T/S: 01/07/2010 10:48 AM SSTEWARD -----
R429 01	3/09/10 3/09/10	DT DA	FOUR TRADE FINAL VRU #: 001892385 1. Label a/c units. 2. a/c units on breakers larger than specified. 3. No insulation depth guages visible at rear of house. Install guages and additional insulation if necessary. T/S: 03/09/2010 01:45 PM DETAYLOR -----

PREPARED 3/10/10, 13:58:58  
Harnett County

INSPECTION TICKET  
INSPECTOR: IVR

PAGE 15  
DATE 3/11/10

-----  
ADDRESS . : 232 KIMBROUGH DR  
CONTRACTOR : CAVINESS LAND DEVELOPMENT  
OWNER . . : CAVINESS LAND DEVELOPMENT INC  
PARCEL . . : 01-0536-06- -0028- -29-  
APPL NUMBER: 09-50022447 CP NEW RESIDENTIAL (SFD)

SUBDIV: WOODSHIRE PH 5  
PHONE : (919) 481-0503  
PHONE :

-----  
REQUESTED INSP DESCRIPTION  
TYP/SQ COMPLETED RESULT RESULTS/COMMENTS  
-----  
R429 02 3/11/10 TI FOUR TRADE FINAL VRU #: 001893348  
3/11/10 DA DG

----- COMMENTS AND NOTES -----

ADDRESS : 232 KIMBROUGH DR SUBDIV: WOODSHIRE PH 5  
 CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503  
 OWNER : CAVINESS LAND DEVELOPMENT INC PHONE :  
 PARCEL : 01-0536-06- -0028- -29-  
 APPL NUMBER: 09-50022447 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : WOODSHIRE SUB DIV #189, KIMBROUGH  
 DRIVE. 27W, LEFT ON NURSERY RD, LEFT  
 ON WOOD POINT DR, RIGHT KIMBROUGH DR.  
 T/S: 07/13/2009 12:49 PM VBROWN ----

STRUCTURE: 000 000 58X48 4BDR 3BATH SFD WITH GAR, DECK, SLAB  
 FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 4.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/06/09 10/06/09	DT DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001831361 Footing not dug T/S: 10/06/2009 12:47 PM DETAYLOR -----
B101 02	10/08/09 10/08/09	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001832903
B103 01	10/16/09 10/16/09	DT AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001837631
A814 01	10/20/09 10/22/09	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001836981 ✓ 232 kimbrough dr lot 189 ----- T/S: 10/22/2009 04:49 PM TWARD -----
P309 01	10/26/09 10/26/09	DT DA	R*PLUMB UNDER SLAB VRU #: 001841671 Drain must be sleeved through foundation wall. T/S: 10/26/2009 11:49 AM DETAYLOR -----
P309 02	10/27/09 3/09/10	DT AP	R*PLUMB UNDER SLAB VRU #: 001842518
B111 01	11/02/09 11/02/09	DT AP	R*BLDG SLAB INSP VRU #: 001844776
R425 01	11/25/09 11/25/09	DT DA	FOUR TRADE ROUGH IN VRU #: 001855371 1. Fire caulk three inch by fireplace. 2. Repair holes at upstairs tub. 3. Fire block top corners of upstairs gables. 4. Plumbing boots not installed. Okay to side. T/S: 11/25/2009 10:27 AM DETAYLOR -----
R425 02	12/02/09 12/02/09	DT AP	FOUR TRADE ROUGH IN VRU #: 001856735
I129 01	12/04/09 12/04/09	DT AP	R*INSULATION INSPECTION VRU #: 001857636
H824 01	1/05/10 1/05/10	BM AP	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001868546 T/S: 01/07/2010 10:48 AM SSTEWARD ----- T/S: 01/07/2010 10:48 AM SSTEWARD -----
R429 01	3/09/10 3/09/10	DT DA	FOUR TRADE FINAL VRU #: 001892385 1. Label a/c units. 2. a/c units on breakers larger than specified. 3. No insulation depth guages visible at rear of house. Install guages and additional insulation if necessary. T/S: 03/09/2010 01:45 PM DETAYLOR -----

PREPARED 3/11/10, 14:01:41  
Harnett County

INSPECTION TICKET  
INSPECTOR: IVR

PAGE 17  
DATE 3/12/10

ADDRESS : 232 KIMBROUGH DR  
CONTRACTOR : CAVINESS LAND DEVELOPMENT  
OWNER : CAVINESS LAND DEVELOPMENT INC  
PARCEL : 01-0536-06- -0028- -29-  
APPL NUMBER: 09-50022447 CP NEW RESIDENTIAL (SFD)

SUBDIV: WOODSHIRE PH 5  
PHONE : (919) 481-0503  
PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R429 02	3/11/10 3/11/10	DT DA	FOUR TRADE FINAL VRU #: 001893348 Need access to jacuzzi tube in master. T/S: 03/11/2010 10:55 AM DETAYLOR
R429 03	3/12/10 <u>3-12</u>	TI <u>DP</u>	FOUR TRADE FINAL VRU #: 001894276

----- COMMENTS AND NOTES -----

**Violation Notice  
Do Not Remove**

**Harnett County Inspection Department  
102 East Front St P.O. Box 65  
Lillington, NC 27546  
Phone (910) 893-7525 Fax (910) 893-2793**

09-50022447

March 12, 2010

**Tile removed does not meet the required size of the opening to access the pump. See the attached code reference.**

**Third attempt at final. \$50. re-inspection fee.**

**Ken Slattum  
Harnett County Code Official**



ADDRESS : 232 KIMBROUGH DR SUBDIV: WOODSHIRE PH 5  
CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503  
OWNER : CAVINESS LAND DEVELOPMENT INC PHONE :  
PARCEL : 01-0536-06- -0028- -29-  
APPL NUMBER: 09-50022447 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : WOODSHIRE SUB DIV #189, KIMBROUGH  
DRIVE. 27W, LEFT ON NURSERY RD, LEFT  
ON WOOD POINT DR, RIGHT KIMBROUGH DR.  
T/S: 07/13/2009 12:49 PM VBROWN ----

STRUCTURE: 000 000 58X48 4BDR 3BATH SFD WITH GAR, DECK, SLAB  
FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 4.00 PROPOSED USE : SFD  
SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/06/09 10/06/09	DT DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001831361 Footing not dug T/S: 10/06/2009 12:47 PM DETAYLOR -----
B101 02	10/08/09 10/08/09	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001832903
B103 01	10/16/09 10/16/09	DT AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001837631
A814 01	10/20/09 10/22/09	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001836981 232 kimbrough dr lot 189 ----- T/S: 10/22/2009 04:49 PM TWARD -----
P309 01	10/26/09 10/26/09	DT DA	R*PLUMB UNDER SLAB VRU #: 001841671 Drain must be sleeved through foundation wall. T/S: 10/26/2009 11:49 AM DETAYLOR -----
P309 02	10/27/09 3/09/10	DT AP	R*PLUMB UNDER SLAB VRU #: 001842518
B111 01	11/02/09 11/02/09	DT AP	R*BLDG SLAB INSP VRU #: 001844776
R425 01	11/25/09 11/25/09	DT DA	FOUR TRADE ROUGH IN VRU #: 001855371 1. Fire caulk three inch by fireplace. 2. Repair holes at upstairs tub. 3. Fire block top corners of upstairs gables. 4. Plumbing boots not installed. Okay to side. T/S: 11/25/2009 10:27 AM DETAYLOR -----
R425 02	12/02/09 12/02/09	DT AP	FOUR TRADE ROUGH IN VRU #: 001856735
I129 01	12/04/09 12/04/09	DT AP	R*INSULATION INSPECTION VRU #: 001857636
H824 01	1/05/10 1/05/10	BM AP	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001868546 T/S: 01/07/2010 10:48 AM SSTEWARD ----- T/S: 01/07/2010 10:48 AM SSTEWARD -----
R429 01	3/09/10 3/09/10	DT DA	FOUR TRADE FINAL VRU #: 001892385 1. Label a/c units. 2. a/c units on breakers larger than specified. 3. No insulation depth guages visible at rear of house. Install guages and additional insulation if necessary. T/S: 03/09/2010 01:45 PM DETAYLOR -----

-----  
ADDRESS . . : 232 KIMBROUGH DR SUBDIV: WOODSHIRE PH 5  
CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503  
OWNER . . . : CAVINESS LAND DEVELOPMENT INC PHONE :  
PARCEL . . . : 01-0536-06- -0028- -29-  
APPL NUMBER: 09-50022447 CP NEW RESIDENTIAL (SFD)  
-----

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R429 02	3/11/10 3/11/10	DT DA	FOUR TRADE FINAL VRU #: 001893348 Need access to jacuzzi tube in master. T/S: 03/11/2010 10:55 AM DETAYLOR -----
R429 03	3/12/10 3/12/10	KS <u>DP</u>	FOUR TRADE FINAL VRU #: 001894276 Access hole not large enough. see section 421 of plumbing code attached to violation sheet. T/S: 03/12/2010 09:29 AM KSLATTUM -----
R431 01	3/16/10 <u>3/16/10</u>	TI <u>AP DC</u>	FOUR TRADE FINAL >2500 TIME: 17:00 VRU #: 001895051 T/S: 03/15/2010 12:39 PM VBROWN -----

----- COMMENTS AND NOTES -----

County of Harnett  
Building Inspections Department  
Planning Services

Certificate of Compliance: \_\_\_ Occupancy: ✓

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential

Permit Numbers

Name: Caviness Land Development

Building: \_\_\_\_\_

Electrical: \_\_\_\_\_

Address: 232 Kimbrough Dr.

Insulation: \_\_\_\_\_

Lillington, NC 27546

Plumbing: \_\_\_\_\_

Mechanical: 09-50022447

MFG Home: \_\_\_\_\_

Date: 3/16/10

Building Official: [Signature]