Department of Environment, Health, and Natural Resources
Division of Environmental Health
On-site Wastewater Section

Sheet:
Property ID:
Lot #:
File #:
Code:

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Owner:
Address:
Applicant:
Date Evaluated: 8/3/09
Property Size:
Property Recorded:
Proposed Facility: 4 BEDROOM HOUSE Design Flow (.1949): 480 gpd
Location of Site:
Water Supply: [X] Public [ ] Individual [ ] Well [ ] Spring [ ] Other
Evaluation Method: [X] Auger Boring [ ] Pit [ ] Cut
Type of Wastewater: [X] Sewage [ ] Industrial Process [ ] Mixed

PROFILE #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 0-2%	0-48	G S	VFR NS/NP					S .8
		0-32	G S	VFR NS/NP					PS .8
2			HPR @ 32"	ROOT					
		0-48	G S	VFR NS/NP					S .8
3									

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	CON	CON
Site LTAR	.8	.8

Other Factors (.1946):
Site Classification (.1948): PS
Evaluated By: ~~AB~~ OT
Others Present: —

4x50' @ 24-30" = REPAIR