

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner:
 Address:
 Proposed Facility: DFD Design Flow (.1949): 480
 Location of Site:
 Water Supply: Public Individual Well
 Evaluation Method: Auger Boring Pit
 Type of Wastewater: Sewage Industrial Process

Applicant: 22543
 Date Evaluated: 7-31-09 8-3-4.50
 Property Size:
 Property Recorded:

Spring Other
 Cut
 Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapru Class	.1944 Restr Horiz	
1	L 3%	0-30	SL	FR GR NSWP					. 4
		30-49	SCL	FR 1.7 BK S.P.	40-42" 2.5% 42				
2	L 3%	0-24	SL	FR GR NSWP					. 4
		24-49	SCL	FR 1.7 BK S.P.	38-40" 2.5% 42				
3	L	0-22	SL	FR GR NSWP					. 4
		22-49	SCL	FR 1.7 BK S.P.	36-38" 7.5% 42				

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	CON	CON
	. 4	. 4

Other Factors (.1946): _____
 Site Classification (.1948): PS
 Evaluated By: [Signature]
 Others Present: