
ADDRESS . : 245 WOOD POINT DR SUBDIV: WOODSHIRE PH 5
 CONTRACTOR : CEBCO CONSTRUCTION INC PHONE : (910) 893-3331
 OWNER . . : KENNETH CUMMING LLC PHONE : (910) 893-5826
 PARCEL . . : 01-0536-06- -0028- -23-
 APPL NUMBER: 09-50022593 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 08/05/2009 08:58 AM VBROWN ----
 WOODSHIRE SUB DIV #183, AT INTERSECTION
 OF WOOD POINT DR AND KIMBROUGH DRIVE,
 HOUSE ON WOOD POINT DRIVE. 27W, LEFT
 ON NURSERY, LEFT ON WOOD POINT, LOT ON
 LEFT.

STRUCTURE: 000 000 58X58 4BDR 3BATH SFD WITH GAR DECK CRAWL
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/04/09 <u>9/4/09</u>	TI <u>APDT</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001817444

----- COMMENTS AND NOTES -----

ADDRESS . . : 245 WOOD POINT DR
 CONTRACTOR : CEBCO CONSTRUCTION INC
 OWNER . . . : KENNETH CUMMING LLC
 PARCEL . . . : 01-0536-06- -0028- -23-
 APPL NUMBER: 09-50022593 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 08/05/2009 08:58 AM VBROWN ----
 WOODSHIRE SUB DIV #183, AT INTERSECTION
 OF WOOD POINT DR AND KIMBROUGH DRIVE,
 HOUSE ON WOOD POINT DRIVE. 27W, LEFT
 ON NURSERY, LEFT ON WOOD POINT, LOT ON
 LEFT.

STRUCTURE: 000 000 58X58 4BDR 3BATH SFD WITH GAR DECK CRAWL
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4.00
 SEPTIC - EXISTING? : NEW SEPTIC

PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/04/09	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001817444
	9/04/09	AP	
B103 01	9/08/09	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001818028
	9/08/09	AP	
B105 01	9/11/09	TI	R*OPEN FLOOR VRU #: 001820088
	<u>9/11/09</u>	<u>AP DT</u>	

----- COMMENTS AND NOTES -----

ADDRESS . : 245 WOOD POINT DR SUBDIV: WOODSHIRE PH 5
CONTRACTOR : CEBCO CONSTRUCTION INC PHONE : (910) 893-3331
OWNER . . : KENNETH CUMMING LLC PHONE : (910) 893-5826
PARCEL . . : 01-0536-06- -0028- -23-
APPL NUMBER: 09-50022593 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 08/05/2009 08:58 AM VBROWN ----
WOODSHIRE SUB DIV #183, AT INTERSECTION
OF WOOD POINT DR AND KIMBROUGH DRIVE,
HOUSE ON WOOD POINT DRIVE. 27W, LEFT
ON NURSERY, LEFT ON WOOD POINT, LOT ON
LEFT.

STRUCTURE: 000 000 58X58 4BDR 3BATH SFD WITH GAR DECK CRAWL
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/04/09	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001817444
	9/04/09	AP	
B103 01	9/08/09	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001818028
	9/08/09	AP	
B105 01	9/11/09	DT	R*OPEN FLOOR VRU #: 001820088
	9/11/09	AP	
R425 01	9/28/09	TI	FOUR TRADE ROUGH IN VRU #: 001827688
	<u>9/28/09</u>	<u>DA JI</u>	

----- COMMENTS AND NOTES -----

ADDRESS : 245 WOOD POINT DR SUBDIV: WOODSHIRE PH 5
 CONTRACTOR : CEBCO CONSTRUCTION INC PHONE : (910) 893-3331
 OWNER : KENNETH CUMMING LLC PHONE : (910) 893-5826
 PARCEL : 01-0536-06- -0028- -23-
 APPL NUMBER: 09-50022593 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : T/S: 08/05/2009 08:58 AM VBROWN ----
 WOODSHIRE SUB DIV #183, AT INTERSECTION
 OF WOOD POINT DR AND KIMBROUGH DRIVE,
 HOUSE ON WOOD POINT DRIVE. 27W, LEFT
 ON NURSERY, LEFT ON WOOD POINT, LOT ON
 LEFT.

STRUCTURE: 000 000 58X58 4BDR 3BATH SFD WITH GAR DECK CRAWL

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/04/09	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001817444
	9/04/09	AP	
B103 01	9/08/09	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001818028
	9/08/09	AP	
B105 01	9/11/09	DT	R*OPEN FLOOR VRU #: 001820088
	9/11/09	AP	
R425 01	9/28/09	DT	FOUR TRADE ROUGH IN VRU #: 001827688
	9/28/09	DA	1. Need 10 psi on gas line Okay to side and insulate. T/S: 09/28/2009 12:48 PM DETAYLOR -----
A814 01	10/01/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001827697
	10/02/09	AP	245 wood point dr lot 183 ----- lillington 27546 T/S: 10/02/2009 11:24 AM TWARD -----
I129 01	10/05/09	TI	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001831445
	<u>10-5-9</u>	<u>AP-MR</u>	T/S: 10/05/2009 08:07 AM NTART -----
R427 01	10/05/09	TI	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001831437
	<u>10-5-9</u>	<u>AP-MR</u>	T/S: 10/05/2009 08:07 AM NTART -----

COMMENTS AND NOTES

Harnett County

INSPECTOR: IVR

DATE 10/29/09

ADDRESS . . : 245 WOOD POINT DR SUBDIV: WOODSHIRE PH 5
 CONTRACTOR : CEBCO CONSTRUCTION INC PHONE : (910) 893-3331
 OWNER . . : KENNETH CUMMING LLC PHONE : (910) 893-5826
 PARCEL . . : 01-0536-06- -0028- -23-
 APPL NUMBER: 09-50022593 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 08/05/2009 08:58 AM VBROWN ----
 WOODSHIRE SUB DIV #183, AT INTERSECTION
 OF WOOD POINT DR AND KIMBROUGH DRIVE,
 HOUSE ON WOOD POINT DRIVE. 27W, LEFT
 ON NURSERY, LEFT ON WOOD POINT, LOT ON
 LEFT.

STRUCTURE: 000 000 58X58 4BDR 3BATH SFD WITH GAR DECK CRAWL

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/04/09	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001817444
	9/04/09	AP	
B103 01	9/08/09	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001818028
	9/08/09	AP	
B105 01	9/11/09	DT	R*OPEN FLOOR VRU #: 001820088
	9/11/09	AP	
R425 01	9/28/09	DT	FOUR TRADE ROUGH IN VRU #: 001827688
	9/28/09	DA	1. Need 10 psi on gas line Okay to side and insulate. T/S: 09/28/2009 12:48 PM DETAYLOR -----
A814 01	10/01/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001827697
	10/02/09	AP	✓245 wood point dr lot 183 ----- lillington 27546 T/S: 10/02/2009 11:24 AM TWARD -----
I129 01	10/05/09	MR	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001831445
	10/05/09	AP	T/S: 10/05/2009 08:07 AM NTART ----- T/S: 10/05/2009 11:02 AM MREARIC -----
R427 01	10/05/09	MR	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001831437
	10/05/09	AP	T/S: 10/05/2009 08:07 AM NTART ----- T/S: 10/05/2009 11:02 AM MREARIC -----
H824 01	10/16/09	BM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001837863
	10/16/09	DA	PER BRYAN MCSWAIN ON HOLD FOR POWER LINE. T/S: 10/16/2009 10:09 AM SSTEWARD ----- T/S: 10/16/2009 10:10 AM SSTEWARD ----- T/S: 10/16/2009 10:11 AM SSTEWARD -----
H824 02	10/21/09	BM	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001840792
	10/21/09	AP	T/S: 10/22/2009 11:31 AM SSTEWARD ----- T/S: 10/22/2009 11:31 AM SSTEWARD -----
R429 01	10/29/09	TI	FOUR TRADE FINAL VRU #: 001843562

~~10/29/09~~ AP DT

COMMENTS AND NOTES

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: Residential

Conditional Use Permit No.: _____

Type of Construction: _____

Building Permit No.: _____

Owner of Building: Kenneth Cummings LLC

Electrical Permit No.: _____

Building Address: 245 Wood Point Dr.

Insulation Permit No.: _____

Zoning District: Hillington, NC 27546

Plumbing Permit No.: _____

Zoning Permit No.: _____

Mech. Permit No.: 09-50022543

Date: 10/29/09

Envir. C.O. No.: _____

[Signature]
Building Official

Zoning Official