

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner:                      Applicant:

Address:

Date Evaluated: 9/14/09

Proposed Facility:

Design Flow (.1949):

Property Size:

Location of Site:

Property Recorded:

Water Supply:

- Public       Individual       Well       Spring       Other

Evaluation Method:

- Auger Boring       Pit       Cut

Type of Wastewater:

- Sewage       Industrial Process       Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
	653-76	0-22	G/LS	VF-MMP					P. 6
		22-34	SBK/SC1	FV-SSP					
		34-42	G/SL	VF-MMP					
		0-28	G/SL	VF-NSNP					P. 2
		28-36	SBK/SC1	FV-SSP					
		36-48	G/LS	VF-NSNP					
		0-42	G/LS	VF-NSNP					P. 8
		0-48	G/S	VF-NSNP					P. 5
		0-48	G/LS	VF-NSNP					P. 8

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: [Signature] Others Present:
Available Space (.1945)			
System Type(s)	CON	CON	
Site LTAR	5	8	