

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: BAREFOOT, JONATHAN & Amy PROPERTY LOCATION: ADCOCK RD SUBDIVISION \_\_\_\_\_ LOT # \_\_\_\_\_

NEW  REPAIR  EXPANSION  Site Improvements required prior to Construction Authorization Issuance: \_\_\_\_\_

Type of Structure: SFD(53x59)

Proposed Wastewater System Type: CONVENTIONAL

Projected Daily Flow: 480 GPD

Number of bedrooms: 4 Number of Occupants: 8 max

Basement  Yes  No

Pump Required:  Yes  No  May be required based on final location and elevations of facilities

Type of Water Supply:  Community  Public  Well Distance from well 100 feet\* Permit valid for:  Five years  No expiration

Permit conditions: \_\_\_\_\_

Authorized State Agent: [Signature] Date: 8/31/09 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: BAREFOOT, JONATHAN & Amy PROPERTY LOCATION: ADCOCK RD SUBDIVISION \_\_\_\_\_ LOT # \_\_\_\_\_

Facility Type: SFD(53x59)  New  Expansion  Repair

Basement?  Yes  No Basement Fixtures?  Yes  No

Type of Wastewater System\*\* CONVENTIONAL (Initial) Wastewater Flow: 480 GPD

(See note below, if applicable  CONVENTIONAL (Repair))

Installation Requirements/Conditions

Septic Tank Size 1000 gallons Number of trenches 4

Pump Tank Size \_\_\_\_\_ gallons Exact length of each trench 100 feet Trench Spacing: 9 Feet on Center

Trenches shall be installed on contour at a Soil Cover: 6 inches

Maximum Trench Depth of: 18 inches (Maximum soil cover shall not exceed 36" above the trench bottom)

(Trench bottoms shall be level to +/-1/4" in all directions)

Pump Requirements: \_\_\_\_\_ ft. TDH vs. \_\_\_\_\_ GPM Aggregate Depth: 6 inches below pipe 2 inches above pipe

Conditions: WATERLINE MUST BE AT LEAST 10' FROM ALL PARTS OF THE SEPTIC SYSTEMS. ALL OTHER UTILITIES MUST NOT ENCRANCH ON ANY PARTS OF THE SEPTIC SYSTEM AREAS.

\*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: \_\_\_\_\_ Date: \_\_\_\_\_

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature] Date: 8/31/09

Construction Authorization Expiration Date: 8/31/14

HTE# 09-5-22702

Permit # 25658

# Harnett County Department of Public Health Site Sketch

ISSUED TO: BAREFOOT, JONATHAN & Amy PROPERTY LOCATOR: POCOCK RD  
SUBDIVISION \_\_\_\_\_ LOT # \_\_\_\_\_

Authorized State Agent: ~~[Signature]~~ RS (OLIVER TOLSON) Date: 8/31/09

