

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner:                      Applicant:

Address:

Date Evaluated: 9/18/09

Proposed Facility:

Design Flow (.1949):

Property Size:

Location of Site:

Property Recorded:

Water Supply:

Public                       Individual                       Well                       Spring                       Other

Evaluation Method:

Auger Boring                       Pit                       Cut

Type of Wastewater:

Sewage                       Industrial Process                       Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
		G-19	G/LS	Ufr NSNP					
		19-38	SBR/SCI	Fv SSSP	10 YR 8/1, 3 <sup>cl</sup>				PS.6
		G-36	G/LS	Ufr NSNP					PS.8
	*	G-15	G/LS	Ufr NSNP					
		15-35	SBR/SCI	Fv SSSP	10 YR 8/1, 3 <sup>cl</sup>				PS.6
	*								
		G-24	G/LS	Ufr NSNP					
		24-37	SBR/SCI	Fv SSSP	10 YR 8/1, 3 <sup>cl</sup>				PS.6
		G-18	G/LS	Ufr NSNP					
		18-37	SBR/SCI	Fv SSSP					PS.6

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: <i>BM</i> Others Present:
Available Space (.1945)			
System Type(s)	2PT	2PT	
Site LTAR	6	6	